30mm Hazardous Location Switches:







STANDARDS COMPLIANCE

	Switches	Pilot Lights	Meters
UL	Class I, Zone 1, AEx de IIC T6 Gb Class I, Div 2, Groups A, B, C and D	Class I, Zone 1, AEx de IIC T6 Gb Class I, Div 2, Groups A, B, C and D	Class I, Zone 1, AEx de IIC T6 Gb Class I, Div 2, Groups A, B, C and D
c-UL	Class I, Zone 1, Ex de IIC T6 Gb Class I, Div 2, Groups A, B, C and D	Class I, Zone 1, Ex de IIB T6 Gb Class I, Div 2, Groups C and D	Class I, Zone 1, Ex de IIC T6 Gb Class I, Div 2, Groups A, B, C and D
ATEX	, 3	Ex de IIC tD A21 IP65	© II2G Ex de IIC Gb

CERTIFICATE NUMBERS

UL/cUL	E347230
ATEX	PTB 08 ATEX 1053 U PTB 08 ATEX 1003 U

APPLICABLE STANDARDS

Products	Applicable Standards	Mark	Certifications
Pushbuttons Selector Switches Key Selector Switches Pilot Lights	EN60947-5-1	C€	EU Low Voltage Directive
5	FNCODAZ E E	TUV	TÜV SÜD
Emergency Stop Switches	EN60947-5-5	CE	EU Low Voltage Directive

PRODUCT DESCRIPTION

Complying with UL and ATEX Directives for hazardous environments, new 30mm EU2B Hazardous Location Switches provide increased safety for your applications.

Available models include:

- Pushbuttons
- Pilot Lights
- Selector Switches
- Key Selector Switches
- Emergency Stop Switches
- Meters

KEY FEATURES

- Class I, Zone 1/Division 2
- Applicable in explosive gas atmospheres (AEx de IIC T6 Gb)
- UL Type 4X rated
- Up to 3 contact blocks
- Selector switches available with lever or key
- Selector switches available with overlapping contacts
- Exposed and finger-safe (IP20) screw terminals available



IECEx is pending approval

1

SPECIFICATIONS

General Specifications

Degree of Protection	IP65 (IEC60529), Type 4X					
Insulation Resistance	100 MΩ minimum (500V DC megger)					
Operating Temperature	-20 to +50°C (no free	ezing)				
Operating Humidity	45 to 85% (no conder	nsation)				
Altitude	2,000m Maximum					
Pollution Degree	3					
Shock Resistance	Operating Extremes	100-m/s ² Emergency Stop Switch: 150-m/s ² (without Meter)				
	Damage Limits	1000-m/s ²				
Vibration Resistance	Operating Extremes	5 to 55-Hz, amplitude 0.5 mm Emergency Stop Switch: 5 to 500-Hz, amplitude 0.35-mm, acceleration 50-m/s² (without Meter)				
vibi audii nesistance	Damage Limits	30Hz, amplitude 1.5-mm Emergency Stop Switch: 5 to 500-Hz, amplitude 0.35-mm, acceleration 50-m/s ²				

Contact Rating (Switches)

Rated Insulation Voltage (Ui)				600V				
Rated Thermal Current (Ith)			10A*	10A*				
Rated Operating	24V	120V	240V	500V				
	AC 50/60Hz	Resistive Load (AC12)	10A*	10A*	6A	2.8A		
Rated Operat-		Inductive Load (AC15)	10A*	6A	3A	1.4A		
ing Current (le)	DC	Resistive Load (DC12)	8A	2.2A	1.1A	_		
		Inductive Load (DC13)	4A	1.1A	0.55A	_		

Note: Up to 2 contacts (per control unit): 10A

3 contacts (per control unit): 9A

Minimum applicable load: 3V AC/DC, 5mA

Applicable operating locations may vary according to operating conditions and load types.

Contact Rating	Thermal Continuous		Maximum current, Amperes					Maxir Volt-Ar			
Code	Test Current Amperes	120	Volt	240	Volt	480	Volt	600	Volt	600	Volt
Designation		Make	Break	Make	Break	Make	Break	Make	Break	Make	Break
A600	10	60	6.00	30	3.00	15	1.5	12	1.2	7200	720

Switches

Rated Insulation Volta	age	600V
Contact Resistance		$50m\Omega$ maximum (initial value)
Impulse Withstand Voltage (Uimp)		6kV
Insulation Resistance		$100M\Omega$ minimum (500V DC megger)
Short-Circuit Protecti	ion	250V/10A fuse (Type aM IEC60269-1/IEC60269-2)
Conditional Short-Cir	cuit Current	1,000A
	Pushbutton	1,000,000 operations minimum
Mechanical Life	Selector Switch	500,000 operations minimum
Wednamear Life	Key Selector Switch	500,000 operations minimum
	Emergency Stop Switch	50,000 operations minimum
	Pushbutton	250,000 (switching frequency 1800 operations/h)
Electrical Life	Selector Switch	250,000 (switching frequency 900 operations/h)
Electrical Life	Key Selector Switch	250,000 (switching frequency 900 operations/h)
	Emergency Stop Switch	50,000 (switching frequency 900 operations/h)
Minimum Operator Stroke Required for Direct Opening Action	Emergency Stop Switch	7.0mm
Maximum Operator Stroke	Emergency Stop Switch	9.0mm

Note: Contacts will bounce during operation of pushbuttons and selector switches (reference value: 20-ms). Be sure to take contact bounce time into consideration when designing a control circuit.

Pilot Lights

Rated Insulation Voltage (Ui)		500V
Poted Operating Voltage (Us)	Voltage	6V, 12V, 24V AC/DC
Rated Operating Voltage (Ue)	Transformer	120V, 230V, 240V, 380V, 480V AC
Impulse Withstand Voltage (Uimp)		4kV
Insulation Resistance		100 MΩ minimum (500V DC)
Frequency		50/60Hz
Dower Concumption (onney)	Full Voltage	0.3W
Power Consumption (approx.)	Transformer	1.5VA
Life (reference value)		Approx. 40,000 hours

Note: Because the built-in LED lamp is a high-brightness version, the lamp may light dimly due to induction even when power is off.

Meters

Accu	racy Class	2.5			
Insulation Resistance		100 MΩ minimum (500V DC megger)			
	Rated Insulation Voltage (Ui)	300V			
<u>-</u>	Operation	Moving core			
Jet	Impulse Withstand Voltage (Uimp)	4kV			
ammeter	Power Consumption	1VA			
a	Measurement	5A, 10A, 30A, 50A, etc			
AC	Input (CT Ratio)	1A, 5A			
	Extended Memory	3 times, etc			
_	Rated Insulation Voltage (Ui)	150V			
te	Operation	Moving coil			
ammeter	Impulse Withstand Voltage (Uimp)	2.5kV			
ап	Input	0 to10V DC, 4 to 20mA, etc.			
2	Power Consumption	0.15W			
_	Consumption Current	1mA			

Note: Use a commercially available CT (current transformer) for all AC ammeters, and install the CT in a non-hazardous location.

PART NUMBERS

Pushbuttons



Part Number Structure

EU2B - YB1 11 F S D Degree of Protection Operator (style / function)-Contact arrangement B1: Flush pushbutton / Momentary B2: Extended pushbutton / Momentary 10:1NO 01:1NC D: Type 4X -Button color Blank: Red, Green, Black, 20:2NO 02:2NC B3: Mushroom pushbutton / Momentary 30:3NO 03:3NC and White included 11:1NO-1NC 12:1NO-2NC Y:Yellow S:Blue 21:2NO-1NC Terminals F : Finger-safe terminal (IP20) C : Exposed screw terminal

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Style and Function	Contact Arrangement	Weight (Approx.)	① Button Color
EU2B-YB110@102		1NO	CO	
EU2B-YB101@102		1NC	68g	
EU2B-YB111@①②		1NO-1NC		1) Plank aunaliad with
EU2B-YB120@10@		2N0	92g	① Blank - supplied with red, green, black, and white
EU2B-YB102@102	Flush Momentary	2NC		buttons
EU2B-YB121@①②	,	2NO-1NC		For yellow or blue buttons, specify Y (yellow) or S
EU2B-YB112@①②		1NO-2NC	440	(blue).
EU2B-YB130@102		3N0	116g	
EU2B-YB103@102		3NC		
EU2B-YB210@102		1N0	70	
EU2B-YB201@102	Extended Momentary	1NC	70g	
EU2B-YB211@①@		1NO-1NC	94g	
EU2B-YB220412		2N0		
EU2B-YB202412		2NC		
EU2B-YB221@①②		2NO-1NC		
EU2B-YB212@①2		1NO-2NC	110	Specify a button color code in place of ① in the part
EU2B-YB230@①②		3N0	118g	number
EU2B-YB203@①②		3NC		B: black G: green
EU2B-YB310412		1N0	76g	R:red
EU2B-YB301@①②		1NC	, og	S: blue W: white
EU2B-YB311@①②		1NO-1NC		Y: yellow
EU2B-YB320@102		2N0	101g	
EU2B-YB302@①②	Mushroom Momentary	2NC		
EU2B-YB321@①②	,	2NO-1NC		
EU2B-YB312@10@		1NO-2NC	125g	
EU2B-YB3304①2		3N0	1239	
EU2B-YB303@102		3NC		

Note: ① Button Color.

For ②, select –D for Type 4X (UL only) version, or leave blank for IP65 (ATEX/UL) version. Specify a contact terminal style in place of ④ in the part number: F (Finger-safe terminal), C

(Exposed screw terminal)

For Type 4X models, installation of a rubber boot is required on flush and extended versions; see page 10 for ordering information. This is only applicable to the flush and extended pushbuttons. All other models are Type 4X without any boot.

Emergency Stop Switches



Part Number Structure

Per to style / function)

BV3 : 40mm mushroom/push, pull or twist release

11 : 1N0-1NC
02 : 2NC
03 : 3NC
12 : 1N0-2NC
15 : 1N0-2NC
16 : Exposed screw terminal

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Operator	Contact Arrangement	Weight (Approx.)	Button Color
EU2B-YBV301@R		1NC	96g	
EU2B-YBV311@R		1NO-1NC	100	
EU2B-YBV302@R	ø40 Mushroom	2NC	120g	R:Red
EU2B-YBV312@R		1NO-2NC	1.4.4	
EU2B-YBV303@R		3NC	144g	

Specify a terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

Pilot Lights



Part Number Structure

EU2B - YL1 22 F D R Operator (style / function) Lens/LED Colors L1 : Pilot Light / dome R: Red G: Green A: Amber Y:Yellow PW:White S:Blue Operating voltage 126: AC 120V (Transformer type) 66 : AC/DC 6V (Full voltage type) -Terminals 246: AC 240V (Transformer type) F: Finger-safe terminal (IP20) 11 : AC/DC 12V (Full voltage type) 386: AC 380V (Transformer type) 22 : AC/DC 24V (Full voltage type) C: Exposed screw terminal 486: AC 480V (Transformer type)

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number	Туре	Operating Voltage	Weight (Approx.)	① Illumination Color Code		
EU2B-YL1126@D①		120V AC				
EU2B-YL1236@D①		230V AC	150g	R:red G:green A:amber Y:yellow PW:white S:blue		
EU2B-YL1246@D①	Transformer	240V AC				
EU2B-YL1386@D①		380V AC				
EU2B-YL1486@D①		480V AC				
EU2B-YL166@D①	Full Voltage	6V AC/DC	108g			
EU2B-YL111@D①		12V AC/DC				
EU2B-YL122@D①		24V AC/DC				


Note: ① Illumination Color.

Specify a contact terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

Selector Switches



Part Number Structure




Note: Use only when interpreting part numbers. Do not use for developing part numbers.

2-Position Selector Switches

		Operator	Position	Maintained	Spring Return from Right	
Contact	Mounting	L	R	LR	LR	Weight (approx)
NO	1		•			
				EU2B-YS210@	EU2B-YS2110@	
						74g
				EU2B-YS201@	EU2B-YS2101@	
NC	3	•		L02D 10201©	LO2D 102101@	
NO	1		•			
				EU2B-YS220@	EU2B-YS2120@	
NO NO	3	_	•			
NC	1	•		EU2B-YS202@	EU2B-YS21024	98g
NC	3	•		EUZD-132UZ®	EUZD-132102⊕	oug
NO	1	-	•			
				EU2B-YS211@	EU2B-YS2111@	
NC	3	•				
NO	1		•			
NO NO	2		•	EU2B-YS230@	EU2B-YS2130@	
NC NC	3	•	•			
NC	2			EU2B-YS203@	EU2B-YS2103@	
NC	3	•		10200	1020 1021000	400
NO	1		•			122g
NO	2		•	EU2B-YS221@	EU2B-YS2121@	
NC	3	•				
NO NC	1 2	_	•	FUOD VOOAO	FUOD VOOMAGO	
NC NC	3			EU2B-YS212@	EU2B-YS2112@	
NO NO	1					
				EU2B-YS2R11@	N/A	98g
NC	2					

Specify a terminal style in place of \circledast in the part number: F (Finger-safe terminal), C (Exposed screw terminal)




2-Position Selector Switches (Inverse Cam)

		Operator	Position	Maintained	
Contact	Mounting	L	R	LR	Weight (approx)
NO	1	•		EU2B-YS2J10@	74g
NC	3		•	EU2B-YS2J01@	Ů
NO NO	3	•		EU2B-YS2J20@	
NC NC	3		•	EU2B-YS2J024	98g
NO NC	3	•	•	EU2B-YS2J11@	
NO NO NO	1 2 3	•		EU2B-YS2J30@	
NC NC NC	1 2 3		•	EU2B-YS2J03@	122g
NO NO NC	1 2 3	•	•	EU2B-YS2J21@	1229
NO NC NC	1 2 3	•	•	EU2B-YS2J12@	

3-Position Selector Switches

		Ор	erator Posi	tion	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two Way	
Contact	Mounting	L	¢ †	R	L C R	L C R	L C R	L C R	Weight (approx)
NO	1	•			EU2B-YS320®	EU2B-YS3120@	EU2B-Y\$3220@	EU2B-YS3320@	
N0	3			•					
NO NO	2 3	•		•	EU2B-YS320N1@	EU2B-YS3120N1@	EU2B-YS3220N1@	EU2B-YS3320N1@	
NC	1								
NC	3				EU2B-YS302@	EU2B-YS302⊕	EU2B-YS3202@	EU2B-YS3302⊕	
NC	2		•		EU2B-YS302N1@	EU2B-YS3102N1@3	EU2B-YS3202N1@3	EU2B-YS3302N1@	
NC NO	3								
NC	3				EU2B-YS311@	EU2B-YS311@	EU2B-YS3211@	EU2B-YS3311@	98g
NC	1			_					
NO	3			•	EU2B-YS311N1@	EU2B-YS3111N1@	EU2B-YS3211N1@	EU2B-YS3311N1@	
NO NO	1	•							
NC	2		•		EU2B-YS311N2@	EU2B-YS3111N2@	EU2B-YS3211N2@	EU2B-YS3311N2@	
NC	2		•		EU2B-YS311N34	EU2B-YS3111N3①	EU2B-YS3211N3①	EU2B-YS3311N3①	
NO	3			•					
NO	2	•		•	EU2B-YS311N4@	EU2B-YS3111N4@	EU2B-YS3211N4@	EU2B-YS3311N4@	
NC	3								
NO NO	2	•		•	EU2B-YS330@	EU2B-YS3130@	EU2B-YS3230@	EU2B-YS3330@	
NO	3			•					
NC	1			-					
NC	2		•		EU2B-YS303@	EU2B-YS3103@	EU2B-YS32034	EU2B-YS33034	
NC	3								122g
NO	1	•							
NC	2		•		EU2B-YS3 21N1@	EU2B-YS3121N14	EU2B-YS3221N1@	EU2B-YS3321N1@	
NO	3			•					
NC	1								
NO NC	2	•		•	EU2B-YS3 12N1@	EU2B-YS3112N1@	EU2B-YS3212N1@	EU2B-YS3312N1@	
NC	3								

Specify a terminal style in place of 4 in the part number: F (Finger-safe terminal), C (Exposed screw terminal)



Key Selector Switches



Part Number Structure

EU2B - YSK 2 11 N1 F A

	EUZD - 1 <u>3N Z I</u>	INICA		
Operator (style / function) SK: Key selector (Key operator)		— Contact arra 10 : 1NO	ngement 03 : 3NC	Key Removable Position See Key removable option codes below
Number of Positions / Spring Return Actio	n	11:1NO-1NC	02 : 2NC	Terminals
2 : 2-position / Maintained	3: 3 -position / Maintained	01:1NC	21 : 2NO-1NC	F : Finger-safe terminal (IP20)
2R: 2-position / Maintained (Overlap)	31: 3-position / Spring return from right	30:3NO	12 : 1NO-2NC	C : Exposed screw terminal
2J: 2-position / Maintained (Special function)	32 : 3-position / Spring return from left	20:2NO	L	—Circuit Number
21 : 2-position / Spring return from right	33 : 3-position / Spring return two-way			Blank : No Designation
	,			N* : See the following charts

Note: Use only when interpreting part numbers. Do not use for developing part numbers.


2-Position Key Selector Switches

		Operator Position	Maintained	Spring Return from Right	
Contact	Mounting	L R	LR	LR	Weight (approx)
NO	1	•	EU2B-YSK21043	EU2B-YSK2110@3	06a
NC	3	•	EU2B-YSK201@3	EU2B-YSK2101@3	96g
NO NO	3	•	EU2B-YSK220@3	EU2B-YSK2120@3	
NC NC	3	•	EU2B-YSK202@3	EU2B-YSK2102@3	120g
NO NC	3	•	EU2B-YSK211@3	EU2B-YSK2111@3	
N0 N0 N0	1 2 3	•	EU2B-YSK230@3	EU2B-YSK2130@3	
NC NC NC	1 2 3	•	EU2B-YSK203@3	EU2B-YSK2103@3	144g
NO NO NC	1 2 3	•	EU2B-YSK221@3	EU2B-YSK2121@3	144 <u>y</u>
NO NC NC	1 2 3	•	EU2B-YSK212@3	EU2B-YSK2112@3	
NO NC	2		EU2B-YSK2R11@3	N/A	120g

Key is removable in all maintained positions. Specify key removal position in place of $\@3$ in the part number. See table.

Specify a terminal style in place of \circledast in the part number: F (Finger-safe terminal), C (Exposed screw terminal).

Operator Position



The key can be released in any maintained position.

2-Position Key Selector Switches (Inverse Cam)

		Operator	Position	Maintained	
Contact	Mounting	L	R	LR	Weight (approx)
NO	1	•			
				EU2B-YSK2J10@3	
					96g
				FUED VOVE IN C.C.	
NC	3			EU2B-YSK2J01@3	
NO NO	ა 1	•	_		
INO				EU2B-YSK2J20@3	
NO	3	•		EOZD TORZOZOGO	
NC	1		•		
				EU2B-YSK2J02@3	120g
NC	3		•		
NO	1	•			
NC	3			EU2B-YSK2J11@3	
NO NO	1		•		
NO NO	2			EU2B-YSK2J30@3	
NO	3	•		EGED TOREGOOD	
NC	1		•		
NC	2		•	EU2B-YSK2J03@3	
NC	3		•		144g
NO	1	•			1779
NO NO	2	•		EU2B-YSK2J21@3	
NC NO	3	•	•		
NC	2			EU2B-YSK2J12@3	
NC	3		•	EOZD-TORZOTZ®®	
. • •	,				

③ Key Removable Option Codes (2-position)


Code	Description
Α	Key removable in any position
В	Key removable in left position
С	Key removable in right position

3-Position Key Selector Switches

		Ор	erator Positi	on	Maintained	Spring Return from Right	Spring Return from Left	Spring Return Two Way	
Contact	Mounting	r.	c †	R	L C R	L C R	L C R	$L \longrightarrow C \longrightarrow R$	Weight (approx)
NO	1	•							
NO	3				EU2B-YSK320@3	EU2B-YSK3120@3	EU2B-YSK3220@3	EU2B-YSK3320@3	
110	3								
NO	2	•		•	EU2B-YSK320N1@3	EU2B-YSK3120N1@3	EU2B-YSK3220N1@3	EU2B-YSK3320N1@3	
NO	3			_•					
NC	1			_	EU2B-YSK302@3	EU2B-YSK302@3	EU2B-YSK3202@3	EU2B-YSK3302@3	
NC	3				LOZD TOROUZOO	LUZB TURUUZUU	E02B 10N020200	E02B 10K0002@@	
NC	2		•		EU2B-YSK302N1@3	EU2B-YSK3102N1@3	EU2B-YSK3202N1@3	EU2B-YSK3302N1@3	
NC NO	3								
140	'				EU2B-YSK311@3	EU2B-YSK311@3	EU2B-YSK3211@3	EU2B-YSK3311@3	120g
NC	3								
NC	1								
NO	3			•	EU2B-YSK311N1@3	EU2B-YSK3111N1@3	EU2B-YSK3211N1@3	EU2B-YSK3311N1@3	
NO NO	1	•							
NC	2		•		EU2B-YSK311N2@3	EU2B-YSK3111N2@3	EU2B-YSK3211N2@3	EU2B-YSK3311N2@3	
NO	2				FLIOD VOIZO44NO @@	FLIOD VCI/O444NIO	FLIOD VOVOQUANDO	FLIOR VOVOQ44NO @@	
NC NO	2		•	•	EU2B-YSK311N3@3	EU2B-YSK3111N3@3	EU2B-YSK3211N3@3	EU2B-YSK3311N3@3	
	Ü			_					
NO	2	•		•	EU2B-YSK311N4@3	EU2B-YSK3111N4@3	EU2B-YSK3211N4@3	EU2B-YSK3311N4@3	
NC	3								
NO	1	•							
NO	2	•		•	EU2B-YSK330@3	EU2B-YSK3130@3	EU2B-YSK3230@3	EU2B-YSK3330@3	
NO	3			•					
NC	1								
NC	2		•		EU2B-YSK303@3	EU2B-YSK3103@3	EU2B-YSK3203@3	EU2B-YSK3303@3	
NC	3								144~
NO	1	•							144g
NC	2				EU2B-YSK321N1@3	EU2B-YSK3121N1@3	EU2B-YSK3221N1@3	EU2B-YSK3321N1@3	
					LUZD-TONOZ INTŒ	LUZD-TONOTZ INTO	LUZD-TONOZZINI (#)(3)	LUZD-TONOOZ HVI (4)(3)	
NO NC	3			_•					
NC NO	2	•			EU2B-YSK312N1@3	EU2B-YSK3112N1@3	EU2B-YSK3212N1@3	EU2B-YSK3312N1@3	
NC	3			•	LUZD-TOKOTZINI (4)(3)	LUZD-TONOTIZINI (4)(3)	LUZD-TONOZ IZINTO	LUZD-TONOOTZINI (4)(3)	

Key is removable in all maintained positions. Specify key removal position in place of ③ in the part number. See table.

Specify a terminal style in place of ④ in the part number: F (Finger-safe terminal), C (Exposed screw terminal) Key Removable Option Codes (3-Position)



The key can be released in any maintained position.

Code	Description
Α	Key removable in any position
В	Key removable in left and center positions
С	Key removable in center and right positions
D	Key removable in center position
E	Key removable in left and right positions
G	Key removable in left position
Н	Key removable in right position)

Meters



Part Number Structure - AC Ammeter

i ait italiibei otiaota	IU AUA					
	EU	2B - Y <u>I</u>	<u> </u>	<u> 10 F R</u>		
Function M: Meter Input current 1: 1A 5: 5A Specification of overloa 3: 3 times 2: 2 times 5 Type of meter A: AC ammeter		N:Non		Termin F : Fing	i als er-safe te	-R : with set pointer rminal (IP20) w terminal
Measuring range —						
Direct measuring		5 : 5A				
For current transformers:	10:10A	15 : 15A	20 : 20A	30:30A	50:50A	
	60:60A	75 : 75A	100:100A	150:150A	etc.	

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Part Number Structure - DC Ammeter or Voltmeter

	EU2B - Y <u>M</u> <u>010</u> <u>VD</u>	F-PER-R
Function M: Meter Input voltage or cu 010: 0-10V 001: 0-1mA 420: 4-20mA etc.	rrent Type of meter VD : DC voltmeter MD : DC ammeter	Set pointer blank: non -R: with set pointer -Specification of scale -PER: 0~100% -60HZ: 0~60Hz -80HZ: 0~80Hz etc.
Terminals F: Finger-safe termina C: Exposed screw ter		

Note: Use only when interpreting part numbers. Do not use for developing part numbers.

Input	Part Number	Description		Weight (approx.)
	EU2B-YM53A5@	Capacity: 5A	Expansion scale: x3	
	EU2B-YM53A10@	Capacity:10/5A	Expansion scale: x3	
	EU2B-YM13A10@	Capacity:10/1A	Expansion scale: x3	
	EU2B-YM53A15@	Capacity:15/5A	Expansion scale: x3	
	EU2B-YM13A15@	Capacity:15/1A	Expansion scale: x3	
	EU2B-YM13A20@	Capacity:20/1A	Expansion scale: x3	
AC input meter (ammeter)	EU2B-YM53A30@	Capacity:30/5A	Expansion scale: x3	
	EU2B-YM13A30@	Capacity:30/1A	Expansion scale: x3	
	EU2B-YM53A50@	Capacity:50/5A	Expansion scale: x3	
	EU2B-YM53A60@	Capacity:60/5A	Expansion scale: x3	270~
	EU2B-YM53A75@	Capacity:75/5A	Expansion scale: x3	270g
	EU2B-YM53A100@	Capacity:100/5A	Expansion scale: x3	
	EU2B-YM53A150@	Capacity:150/5A	Expansion scale: x3	
	EU2B-YM010VD@-PER	0-10V DC Input	Scale: 0 to 100%	
	EU2B-YM010VD@-60HZ	0-10V DC Input	Scale: 0 to 60Hz	
	EU2B-YM001MD@-PER	0-1mA DC Input	Scale: 0 to 100%	
DC input meter	EU2B-YM001MD@-60HZ	0-1mA DC Input	Scale: 0 to 60Hz	
	EU2B-YM001MD@-80HZ	0-1mA DC Input	Scale: 0 to 80Hz	
	EU2B-YM420MD@-PER	4-20mA DC Input	Scale: 0 to 100%	
	EU2B-YM420MD4-60HZ	4-20mA DC Input	Scale: 0 to 60Hz	


Specify a terminal style in place of \circledast in the part number: F (Finger-safe terminal), C (Exposed screw terminal)

DIMENSIONS

All dimensions in mm


Pushbuttons


Shown with finger-safe contacts



Pilot Lights

Shown with finger-safe contacts







67.7

20.3

Emergency Stop Switches


Shown with finger-safe contacts






Meters


Shown with finger-safe contacts






Selector Switches

Shown with finger-safe contacts






Mounting Hole Dimensions

Panel thickness: 1.0 to 4.5 mm.


*Note: The meter can be mounted on the top mounting holes of a standard 50mm mounting centers. The meter can be mounted on any mounting hole with


a 70mm or larger mounting center.



Key Selector Switch

Shown with finger-safe contacts






ACCESSORIES

All dimensions in mm

Nameplates

Used for pilot light, pushbutton, selector switch, and key selector switch.




Nameplate Inserts


Appearance	Legend	Part Number
	Blank	EU9Z-NP0
HAND OFF AUTO	ON	EU9Z-NP1
HAND OFF AUTO	OFF EU9Z-NP2	EU9Z-NP2
	START	EU9Z-NP3
ON	STOP	EU9Z-NP4
	OFF-ON	EU9Z-NP31
OFF	HAND-AUTO	EU9Z-NP35
	HAND-OFF-AUTO	EU9Z-NP53


Material: Aluminum

Installing the Insert to the Nameplate

Insert







To remove the Insert, insert a flat screwdriver between the Insert and Nameplate.

Rubber Boots

Appearance	Description/Usage	Part Number
For Flush Pushbuttons	Not for use with name plate	EU9Z-DB1
For Flush Pushbuttons	For use with name plate	EU9Z-DB1N
For Extended Pushbuttons	Not for use with name plate	EU9Z-DB2
For Extended Pushbuttons	For use with name plate	EU9Z-DB2N

Note: Rubber boot must be mounted on flush or extended pushbuttons to achieve UL Type 4X rating

Emergency Stop Switch Nameplate Stickers

Appearance	Legend	Part Number	Dimensions
	Blank	EU9Z-NVS0	040.5
STOP	Emergency Stop	EU9Z-NVS27	ENERGENC) 058

Material: synthetic paper Background: yellow Legend: black

Padlock Cover

EU2B-YB2 extended pushbutton: to maintain latched status
EU2B-YB1 flush pushbutton/EU2B-YSK key selector switch: to prevent operation

Appearance	Part Number	Dimensions
	EU9Z-PC	32.1

Material: Stainless Steel

Emergency Stop Switch Padlock Cover


Used with EU2B-YBV emergency stop switch to maintain the switch in the latched status.

Appearance	Part Number	Dimensions
	EU9Z-PCE	Base 9 32.2 32.2

Coating: yellow Material: Stainless Steel

Mounting Hole Plug

Used to plug unused mounting holes (ø30.5) on the mounting panel.



Buttons

Appearance	Style	Part Number	Button Color Code
	Flush	HW1A-B1⊕	Specify a color code in place of ①
	Extended	HW1A-B2①	in the Ordering Number. R:red G:green B:black Y:yellow
	ø40 Mushroom	HW1A-B4①	W:white S:blue

Material: Polyacetal

Lenses

Appearance	Lens Color	Part Number
	Red	EU9Z-LR
	Green	EU9Z-LG
	Amber	EU9Z-LA
	Yellow	EU9Z-LY
	White	EU9Z-LW
	Blue	EU9Z-LS

Material: AS resin (gasket supplied)

LED Lamps



Operating	Curre	nt Draw	Part	Illumination Color Code	Base
Voltage	AC	DC	Number	mammadon color codo	Биоо
6V AC/ DC±10%	8mA	7mA (A, R, W) 5.5mA (G, PW, S)	LSTD-6①	Specify a color code in place of ① in the part number	
12V AC/ DC±10%	11mA	10mA	LSTD-1①	R:red G:green A:amber PW:white S:blue Use a white (PW) LED with	BA9S/13
24V AC/ DC±10%	11mA	10mA	LSTD-2①	yellow (Y) lens.	

OPERATING INSTRUCTIONS

Wiring


Applicable Wires

Stranded wire: 1.5 to 2.5 mm², solid wire: \emptyset 1.2 to \emptyset 1.6 mm (AWG16 to 14) Note: Do not connect more than 2 wires to the same terminal.

Applicable crimping terminal

Ring and spade terminals cannot be used with IP20 finger-safe terminal blocks.

When connecting 2 ferrules to the EU2B control unit, use ferrules without insulating sheath.



Recommended crimping terminal (WAGO) Ferrule with insulating sheath: 216-204 Ferrule without insulating sheath: 216-104 Crimping plier: 206-204

Recommended Tightening Torque

EU2B control units (M3.5): 1.0 to 1.3 N·m

Warning

Incorrect wiring may cause fire hazard. Observe the following conditions.

- Be sure to install an insulating sheath on the crimping terminal or the crimping terminal with insulation.
- When connecting solid wires or stranded wires directly, strip the insulation, mentioned below, and insert the wire all the way in.

EU2B Control units: 8.6 mm maximum


Crimping terminal: 8 to 9 mm $\,$

- When using stranded wires, make sure that there are no wire whiskers.
- Make sure that the spade crimping terminals and ferrules are inserted all the way in.



Unit

To remove the contact unit or the lamp unit from the operator, pull the protruding yellow part of the locking lever outwards as shown in the figure below using a screwdriver, and turn it to the left. The contact unit or lamp unit can be removed.



When the contact unit is removed from the emergency stop switch operator, the NO contact closes and the NC contact opens.

Do not turn the locking lever when the contact unit is removed from the operator (the red indicator is protruding out. See the figure below) or the switch can be damaged.



Panel mounting for the operator, lens unit and meter

Remove the locking ring from the operator and check that the rubber gasket is in place. Insert the operator from the panel front into the panel hole. Place the projection on the operator with TOP marking upward and the recess on the mounting panel in the same direction. (The meter has no projection.)

Tighten the locking ring using ring wrench XN9Z-T1 to a torque of 2.5 Nm. When using a nameplate or padlocking cover, install it between the operator and panel. Make sure that the groove of the namplate or padlocking cover and the projection on the TOP marking of the operator are in the same direction.


Note: The locking ring for emergency stop switches and meter is metallic. The meter can't mount the nameplate or podlocking cover.


Installing the contact unit and lamp unit

To install the contact unit, place the TOP marking on the operator and the TOP marking on the contact block adapter in the same direction, and then attach the contact unit to the operator. Then turn the locking lever to the right. Follow the same procedure when installing the lamp unit.

When installing the lamp unit, check that the inner lens is not loose.


The contact block adapters for emergency stop switches cannot be used for the pushbutton, selector and key selector switches.





Removing the Contact Block

To remove the contact block, insert a flat screwdriver under the latch of the contact block adaptor and disengage the latch as shown in the figure below.



Installing the Contact block

When installing the contact block after maintenance or wiring, make sure that the contact configuration is correct. Installing the contact block in the incorrect position or incomplete installation may cause malfunction of the switch.

Remove the contact block from the operator before installing the contact block to the contact block adaptor. Also make sure that the contact block is correctly installed to the contact block adaptor before attaching the operator. Do not install the contact block adaptor with the operator attached. Otherwise, malfunction may result.

Accessories

Padlock Cover

The following padlocks and hasps can be used:

(Padlock Size)	a	b	C
Flush/extended pushbutton/key selector switch	ø3.5 to 7.0 mm	15 mm min.	70 mm max.
Emergency Stop Switch	ø5.5 to 7.0 mm	_	_

Recommended Hasp

Manufacturer	Part No.
Panduit	PSL-1, PSL-1A, PSL-1.5, PSL-1.5A, PSL-HD1
Master Lock	420, 421

Padlock and hasp are available in various shapes and sizes. Make sure that they do not interfere with the control units. Note: Not supplied by IDEC.

Keep the total weight of padlock and hasp under 1500g max, otherwise the switch may malfunction or result in failure. No vibration should be applied when padlock or hasp are installed. When padlock or hasp are disfigured, stop usage immediately.

Ensure that no shock or electric sparks are generated.

When using the plate lock padlock cover with the extended pushbutton, the switch contact may turn on/off when the cover is being installed. Ensure to provide functional safety measure to prevent unexpected startup.

When using the padlock cover on the safety-related part of the control system, observe safety standards and regulations of the relevant country or region. Also be sure to perform risk assessment before operation.


Installing EU9Z-PC Padlock Cover

(Flush/extended pushbtton/key selector switch)

EU9Z-PC can be installed in the following two ways.


Remove the cover in the reverse step of installing the cover. Do not install or remove the cover forcefully, or it will cause failure.

[Installation A]




[Installation B]

This method is effective when the neighboring control unit interferes when installing in method



Installing EU9Z-DB Rubber Boots

To install the rubber boot on flush and extended pushbuttons, place the rubber boot on the cap and push the rubber boot holder straight. The notches around the rubber boot must show evenly.



Push the rubber boot holder further around on the two notches on the holder so that the holder fits the button completely

Make sure that the rubber boot and rubber boot holder are installed straight.

On Nameplate Types, the EU2B and the rubber boot holder must be aligned so that when installed, the anti-rotation projection on the EU2B comes to the center of the groove on the holder.

Make sure that the rubber boot is installed completely, otherwise Type 4X degree of protection cannot be obtained. Water droplets might enter the rubber boot, but no water will enter the control box.



To remove the rubber boot from the flush and extended pushbuttons, gently insert the slotted screwdriver (0.5t x 4w or below) inside a notch on the rubber boot holder and tilt to the direction shown by the arrow ①. To prevent damage, do not apply excessive force to the EU2B when removing the rubber boot.



Maintenance and Inspection

EU2B switches should be installed in an appropriate control box.

Maintenance and Inspection Method

Perform daily or periodical maintenance and inspection for items such as damage and temperature rise of the EU2B switches listed in the Maintenance and Inspection table below.

Maintenance and Inspection

Inspection Items	Inspection Method	Inspections	Measures
Enclosure base	Visual	No rusting No damages	Cleaning Rust-resistant treat- ment
Tightening bolt, screws	Visual, tactile	No loosening No rusting	Tightening Cleaning
Packings	Visual	No cracks No apparent deforma- tion	Replacement
Connecting parts	Visual, tactile	No loosening of screws No dirt on insulation materials	Tightening Cleaning
Temperature rise	Thermometer, tactile	Surface temperature 80°C max.	Investigate the cause

Disposal

Observe laws and regulations set by each country concerning refuse disposal.

Safety Precautions

Use EU2B switches that are applicable for use in hazardous areas (potentially explosive atmosphere where explosive gas or vapor may exist), otherwise explosion or fire hazard may result.

- EU2B switches can be installed only in zones 1 and 2. Do not use in zone 0.
- Turn power off to the EU2B switches before installation, removal, wiring, or maintenance, otherwise explosion, fire hazard, or electric shock may result.
- Do not disassemble, repair, or modify, otherwise damage or accident may result.
- Do not use damaged EU2B switches, otherwise damage or accident may result.
- When connecting external devices, make sure that each cable is connected to the correct terminal, otherwise electric shock, fire hazard, or explosion may result.
- Use wires of a proper size to meet voltage and current requirements. Incorrect wiring may
 cause abnormal temperature rise and lead to fire hazard and explosion.
- Connect the grounding terminal to a proper ground, otherwise electric shock, fire hazard, or explosion may result.
- Operate the EU2B switches at the rated current and voltage specified in this catalog, otherwise short-circuiting, fire hazard, or explosion may result.
- Stop operation immediately if abnormal operation occurs. Otherwise, a secondary accident may occur.



X-ON Electronics

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Other Tools category:

Click to view products by Idec manufacturer:

Other Similar products are found below:

CR-05FL7--150R CR-05FL7--698K 899-2-KT46 899-5-KT46 CR-0AFL4--332K CR-12FP4--260R CRCW04021100FRT7

CRCW04021961FRT7 5800-0090 CRCW04024021FRT7 CRCW040254R9FRT7 CRCW0603102JRT5 59065-5 00-8273-RDPP 00-8729-WHPP 593033 593058 593072 593564100 593575 593591 593593 011349-000 CRCW08052740FRT1 LUC-012S070DSM LUC-018S070DSP 599-2021-3-NME 599-JJ-2021-03 00-5080-YWPP 5E4750/01-20R0-T/R LW1A-L1-GL LW1A-P1-GD LW1L-A1C10V-GL LW1L-M1C70-A 0202-0173 00-9089-RDPP 00-9300-RDPP CRCW2010331JR02 01-1003W-8/32-10 601-GP-08-KT39 601-JJ-06 601-SPB 601YSY 602-JJ-03 602SPB 602Z 603-JJ-07-FP 603-JJY-04 604J 604-JJ-05