

## Fluke RLD2 Leak Detector Flashlight

### Technical Data



RLD2 in leak detection mode

### Features

Compact UV flashlight uncovers refrigerant leaks instantly.\* The RLD2 combines leak detection ability with a bright flashlight to illuminate dark areas along with a laser pointer to pinpoint a leak.

- Instantly highlights leak detection dyes
- White LED light with 100,000 hour life
- Leak detection made easy
  - Vivid UV refrigerant leak detector finds the fault fast
  - Laser pointer pinpoints leak location
  - Bright flashlight with three LEDs penetrates dark areas
  - Key chain carabiner for convenience

\*For use with standard leak detection dyes available in the market.








RLD2 with standard carabiner

## Specifications

- Six UV/Blue LEDs highlight leak detection dyes
  - For use with standard leak detection dyes available in the market
- Laser pointer locates center of UV/Blue field
- Three white LED flashlight with 100,000 hour LED life
- Operating temperature: 0 °C to 50 °C (32 °F to 122 °F)
- Includes detachable key chain carabiner and AAA batteries
- One-year warranty

## Functions

<p><b>First Mode</b> <b>Flashlight</b></p> <p>First press activates unit and it is in the <b>LAST mode</b> selected</p> <p><b>TRIGGER</b> press turns <b>ON</b> flashlight*</p> 	<p><b>Second Mode</b> <b>UV light and Laser light</b></p> <p>Second press changes unit to the <b>COMBO mode</b></p> <p><b>TRIGGER</b> press turns <b>ON</b> UV light and laser light</p> 	 <p><b>1</b> Press indentation on top of battery door and slide downward</p> <p><b>2</b></p> <p><b>3</b></p> <p>Battery access.</p>
<p><b>Third Mode</b> <b>UV light</b></p> <p>Third press changes unit to the <b>NEXT mode</b></p> <p><b>TRIGGER</b> press turns <b>ON</b> UV light</p> 	<p><b>Fourth Mode</b> <b>Laser light</b></p> <p>Fourth press changes unit to the <b>NEXT mode</b></p> <p><b>TRIGGER</b> press turns <b>ON</b> laser light</p> <p><b>NEXT</b> Press changes unit <b>BACK</b> to original flashlight</p> 	

\*By holding in **TRIGGER** and then pressing **MODE** button the unit **LOCKS** into **FLASHLIGHT** mode- next **TRIGGER** press will release **LOCKED** state. This only occurs for the **FLASHLIGHT** mode.

## Ordering information

**RLD2** Leak Detector Flashlight

### Included accessories

Key chain carabiner and batteries.

Standard leak detection dyes are not sold by Fluke.

**Fluke.** Keeping your world up and running.®

### Fluke Corporation

PO Box 9090, Everett, WA 98206 U.S.A.

### Fluke Europe B.V.

PO Box 1186, 5602 BD Eindhoven, The Netherlands

### For more information call:

In the U.S.A. (800) 443-5853 or Fax (425) 446-5116  
 In Europe/M-East/Africa +31 (0) 40 2675 200 or Fax +31 (0) 40 2675 222  
 In Canada (800)-36-FLUKE or Fax (905) 890-6866  
 From other countries +1 (425) 446-5500 or Fax +1 (425) 446-5116  
 Web access: <http://www.fluke.com>

©2009 Fluke Corporation. Specifications subject to change without notice. Printed in U.S.A. 4/2009 3471674 D-EN-N Rev A

Modification of this document is not permitted without written permission from Fluke Corporation.



## X-ON Electronics

Largest Supplier of Electrical and Electronic Components

*Click to view similar products for [Environmental Test Equipment](#) category:*

*Click to view products by [Fluke](#) manufacturer:*

Other Similar products are found below :

[CW40](#) [F150C10E3DRT](#) [F150LTC20](#) [F150CD10E2](#) [F150L75](#) [F150LRS](#) [S-11](#) [FLUKE-LDG](#) [382153](#) [FM100](#) [RH210](#) [382253](#) [MO290-P](#)  
[GEO-CABLE-REEL-50M](#) [T197914](#) [RD300-L](#) [IR11BD](#) [IR11GM](#) [IR12GM](#) [IR21BD](#) [IR31CE](#) [IR32BC](#) [IR33BC](#) [MP7217TC](#) [NGM-1](#) [SGX-](#)  
[7NH3](#) [UT381](#) [F150-SLC50](#) [AW-CO-1000](#) [AW-NmHc-100](#) [3.000.401](#) [AX-7535](#) [CS-9S6SS-A](#) [P 2800 A](#) [P 2801](#) [P 2802](#) [P 5039](#) [P 5130](#) [P](#)  
[5055](#) [P 5060](#) [P 5065](#) [P 5086](#) [P 5090](#) [P 5110](#) [P 5115](#) [P 5135](#) [P 5140](#) [P 5145](#) [P 5150](#) [P 5160](#)