



Model No. PEL00581

NON MAINTAINED TWIN SPOTLIGHT WALL MOUNT LED EMERGENCY LIGHT

Please read these instructions carefully before starting installation and retain for future reference. The centre page test record can be removed and kept with the building fire safety records.

IMPORTANT SAFETY INFORMATION

RISK OF ELECTRICAL SHOCK. ALWAYS ISOLATE THE POWER AT THE MAINS BEFORE INSTALLING OR MAINTAINING THIS EMERGENCY LIGHT.

- This product must be installed by a competent person in accordance with the Building Regulations and the current edition of the IET Wiring Regulations (BS7671).
- This product is suitable for mounting on normally flammable surfaces such as wood, plasterboard or masonry.
- Emergency light fittings should have their own separate mains circuit, protected with an appropriate MCB or fuse. They should not share their supply with other lighting or electrical equipment.
- The emergency light is suitable for connection to a 220-240V~ 50Hz.
- This emergency light is for indoor use only.
- This product will only illuminate in the event of a mains failure (non-maintained).
- Ensure that after installation the emergency light remains accessible for regular maintenance and testing.

INSTALLATION

NOTE: Before drilling any holes, check that there are no hidden obstructions behind the mounting surface such as pipes or cables.

- 1. Undo the four screws on the front of the main body and lift the panel off.
- 2. The position of the cable entry and fixing holes are marked on the case. Remove and open out as required.
- 3. Using the back of the product as a template, mark the position of the fixing holes on your mounting surface (see fig 1).
- 4. Drill the fixing holes and fit wall plugs as appropriate.
- 5. Secure the back of the product to the mounting surface using suitable fixings (not supplied).
- 6. Fit a cable gland (not supplied) into the cable entry hole. Apply silicone sealant to the fixings if moisture or weatherproofing is required.
- 7. Thread the supply cable through into the product and fit the cable retainer.
- 8. Make connection to the supply using the terminal block on the PCB. Ensure that the correct polarities are observed i.e.:
 - Brown Live terminal 'L'
 - Blue Neutral terminal 'N'
- 9. Write the current date on the battery pack.
- 10. Connect the battery pack terminal connector to the connector on the PCB.
- 11. Fit the front cover and restore the power supply. The green LED should light to show the battery is being charged.
- 12. Perform the electrical tests specified in the Wiring Regulations (BS7671).

Test Record Sheet on reverse PULL OUT

Installation, maintenance a

Location:

Installation date:

Installed by:


		20		20		2	
Month	Test	Sign	Date	Sign	Date	S	
1	Short						
2	Short						
3	Short						
4	Short						
5	Short						
6	1 h						
7	Short						
8	Short						
9	Short						
10	Short						
11	Short						
12	3h						

nd operation check record

Installation test duration:

0		20		20	
Sign	Date	Sign	Date	Sign	Date

Test Record Sheet on reverse PULL OUT



OPERATIONAL CHECKS

Note: This equipment must be checked regularly in compliance with local regulation and codes of practice. For your own safety, testing should occur during the day.

The LED's can be tested by pressing the TEST button on the bottom of the case.

- After installation, you should allow 24 hours for the battery pack to charge fully before testing.
- Isolate the power supply and check that the lamp remains illuminated for at least three hours. Restore the power supply.
- Each day: Check that the green charging LED is lit.
- Each month (short test): Isolate the power supply and check that the lamp remains illuminated. Record the results on the test record sheet included with these instructions.
- Every six months: Isolate the power supply and check that the lamp remains illuminated after 1 hour. Record the results on the included test record.
- Once each year: Isolate the power supply and check that the lamp is still illuminated after 3 hours. Record the results on the included test record.

Please keep these test records in a safe place. A fire officer or other authorised person may want to see your record of inspection and testing.

CLEANING AND MAINTENANCE

- Clean the product with a soft, dry cloth only. Do not use any solvents or abrasive chemical cleaners.
- The LED lamps in this product are non-replaceable.

Changing the battery

- If after a routine operation check, the lamp does not remain lit for the 3 hour period, a new battery pack may be required. Change the battery pack as follows:
- 1. Isolate from the mains supply.
- 2. Remove the front panel.
- 3. Unplug the battery pack connector from the PCB.
- 4. Remove the old battery pack.
- 5. Write the current date on the new battery pack.
- 6. Secure the new battery pack in position and connect the wiring terminal connector.
- 7. Refit the cover. Make sure that the screws are securely fastened.
- 8. Restore mains power and allow to charge for 24 hours.
- 9. Perform the full operation check and update the test record.

Changing the fuse

- 1. Isolate from the mains supply.
- 2. Remove the front cover.
- Remove the fuse from it's housing and replace with one of the same type (240V F3A).
- 4. Refit the front cover making sure that it is securely screwed in place.
- 5. Test the operation.

Self Test Fault Warning

- If the battery has failed, the alarm will sound at one minute intervals and the yellow indicator LED will flash. If the main lamp LED has failed, the alarm will sound every half minute and the yellow indicator will flash at about 1 second intervals.
- The fault alarm may be silenced using the test switch.

Manual Test Operation:

- Press the "Test" button for 1 second: green LED will go off and a lamp test will run briefly.
- Press the "Test" button for 3 seconds: green LED will flash and a function test will run for 30 second simulating a mains power failure.
 Press the "Test" button for 5 seconds: green LED will flash and a battery duration test will run for 3 hours.
- Press the "Test" button for 10 seconds, all 3 LED indicators will flash 3 times and the lamps and functions will be reset to normal operation.

Input voltage:	220-240V~, 50Hz		
Rated power:	5W		
Lamps:	SMD2835 LEDs x 60pcs		
Luminous flux:	600 lm		
Continuous emergency illumination:	> 3 hours (when the battery is fully charged)		
Battery pack:	Ni-Cd, 3.6V, 6Ah		
Recharge time:	24 hours – approx.		
Ambient temperature:	0 - 35°C		
Over-discharge protection:	Yes		
Ingress protection rating:	IP65		

SPECIFICATIONS



INFORMATION ON WASTE DISPOSAL FOR CONSUMERS OF ELECTRICAL & ELECTRONIC EQUIPMENT.



When this product has reached the end of its life it must be treated as Waste Electrical & Electronic Equipment (WEEE). Any WEEE marked products must not be mixed with general household waste, but kept separate for the treatment, recovery and recycling of the materials used. Waste batteries can be returned to any waste battery recycling point which are provided by most battery retailers. Contact your local authority for details of battery and recycling schemes in your area.

X-ON Electronics

Largest Supplier of Electrical and Electronic Components

Click to view similar products for pro elec manufacturer:

Other Similar products are found below :

 PE01004
 PE01003
 LMP-G60BCW07-02B
 PSG91116
 PEL00582
 PEL00418
 PEL00217
 PEL00156
 PEL00170
 PEL00175
 PEL00251

 PEL00417
 PEL00581
 PEL00346
 PEL00350
 PEL00291
 PEL00153
 PEL00061
 PEL00199
 PEL00371
 PE01005
 PEL00414
 JR60431

 PEL00091
 PEL00075
 PEL00222
 PEL00144
 PEL00227
 PEL00151
 PEL00154
 PEL00281
 LMP-G60E27W07-02B
 PSG91112
 2213U 2.4A

 PEL00093
 PEL00223
 PEL00051
 HS-5626
 1518C WHT
 PEL00221
 PEL00225
 PEL00157
 PEL00162
 PEL00163

 PEL00231
 PE000031
 PC2213U
 PEL00347