

POWER TRANSFORMER MOUNT: WORLD SERIES

VPP10-2000

Electrical Specifications (@25C)

1. Maximum Power: 20.0VA

2. Input: Series: 230VAC, 50/60Hz; Parallel: 115VAC, 50/60Hz 3. Output: Series¹: 10.0V CT@ 2.00A; Parallel²: 5.0V @ 4.0A 4. Voltage Regulation: 25% TYP @ full load to no load

5. Temperature Rise: 30C TYP (45C MAX allowed)

6. Insulation Resistance: $100M\Omega$

7. Hipot: 4000VAC between primary to secondary and windings to core.

8. Recommended Fuse³:

Series: Littelfuse p/n 313 2.5HXP, 2.5A 250V, slow blow, 1/4 x 1 1/4 or, Cooper Bussmann p/n BKMDL-2, 1/2 A 250V, 1/4 x 1 1/4 Parallel: Littelfuse p/n 313 5.0HXP. 5A 250V. slow blow. 1/4 x 1 1/4 or. Cooper Bussmann p/n BKMDL-5, 5A 250V, 1/4 x 1 1/4

Construction:

Dual bobbin construction with an insulated shroud, both made of a high temperature material that exceeds UL flammability requirements.

Safety:

Since the dual bobbin construction effectively reduces capacitance, electrostatic shielding is not required. World Series Transformers are designed and manufactured to meet the following agency approvals:







Agency File:

UL: File E53148, UL 5085-1 and 2 (formerly UL 506), General Purpose. UL: File E65390, UL 5085-1 and 3 (formerly UL1585), Class 2/3.

CSA: File LR 221330. C22.2 NO. 66, General Purpose.

TUV: File R72103639, EN 60950, (IEC950) information Technology Equipment.

A. Dimensions: Units: In inches

Α	В	С	D	Е	F	G	Н
1.500	1.625	.187	.400	.400	1.875	2.250	1.460

B. PIN DIM.: 0.036 SQ C. WT Lbs.: 0.90

D. Mounting Holes: .112 dia. x 2.

Connections⁴:

Input: Series - Pin 1 to Pin 6, Jumper Pin 4 to Pin 3

Parallel - Pin 1 to Pin 6, Jumper Pin 1 to Pin 4 and Pin 3 to Pin 6

Output: Series – Pin 7 to Pin 12, Jumper Pin 9 to Pin 10

Parallel – Pin 7 to Pin 12, Jumper Pin 7 to Pin 10 and Pin 9 to Pin 12

RoHS Compliance: Meets the requirements of 2002/95/EC, known as the RoHS initiative.

* Upon printing, this document is considered "uncontrolled". Please contact Triad Magnetics' website for the most current version



² Non-Inherently limited. Class 2.


³ Fuse must be used on **secondary** as conditions of acceptability for UL Class2/3 operation.

Primary and secondary windings are designed to be connected in series or parallel. Winding are not intended to be used independently.

Web: www.TriadMagnetics.com Phone 951-277-0757 Fax 951-277-2757

22520B Temescal Canyon Road Corona, California 92883





SCHEMATIC

Publish Date: November 7, 2012