Compact Power Line Shelves Dual I²C shelves for the CP3500 rectifier Model: J2014003



Features

- Mounts into standard 19" EIA-310-D racks
- Isolated output feed may be grounded at either polarity
- +5V standby power isolated from the main output
- Adjustable mounting ears for flush or set back positions.
- Supports hot-swapping of modules
- Accommodates mechanical latching into the slot
- Communicates via PMBus™ compliant dual, redundant I²C
- Passes Zone 4 earthquake requirements
- CUR*† recognized
- CE Mark (pending)§
- Shock & Vibration: Meets IPC 9562 Class II standards

Description

The J2014003 type shelves accommodate up to 4 CP3000/CP3500AC54TE and similar rectifiers in a standard 19" EIA-310-D mounting configuration. The shelf is stackable and parallelable for higher power capacity needs. Parallelability is limited to four shelves when utilizing a single I²C bus, configuring the rectifiers with up to 16 different address possibilities. The shelf address is selected by a rotary switch accessible at the rear of the shelf. The L001 shelf has individual Molex input feed connectors for each rectifier. The shelf provides the interfacing connections to either a single PMBus™ compliant I²C bus, or to dual/redundant PMBus™ compliant I²C busses for applications where duplicated control and monitoring of the power system are desired. The two independent I²C busses have their own dedicated connections to the two external controllers. A fault to one of the I²C busses should not propagate to the other bus. A built in steering circuit ensures that control is granted to only one of the controllers at any time. Taking over control is granted only during idle communication states. Both controllers are informed when changes are granted.

- * UL is a registered trademark of Underwriters Laboratories, Inc.
- [†] CSA is a registered trademark of Canadian Standards Association.
- [‡] VDE is a trademark of Verband Deutscher Elektrotechniker e.V.
- § This product is intended for integration into end-user equipment. All *CE* marking procedures of end-user equipment should be followed. (The CE mark is placed on selected products.)
- ** ISO is a registered trademark of the International Organization of Standards



March 14, 2017

Absolute Maximum Ratings

Stresses in excess of the absolute maximum ratings can cause permanent damage to the device. These are absolute stress ratings only, functional operation of the device is not implied at these or any other conditions in excess of those given in the operations sections of the data sheet. Exposure to absolute maximum ratings for extended periods can adversely affect the device reliability.

| Parameter | Symbol | Min | Max | Unit |
|---|------------------|-----|------|-----------------|
| Input Voltage: Continuous | VIN | 0 | 300 | Vac |
| Operating Ambient Temperature ¹ | TA | -40 | 65 | °C |
| Storage Temperature | T _{stg} | -40 | 85 | °C |
| I/O Isolation voltage to Frame (100% factory Hi-Pot tested) | | | 2250 | V _{ac} |

Electrical Specifications

Unless otherwise indicated, specifications apply over all operating input voltage, load, and temperature conditions.

| INPUT | | | | | |
|------------------------------|-----------------|-----|---------|-----|-----------------|
| Parameter | Symbol | Min | Тур | Max | Unit |
| Operational Range | VIN | 85 | 110/230 | 300 | V _{AC} |
| Frequency Range | Fin | 47 | 50/60 | 63 | Hz |
| AC Input Current, per module | l _{in} | | | 20 | A _{AC} |

| MAIN OUTPUT | | | | | | |
|---|--------------------------|--------|-----|-----|--------|-----------------|
| Parameter | | Symbol | Min | Тур | Max | Unit |
| Output Power | $V_{in} > 200V_{AC}$ | W | 0 | - | 14,000 | W |
| | $V_{in} \leq 140 V_{AC}$ | VV | 0 | - | 6,000 | W |
| Max output current | | IOUT | | | 270 | A _{DC} |
| Isolation Output/frame – other circuits | | V | 100 | | | V _{DC} |

| AUXILIARY OUTPUT | | | | | |
|--|------------------|-----|-----|-----|-----------------|
| Parameter | Symbol | Min | Тур | Max | Unit |
| Set point | V _{OUT} | | 5.0 | | V _{DC} |
| Output current | lout | 0 | | 8 | ADC |
| Isolation Output/Frame | V | 50 | | | V _{DC} |
| Output/Main output | V | 50 | | | V _{DC} |
| The auxiliary output is accessible to the user via a two position panel mounted connector capable of carrying 9A of current. | | | | | |

¹ See the derating guidelines published in the rectifier data sheet

General Specifications

| Parameter | Min | Тур | Max | Units | Notes | | |
|-----------------------------|---------|--|-----|---------|--|--|--|
| Reliability | | 14,000,000 ² | | Hrs | Full load, 25°C ; MTBF per SR232 Reliability protection for electronic equipment, issue 2, method I, case III, | | |
| Service Life | | 10 | | Yrs | Full load, excluding fans | | |
| Unpacked Weight | | | | Kgs/Lbs | | | |
| Packed Weight | | 5.53/12.2 | | Kgs/Lbs | | | |
| Safety/Standards Compliance | | | | | | | |
| Safety Standards | UL6095 | UL60950-1, CAN/CSA C22.2 No 60950-1, EN60950-1 | | | | | |
| Certification Marks | CE mark | CE mark, UL Recognized (Canada and U.S.) | | | | | |

Environmental Specifications

| Parameter | Min | Тур | Max | Units | Notes |
|----------------------------------|--------|-----|-----------------|-------|--|
| Ambient Temperature Operating | -403 | | 50 ⁴ | °C | |
| Storage | -40 | | 85 | °C | |
| Humidity Operating Storage | 5 5 | | 95 95 | % | Relative humidity, non-condensing |
| Shock and Vibration acceleration | | | 6 | Grms | NEBS GR-63-CORE, Level 3, 20 -2000Hz, min 30 minutes |
| Earthquake Rating | 4 | | | Zone | NEBS GR-63-CORE, all floors, Seismic Zone 4 Designed and tested to meet NEBS specifications. |

EMC

| Parameter | Criteria | Standard | Level | Test |
|---------------------|----------------------|--|-------|-----------------------------|
| Conducted emissions | AC input | EN55022, FCC Docket 20780 part 15, subpart J | А | 0.15 – 30MHz |
| | | EN61000-3-2 Meets Telcordia GR1089-CORE by a 6dB margin | | 0 – 2 KHz |
| Radiated emissions | | EN55022 by a 6dB margin | А | 30 – 10000MHz |
| Lightning surge | AC input | EN61000-4-5, Level 4, 1.2/50µs – error free | А | 4kV, common mode |
| | | | А | 2kV, differential mode |
| | | ANSI C62.41 - damage free | A3 | 6kV, common & differential |
| Fast transients | Input immunity | EN61000-4-4, Level 3 | В | 5/50ns, 2kV (common mode) |
| Conducted RF fields | Enclosure immunity | EN61000-4-6, Level 3 | А | 130dBµV, 0.15-80MHz, 80% AM |
| Radiated RF fields | | EN61000-4-3, Level 3 | А | 10V/m, 80-1000MHz, 80% AM |
| | | ENV 50140 | А | |
| ESD | AC input & DC output | EN61000-4-2, Level 3 | В | 6kV contact, 8kV air |

² Estimated based on comparable calculations of similar shelves

³ Designed to start and work at an ambient as low as -40°C, but may not meet operational limits until above -5°C

⁴ At 277V input line operation the maximum ambient is reduced to 50°C. Power Derating with Temperature is 2%/°C above 55°C. Power Derating with Altitude is 2%/305m(1000 ft) above 1524m(5000 ft). Max operational altitude is 3962m(13000 ft). See the safety section for further limitations.

Communication Signals: J1 Connector

| Pin out | | | | | | | | |
|---------|-------------|--|-----|------------------|--|--|--|--|
| Pin | Signal | | Pin | Signal | | | | |
| 1 | POWER_CAP_1 | | 16 | SDA_1 | | | | |
| 2 | POWER_CAP_2 | | 17 | Fault | | | | |
| 3 | POWER_CAP_3 | | 18 | Alert#_0 | | | | |
| 4 | POWER_CAP_4 | | 19 | Enable side B | | | | |
| 5 | MOD_PRES_1 | | 20 | Logic_GRD | | | | |
| 6 | MOD_PRES_2 | | 21 | Enable Side A | | | | |
| 7 | MOD_PRES_3 | | 22 | Logic_GRD | | | | |
| 8 | MOD_PRES_4 | | 23 | Alert#_1 | | | | |
| 9 | PFW_1 | | 24 | 5VA | | | | |
| 10 | PFW_2 | | 25 | OTW | | | | |
| 11 | PFW_3 | | 26 | Reset | | | | |
| 12 | PFW_4 | | 27 | lso. barrier n/c | | | | |
| 13 | SCL_0 | | 28 | lso. barrier n/c | | | | |
| 14 | SCL_1 | | 29 | Vprog | | | | |
| 15 | SDA_0 | | 30 | n/c | | | | |


Control Interface cable (part # CC848854034)



Communication Signals: J2 Connector

| | Pin out | | | | | | | | |
|-----|-----------|-----|---------------|--|--|--|--|--|--|
| Pin | Signal | Pin | Signal | | | | | | |
| 1 | SCL_0 | 8 | Alert#_1 | | | | | | |
| 2 | SCL_1 | 9 | Isolation n/c | | | | | | |
| 3 | SDA_0 | 10 | Isolation n/c | | | | | | |
| 4 | SDA_1 | 11 | Ishare - B | | | | | | |
| 5 | Alert#_0 | 12 | Ishare - A | | | | | | |
| 6 | 5VA | 13 | 8V_INT - B | | | | | | |
| 7 | Logic_GRD | 14 | 8V_INT - A | | | | | | |

Shelf-to-shelf cable connection (part # CC848848952)



Notes: (For all other signals refer to the rectifier data sheet)

- 1. 8V_INT-x, and Ishare-x are referenced to power output Vout(-). All other signals are referenced to Logic_GRD. A and B are signals referenced to the optional A and B side Vout (-) terminations when split outputs are utilized. A and B side connections are shorted for the standard single output shelf.
- 2. For paralleled shelves the Vout(-) busses must be tied together. Modules could get damaged if this connection is not made.
- 3. Unit_ID: The four rectifiers are internally configured into slots 1 4. Viewing from the front the leftmost slot is #1.
- 4. Rack_ID: Selected using the rotary switch on the back of the shelf. The two combinations provide the following addressing;

| | | Unit_ID | | | | | |
|---------|---|---------|------|------|------|--|--|
| | | 1 | 2 | 3 | 4 | | |
| | 1 | 0000 | 0001 | 0010 | 0011 | | |
| Pack ID | 2 | 0100 | 0101 | 0110 | 0111 | | |
| Rack_ID | 3 | 1000 | 1001 | 1010 | 1011 | | |
| | 4 | 1100 | 1101 | 1110 | 1111 | | |

- 5. Address detection: The Slot_ID pin is shorted to Vout(-) on each rectifier connector in order to deliver output power. This connection provides a second interlock feature.
- 6. **Pull-up resistors:** $10k\Omega$ pull-up resistors can be optionally provided between each signal pin; clock, data, Alert# and +5V. The basic shelf does not include the pull-ups resistors.

Shorting jumper between J1-19 and J1-20 for single output shelves, and a second shorting jumper between J1-21 and J1-22 for split output shelves Part Number: AMP 881545-2 or equivalent J1-19: ENABLE-A, J1-21 - ENABLE-B J1-20, 22: Logic_GRD

J1

Shorting Jumper

Plating 0.000076 0.000030

Gold

Part Number

881545-2

GE Dual I²C shelves for the CP3500 rectifier Model: J2014003


Operation without I²C communications


Jumpers shorting ENABLE-A & B (turn ON) to Logic_GRD are either in a separate bag or inserted into the J1 signal connector.

Remove these jumpers prior to inserting the J1 connector.


Applications desiring ON/OFF control of the output voltage should connect ENABLE-x to Logic_GRD via an external switch. In split shelves ENABLE-A controls the two leftmost rectifiers and ENABLE-B controls the two rightmost rectifiers. Single output shelves use only ENABLE-A.

Package Outline






Rear of shelf



Notes:

1. Brackets are located near the input connectors to secure the input cable harness and thus relief strain from the input connector. These brackets are removable.

Shelf Insertion Keying



Ordering Information

| Part Number | Description | Comcode | Usage |
|---------------------|--|-------------|-------|
| Shelves | | | |
| J2014003L001 | Single output, lug output terminations, no communication pull-ups | 150040608 | |
| J2014003L002 | Split output, lug output terminations, no communication pull-ups | 1600092468A | |
| Blank Slot Fillers | | | |
| Central Office Wh | te | CC848822263 | All |
| Raven Black | | CC848781534 | _ |
| Graphite | | CC848825233 | |
| Extensions and m | ounting brackets | | |
| CP 19 inch mount | ing bracket kit (includes two brackets and mounting hardware) | CC109145760 | |
| 1U high extension | bracket kit for 23" cabinets (includes two brackets and mounting hardware) | CC848844803 | All |
| 2U high extension | bracket kit for 23" cabinets (includes two brackets and mounting hardware) | 848683009 | All |
| Cables sets | | | |
| Individual J1 cont | roller wire set– 6 ft. One end mates into J1, other end not terminated. | CC848854034 | All |
| Cable set from J1 | of the shelf to the CPL Interface Board | CC848848960 | All |
| Inter-shelf cable s | et for interconnecting J2 signals between shelves | CC848848952 | All |
| Output cable set: | 2 AWG DC Lug termination– 10 ft (1 RED and 1 BLACK cable) | 848748987 | All |
| m6 screw with co | nical washer | 901377010 | All |

| Connector | Positions | On shelf | Ribbon cable | Individual wires | Crimping tool |
|-----------|-----------|----------------|---------------------|------------------|---------------|
| J1 | 30 | 5102159-7 | 1658621-7 header | 102387-7 header | |
| | | 102320-1 latch | 1-499252-2 retainer | 6-87756-8 pin⁵ | 91517-1 |
| J2 | 14 | 5102159-2 | 1658621-2 header | 102387-2 header | |
| | | 102320-1 latch | 499252-9 retainer | 6-87756-8 pin | 91517-1 |

⁵ For 22 – 26ga wires

Accessories

| Item | Description | Part number |
|---|---|---------------|
| | 1u_CP3500_shelf_interface board. This debug tool can be used to evaluate the performance of a set of rectifiers inserted into this shelf. The board provides terminations to two independent Isolated Adaptors that can be connected to either of the two i2c lines. Additionally, connection points are provided for interfacing to the four signals of each i2c line for monitoring the signals. The input interface is a standard IEC 320 C20 type socket. Outputs are connected via standard 0.25 fast-ons. | 150045498 |
| | Interface cable between the 30 pin J1 signal connector of the shelf and the 40 pin mating connector of the interface board above. | CC848848960 |
| | Isolated Interface Adapter Kit – interface between a USB port and the I ² C connector on the rectifier interface board. Includes a cable set to the PC and to the 1u_CP3500_interface board above. | 150036482 |
| Software: | The site below downloads the GE Digital Power Insight [™] software tools, including the pro_GUI. When the download is complete, icons for the various utilities will appear on the desktop. Click on pro_GUI.exe icoSuitaxe to start the program after the download is complete. http://www.geindustrial.com/products/embedded- power Graphical User Interface Manual; The GUI download created a | Free download |
| Vour OV Fault 60.0 at sec OUI CTRL spo 1 spo 2 ≥ ≥ 5 > 2 CCI CCI (D) (D) (PAI) (PAI) Spo 2 ≥ ≥ > 5 > 2 CCI CCI (D) (PAI) (PAI) Spo 2 ≥ > 5 2 C CCI (CCI (CCI (CCI CCI (CI A 0 2560 2784 @ | directory Computer Windows7 (C:) DPI Suite In that directory start the DPI_manual.pdf file. | |

The GE Digital Power Insight[™] software tool exercises the various commands and functions available via the PMBus[™] interface of the power supply.

Additionally, two independent GUIs, representing two independent 'system controllers', can be connected to the two independent, multiplexed i²C lines in order to demonstrate the redundant communications features of the platform. The GUI displays and controls which i²C line is in control. The GUIs can also be set up such that control is shifted automatically from one controller to the other, executed at a pre-set time interval.

Another useful feature of the GUI is the automated polling feature that records all time stamped state changes automatically. The power system can be monitored for an extended period of time and if any operational state changed it will be recorded for further analysis

Safety

Product Labeling

Follow all warnings and instructions marked on the product. Some of the safety symbols used with the CP3500 rectifier and this shelf may include the following. They may also be accompanied by instructions:

Mounting and Installation

- This product shall be installed in compliance with mounting requirements for the ultimate application.
- This product must be installed, serviced, and operated only by skilled and qualified personnel who have the necessary knowledge and practical experience with electrical equipment and who understand the hazards that can arise when working on this type of equipment. This product is intended for use in a Restricted Access Location.
- This equipment is to be used in controlled environments (an area where the humidity is maintained at levels that cannot cause condensation on the equipment, the contaminating dust is controlled, and the steady-state ambient temperature is within the range specified).
- This equipment has been evaluated for use in a continuous ambient temperature of:
 - a. 50°C at full load with sharing the load across the two DC output feeds with 2%/°C de-rating from 50°C to 75°C at low range and 2.3%/°C de-rating from 50°C to 75°C at high range.
 - b. 44°C at full load with a single DC output feed setup with 1.6%/°C de-rating from 44°C to 75°C for low range and 1.8%/°C de-rating from 50°C to 75°C for high range.
- The CE mark if provided on the product is applied to show conformance to the requirements outlined in the European Union's Low Voltage Directive {2006/95/EC} and EMC Directive {2004/108/EC}.
- The internal AC-DC rectifier connectors have been evaluated for hot swapping. The four main AC input feed Mate-N-Lok connectors at the rear of the shelf have not been evaluated for hot swapping.
- A separate protective Earthing terminal is provided at the rear of the shelf
- the building installation shall provide a means for connection to protective earth; and
- the equipment is to be connected to that means; and

- a SERVICE PERSON shall check whether or not the socket-outlet from which the equipment is to be powered provides a connection to the building protective earth. If not, the SERVICE PERSON shall arrange for the installation of a PROTECTIVE EARTHING CONDUCTOR from the separate protective Earthing terminal to the protective earth wire in the building.

Output Connections

- All field wiring should comply with the U.S. National Electrical Code (NEC) and/or applicable local codes/standards.
- Routing of the DC output cables should guarantee that cables are not in contact with sources of heat and surfaces that may damage the cable insulation.
- The DC output is not provided with a fuse or circuit breaker suitable for branch circuit protection. Therefore, the power shelf should be mounted in the same rack or cabinet as the equipment being powered. Use interconnecting power cables suitable for the application and sized to carry the rated output current. The interconnecting cables should be capable of carrying the overload current and short circuit current without damage or risk of fire.
- The output for the system is SELV and has available power greater than 240VA.
- Insulation on output field-wired conductors should be rated no less than 90°C. Wiring internal to enclosed equipment cabinets should be rated at 105°C (minimum). The provided DC output cords (red and black wires) are rated for 105°C.
- Before opening the insulating cover to gain access to load and ground connections, ensure all power supplies are disconnected from the AC MAINS.

AC Input Connections

• This shelf is configured with primary internal wiring and Molex connectors, rated for internal factory wiring only. The Molex connector is not UL Recognized for direct connection to the AC mains. The internal wiring is not UL recognized to be directly

accessible by a user. Consideration should be taken on the end product's Listing to comply with NEC requirement for AC mains installations.

- The subject equipment was evaluated for use with a maximum 30A branch circuit per feed. Consideration shall be taken in the endproduct evaluation in the sizing of conductors per Annex NAE s.c. 3.3.4. If used on a branch circuit greater than this, additional testing may be necessary.
- An accessible AC disconnect/protection device to remove AC power from the equipment in the event of an emergency must be provided.
- The equipment is powered by multiple AC inputs (one per rectifier). Disconnect all AC sources of power before servicing.
- These units are to be used with TN-S power systems only.

Safety Symbols and Guidelines

Read and understand all instructions before attempting any installation of this product. When installing, operating, or maintaining the J85480S1 Power System, basic safety precautions should always be followed to reduce the risk of fire, electric shock, and injury to persons. Such precautions include the following:



This symbol identifies the need to refer to the equipment instructions for important information.

This symbol identifies the presence of hazardous AC or DC voltages or hazardous energy levels. In the context of this product

- The DC output cables contain electrical energy levels capable of causing heating and arcing if shorted to metal objects. Make connections with the power disconnected.
- Hazardous AC voltage and DC electrical energy is contained within the enclosure of the power shelf. No user or field serviceable parts inside.



This symbol is used to identify safety earth ground connection points within the equipment.

German Safety Guidelines

Installationsanleitung

- Alle Ausgänge des Gerätes erfüllen die Anforderungen für SELV nach IEC/EN60950-1.
- Die Ausgänge des Gerätes liegen über den Limits für Energiegefahr nach IEC/EN60950-1 (>240 VA). Das Gerät ist zum Einbau in ein Montage-Rack bestimmt. Siehe Einbaubestimmungen in der Montageanleitung, um eine Gefährdung des Benutzers während der Installation zu vermeiden.

ACHTUNG:

Hoher Ableitstrom Vor Anschluss an den Versorgungsstromkreis unbedingt Erdungsverbindung herstellen

- Das Produkt ist zum Gebrauch in einer Umgebungstemperatur von max. 55°C bestimmt.
- Die Gerätestecker des Produktes sind dazu bestimmt, eine sichere Erdung des Gerätes herzustellen.
- Das Produkt ist zum Gebrauch in einer Umgebung mit Verschmutzungsgrad 2 nach IEC/EN60950 bestimmt.
- Die Netzteile des Gerätes können während des Betriebes einzeln ausgetauscht werden (Hot Swapping).

• Das Gerät wurde zusammen mit den Anschlussleitungen (ohne Anschlussstecker) geprüft. Die Installation eines Steckers des jeweiligen Landes, sollte nur durch geschultes Service Personal durchgeführt werden. Als alternative könnte eine Vorinstallation des Steckers bereits bei der Herstellung erfolgt sein.

Data Sheet

GE Compact Power Line Shelves **Dual I²C shelves for the CP3500 rectifier** Model: J2014003

Contact Us

For more information, call us at USA/Canada:

+1 877 546 3243, or +1 972 244 9288

Asia-Pacific: +86.021.54279977*808

Europe, Middle-East and Africa: +49.89.878067-280

http://www.geindustrial.com/products/critical-power

GE Critical Power reserves the right to make changes to the product(s) or information contained herein without notice, and no liability is assumed as a result of their use or application. No rights under any patent accompany the sale of any such product(s) or information.

imagination at work

X-ON Electronics

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Racks & Rack Cabinet Accessories category:

Click to view products by ABB manufacturer:

Other Similar products are found below :

 M00-PLN
 F2424
 8351-832-A-24
 9104
 9105
 PLFF2000
 H-9163-B
 1427C3
 HTS10
 PC-79
 SC10-3A
 SC4-28
 CG3-340S/12
 CP-001BK

 M6123-4007-SS
 TS170
 LP40
 5261304-07
 CG3-160G
 7112C-PLN
 ALUM
 CM10
 8610-3124-S-26
 TS81
 7142
 GP134
 M6125-4007-A-24

 M6127-4007-SS
 PBCOVER
 512
 AEG-4000G
 AEG-3000G
 HD99
 SR2-66A2
 FP10B4HP-1
 FP52-2
 1406-1006-01
 29478
 TS2535
 TS169

 6
 CAC2
 HA19-3U
 BR-19-10-1
 TS180
 CG3-ESD
 SC11-1
 CFS-1.00/2.20
 AX6145WM
 HEC0800PB
 ZC633R
 140PLN