
# R45C IO-Link to Analog Converter




## Instruction Manual



- Compact analog to IO-Link device converter that outputs an analog value, voltage or current, as presented by the IO-Link Master
- The converter also connects to an analog source, voltage or current, and outputs the value to the IO-Link master
- Rugged over-molded design meets IP65, IP67, and IP68
- · Connects directly to a sensor or anywhere in-line for ease of use

## Models



### Overview

#### Analog In

When an analog input value is received by this converter, the numerical representational value is sent to an IO-Link Master via Process Data In (PDI).

### PDI Analog Ranges:

- Voltage = 0 mV to 10,000 mV
- Current = 4,000 μA to 20,000 μA

#### **Analog Out**

This converter also allows for the user to output an analog value by sending the numerical analog value from the IO-Link Master via Process Data Out (PDO).

## PDO Analog Ranges:

- Voltage = 0 mV to 11,000 mV
- Current = 0 μA to 24,000 μA

### PDO Outside Valid Range (POVR)

If the PDO value sent to this converter is outside of the PDO Analog Range value, then the actual analog output value will be set to the one of the three selectable POVR levels after a 2 second delay:

- Low (default): 0 V or 3.5 mA
- High: 10.5 V or 20.5 mA
- · Hold: Level retains previous value indefinitely

Note: If a connected IO-Link sensor is changed back to SIO mode, then the previous value will be held.



Original Document 223053 Rev. A

### Status Indicators

The R45C In-Out Analog to IO-Link Device Converter has four amber LED indicators on both sides for IO-Link and analog communications to allow for installation needs and still provide adequate indication visibility. There is also a green LED indicator on both sides of the converter, which signals the device's power status.

Analog In LED
(on either side)\*

Power LED
(on either side)\*

IO-Link LED
(on either side)\*

Rotate 180°

Analog Out LED
(on either side)\*

Figure 1. R45C status indicators - front and back

\* Indicator LEDs are visible through translucent housing

-Link Amber LED		
Indication	Status	
Off	IO-Link communications are not present	
Flashing Amber (900 ms On, 100 ms Off)	IO-Link communications are active	

Analog In Amber LED			
Indication	Status		
Off	Analog current value is less than setpoint SP1 OR analog value is greater than setpoint SP2		
Solid Amber	Analog current value is between setpoint SP1 AND setpoint SP2		
Default Current Values:	Default Voltage Values:		
• SP1 = 0.004 A	• SP1 = 0 V		
• SP2 = 0.02 A	• SP2 = 10 V		


Analog Out Amber LED		
Indication	Status	
Off	Turns off if written PDO analog value is outside the allowable output range	
Solid Amber	Turns on if written PDO analog value is inside the allowable output range	
Allowable Current Range: 0 mA to 24 mA		
Allowable Voltage Range: 0 V to 11 V		

## Installation Instructions

## Mechanical Installation

Install the R45C to allow access for functional checks, maintenance, and service or replacement. Do not install the R45C in such a way to allow for intentional defeat.

All mounting hardware is supplied by the user. Fasteners must be of sufficient strength to guard against breakage. Use of permanent fasteners or locking hardware is recommended to prevent the loosening or displacement of the device. The mounting hole (4.5 mm) in the R45C accepts M4 (#8) hardware. See the figure below to help in determining the minimum screw length.



Screw Length (with screw head fitting in counterbore) = 12.9 mm + "X" mm + 3 mm



**CAUTION:** Do not overtighten the R45C's mounting screw during installation. Overtightening can affect the performance of the R45C.

## Wiring Diagrams

Male	Female	Pin	Wire Color
	1 2	1	Brown
		2	White
2		3	Blue
3	4 3	4	Black

Male (IO-Link Master)	Signal Description	Female (Analog In-Out)
Pin 1	18 V DC to 30 V DC	Pin 1
Pin 2	Banner-specific	Pin 2
Pin 3	Ground	Pin 3
Pin 4	IO-Link	Pin 4

l	Female (Analog In-Out)	Signal Description
1	Pin 1	18 V DC to 30 V DC
l	Pin 2	Analog In
l	Pin 3	Ground
1	Pin 4	Analog Out

## Configuration

The measured current value is available via Process Data as the measure value  $\mu$ A, and the voltage is available in mV. For more information, see Banner P/N 223174 R45C Analog Converter (Voltage and Current) IO-Link Data Reference Guide and Banner P/N 223171 R45C-K-Analog IO-LINK IODD Files.

## IO-Link®

IO-Link® is a point-to-point communication link between a master device and a sensor and/or light. It can be used to automatically parameterize sensors or lights and to transmit process data. For the latest IO-Link protocol and specifications, please visit <a href="https://www.io-link.com">www.io-link.com</a>.

For the latest IODD files, please refer to the Banner Engineering Corp website at: www.bannerengineering.com.

## Specifications

Supply Voltage

18 V DC to 30 V DC at 50 mA maximum

Power Pass-Through Current

4 A maximum

Supply Protection Circuitry

Protected against reverse polarity and transient voltages

**Leakage Current Immunity** 

400 μΑ

Resolution

14 bits

Accuracy

0.5%

Indicators Green: Power

Amber: IO-Link communications Amber: Analog input value present Amber: Analog output value in range

Connections

Integral male/female 4-pin M12 quick disconnect

Construction

Coupling Material: Nickel-plated brass Connector Body: PVC translucent black

Vibration and Mechanical Shock

Meets IEC 60068-2-6 requirements (Vibration: 10 Hz to 55 Hz, 0.5 mm amplitude, 5 minutes sweep, 30 minutes dwell)

Meets IEC 60068-2-27 requirements (Shock: 15G 11 ms duration, half sine

#### Certifications


 $\epsilon$ 

**Banner Engineering Europe** Park Lane, Culliganlaan 2F bus 3, 1831 Diegem, BELGIUM



Turck Banner LTD Blenheim House, Blenheim Court, Wickford, Essex SS11 8YT, Great Britain





#### **Environmental Rating**

IP65, IP67, IP68 NEMA/UL Type 1

### **Operating Conditions**

Temperature: -40 °C to +70 °C (-40 °F to +158 °F) 90% at +70 °C maximum relative humidity (non-condensing) Storage Temperature: -40 °C to +80 °C (-40 °F to +176 °F)

#### **Required Overcurrent Protection**



WARNING: Electrical connections must be made by qualified personnel in accordance with local and national electrical codes and regulations


Overcurrent protection is required to be provided by end product application per the supplied table.


Overcurrent protection may be provided with external fusing or via Current Limiting, Class 2 Power Supply.
Supply wiring leads < 24 AWG shall not be spliced.
For additional product support, go to www.bannerengineering.com.


Supply Wiring (AWG)	Required Overcurrent Protection (Amps)	
20	5.0	
22	3.0	
24	2.0	
26	1.0	
28	0.8	
30	0.5	

## **Dimensions**

All measurements are listed in millimeters [inches], unless noted otherwise.







## Accessories

#### Cordsets

4-Pin Threaded M12 Cordsets—Double Ended				
Model	Length	Style	Dimensions	Pinout
MQDEC-401SS	0.31 m (1 ft)			Female
MQDEC-403SS	0.91 m (2.99 ft)			<b>○</b> 2
MQDEC-406SS	1.83 m (6 ft)			1 (600)
MQDEC-412SS	3.66 m (12 ft)			4
MQDEC-420SS	6.10 m (20 ft)		Male Straight/ Female Straight  M12 x1  0 14.5 [0.57"]  44 Typ.  [1.73"]  M12 x 1  0 14.5 [0.57"]	Male
MQDEC-430SS	9.14 m (30.2 ft)	Male Straight/		Wate
MQDEC-450SS	15.2 m (49.9 ft)	Female Straight		2 4
				1 = Brown 2 = White 3 = Blue 4 = Black

## Banner Engineering Corp Limited Warranty

Banner Engineering Corp. warrants its products to be free from defects in material and workmanship for one year following the date of shipment. Banner Engineering Corp. will repair or replace, free of charge, any product of its manufacture which, at the time it is returned to the factory, is found to have been defective during the warranty period. This warranty does not cover damage or liability for misuse, abuse, or the improper application or installation of the Banner product.

THIS LIMITED WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES WHETHER EXPRESS OR IMPLIED (INCLUDING, WITHOUT LIMITATION, ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE). AND WHETHER ARISING UNDER COURSE OF PERFORMANCE. COURSE OF DEALING OR TRADE USAGE.

This Warranty is exclusive and limited to repair or, at the discretion of Banner Engineering Corp., replacement. IN NO EVENT SHALL BANNER ENGINEERING CORP. BE LIABLE TO BUYER OR ANY OTHER PERSON OR ENTITY FOR ANY EXTRA COSTS, EXPENSES, LOSSES, LOSS OF PROFITS, OR ANY INCIDENTAL, CONSEQUENTIAL OR SPECIAL DAMAGES RESULTING FROM ANY PRODUCT DEFECT OR FROM THE USE OR INABILITY TO USE THE PRODUCT, WHETHER ARISING IN CONTRACT OR WARRANTY, STATUTE, TORT, STRICT LIABILITY, NEGLIGENCE, OR OTHERWISE.

Banner Engineering Corp. reserves the right to change, modify or improve the design of the product without assuming any obligations or liabilities relating to any product previously manufactured by Banner Engineering Corp. Any misuse, abuse, or improper application or installation of this product or use of the product for personal protection applications when the product is identified as not intended for such purposes will void the product warranty. Any modifications to this product without prior express approval by Banner Engineering Corp will void the product warranties. All specifications published in this document are subject to change; Banner reserves the right to modify product specifications or update documentation at any time. Specifications and product information in English supersede that which is provided in any other language. For the most recent version of any documentation, refer to: www.bannerengineering.com.

For patent information, see www.bannerengineering.com/patents.

### FCC Part 15

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: 1) This device may not cause harmful interference; and 2) This device must accept any interference received, including interference that may cause undesired operation.

## Industry Canada

This device complies with CAN ICES-3 (B)/NMB-3(B). Operation is subject to the following two conditions: 1) This device may not cause harmful interference; and 2) This device must accept any interference received, including interference that may cause undesired operation.

Cet appareil est conforme à la norme NMB-3(B). Le fonctionnement est soumis aux deux conditions suivantes : (1) ce dispositif ne peut pas occasionner d'interférences, et (2) il doit tolérer toute interférence, y compris celles susceptibles de provoquer un fonctionnement non souhaité du dispositif.



# **X-ON Electronics**

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Interface Modules category:

Click to view products by Banner manufacturer:

Other Similar products are found below:

FAB118 60003-002 FC6A-PC3 60016-023 HPCI-14S12U cBP-3208 PCE-DP10-00A1E 60016-024 60016-022 60016-005 60016-002 60006-004 K6CMISZBI52 60011-093 ADAM-4541-C ADAM-4510S-F ADC-30AB BBA USB-CARD-READER USB-RS485 USB-SATA 112095-5118 1020882 1021056 1021058 1021080 73-544-002 UC-313 UC-357 485LDRC9 4850PDRI U442-DOCK1 UH104 US-257 VESP211-232 422LP9R 422PP9R 422PP9TB 4850PDRHS US-279 HW-FMC-XM105-G HP-USB-14 UEXTX5 2316379 2316382 B126-1A1 2465 301-1001-11 301-1001-31 301-1002-98 U444-06N-DP-C