Energy Management
Energy Analyzer
Type EM26 96

CARLO GAVAZZI

- Class 1 (kWh) according to EN62053-21
- Class B (kWh) according to EN50470-3
- Class 2 (kvarh) according to EN62053-23
- Accuracy ±0.5% RDG (current/voltage)
- Dual colour backlight: no backlight, blue or white (selectable)
- Energy analyzer
- Instantaneous variables readout: 4 DGT
- Energies/gas/water readout: 8 DGT
- System variables: VLL, VLN, Admd, VA, VAdmd, VAdmd max, W, Wdmd, Wdmd max, var, PF, Hz, Phase-sequence.
- Single phase variables: VLL, VLN, A, VA, W, var, PF
- Energy measurements: total and partial kWh and kvarh or based on 4 different tariffs; single phase measurements
- Gas, cold water, hot water, kWh remote heating measurements
- Hour counter (6+2 DGT)
- Harmonic analysis (FFT) up to 15th harmonic (current/voltage)
- TRMS measurements of distorted sine waves (voltages/currents)
- Universal power supply: 90 to 260AC/VDC
- 3 digital inputs for tariff selection, DMD synch or gas/water (hot-cold) and remote heating metering (on request)
- 3 digital outputs for pulses or for alarms or as a mix of them (on request)
- Front dimensions: 96x96mm
- Protection degree (front): IP50
- RS485 serial output (on request) (MODBUS-RTU), iFIX SCADA compatibility

- M-bus communication by means of VMU-B adapter
- Application adaptable display and programming procedure (Easyprog function)
- Easy connections management
- Certified according to MID Directive (option PF only): see "how to order" below
- Other versions available (not certified, option XX): see "how to order" on the next page

Product Description

Three-phase energy analyzer with built-in configuration joystick and LCD data displaying; particularly indicated for active and reactive energy metering and for cost allocation. Housing for panel mounting with IP50 (front) protection degree. External Current and potential transformers connection. Moreover the meter can be provided with digital outputs that can be used: for pulses proportional to the active and reactive energy being measured or for alarm outputs, or for remote control. RS485 communication port and 3 digital inputs are available as an option.

MID Certified according to MID Directive, Module B and Module D of Annex II, for legal metrology relevant to active electrical energy meters (see Annex V, MI003, of MID). Can be used for fiscal (legal) metrology. Only the total positive energy meter is certified according to MID.

How to order EM26 96 AV5 3 H O3 S1 PF A

- Model
- Range code
- System
- Power supply
- Inputs/Outputs
- Communications
- Option
- Measurement

Type Selection

Range codes	System	Communication	Options
AV5: 230 V_{LN}/400V_{LL} 1/5(10)A V_{LN}: 160 V to 480 V_{LN} V_{LL}: 277 V to 830 V_{LL}	**3:** 3-phase, 4-wire;	**XX:** none **S1:** RS485 port	**PF:** Certified according to MID Directive. Can be used for fiscal (legal) metrology.
AV6: 120 V_{LN}/208V_{LL} 1/5(10)A V_{LN}: 40 V to 144 V_{LN} V_{LL}: 70 V to 250 V_{LL}	**Power supply** **H:** 90 to 260VAC/DC (48 to 62Hz)	**Input/Output** **O1:** single open collector type (pulse or alarm) **O3:** 3 open collector type (mixed combination of pulse, alarm and/or remote output) **R2:** dual relay type (functions as per "O3") **I3:** 3 digital inputs for tariff selection or Gas/water/energy/remote heating metering	

Range — System — Power supply — Input/Output — Communication — Option — Measurement

AV5 / AV6 — 3 — H — O1 / O3 / R2 — XX / S1 — PF — A / B
I3 — S1

NOTE: please check the availability of the needed code on the verification path diagram on left before order.

CARLO GAVAZZI

STANDARD

Not certified according to MID directive. Cannot be used for fiscal (legal) metrology.

How to order   EM26 96 AV5 3 H O3 S1 XX

Model ───────────
Range code ──────────
System ──────────
Power supply ─────────
Input/Output ──────────
Communication ─────────
Options ─────────

Type Selection

Range codes

AV5: 230 V_{LN}/400V_{LL}
1/5(10)A
V_{LN} : 160 V to 480 V_{LN}
V_{LL} : 277 V to 830 V_{LL}
AV6: 120 V_{LN}/208V_{LL}
1/5(10)A
V_{LN} : 40 V to 144 V_{LN}
V_{LL} : 70 V to 250 V_{LL}

System

3: balanced and unbalanced load:
3-phase, 4-wire;
3-phase, 3-wire;
2-phase, 3-wire;
1-phase, 2-wire

Power supply

H: 90 to 260VAC/DC (48 to 62Hz)

Communication

XX: none
S1: RS485 port

Input/Output

O1: single open collector type (pulse or alarm)
O3: 3 open collector type (mixed combination of pulse, alarm and/or remote output)
R2: dual relay type (functions as per "O3")
I3: 3 digital inputs for tariff selection or Gas/water/energy/remote heating metering

Options

XX: none

NOTE: please check the availability of the needed code on the verification path tables on left before order.

Specifications are subject to change without notice   EM2696 DS ENG 130117

Input specifications

Rated inputs		Overload status	EEEE indication when the value being measured is exceeding the "Continuous inputs overload" (maximum measurement capacity)
Current type	System type: 3 Galvanic insulation by means of built-in CT's		
Current range (by CT)	AV5 and AV6: 1/5(10) A		
Voltage by direct connection or VT/PT	AV5: 230 V_{LN}/400V_{LL}; AV6: 120 V_{LN}/208V_{LL}	Max. and Min. indication	Max. instantaneous variables: 9999; energies: 99 999 999. Min. instantaneous variables: 0; energies 0.00
Accuracy (Display + RS485) (@25°C ±5°C, R.H. ≤60%, 50±5Hz/60±5Hz)	Ib: see below, Un: see below	**LEDs**	Red LED (Energy consumption), according to EN50470-3, EN62052-11
AV5 model	In: 5A, Imax: 10A; Un: 160 to 480VLN (277 to 830VLL)		0.001 kWh/kvarh by pulse if CT ratio by VT ratio is ≤7;
AV6 model	In: 5A, Imax: 10A; Un: 40 to 144VLN (70 to 250VLL)		0.01 kWh/kvarh by pulse if CT ratio by VT ratio is > 7.1 ≤ 70.0;
Current			0.1 kWh/kvarh pulse if CT ratio by VT ratio is > 70.1 ≤ 700.0;
AV5, AV6 models	From 0.002In to 0.2In: ±(0.5% RDG +3DGT) From 0.2In to Imax: ±(0.5% RDG +1DGT).		1 kWh/kvarh by pulse if CT ratio by VT ratio is > 700.1; 1000 imp./kWh/kvarh. Max frequency: 16Hz
Phase-neutral voltage	In the range Un: ±(0,5% RDG +1DGT)		
Phase-phase voltage	In the range Un: ±(1% RDG +1DGT)	**Measurements**	See "List of the variables that can be connected to:"
Frequency	±0.1Hz (50±5Hz/60±5Hz)	Method	TRMS measurements of distorted wave forms.
Active and Apparent power	±(1%RDG +2DGT)		
Power Factor	±[0.001+1%(1.000 - "PF RDG")]	Coupling type	By means of external CT's
Reactive power	±(2%RDG +2DGT)	**Crest factor**	≤3 (15A max. peak)
Active Energy	Class 1 according to EN62053-21; class B according to EN50470-3.	**Current Overloads**	
		Continuous	10A, @ 50Hz
Reactive Energy	Class 2 according to EN62053-23	For 500ms	200A, @ 50Hz
AV5, AV6 models	In: 5A, Imax: 10A; 0.1 In: 0.5A. Start up current: 10mA	**Voltage Overloads**	
		Continuous	1.2 Un
		For 500ms	2 Un
Harmonic distortion	THD up to 15th harmonic ±3% reading	**Input impedance**	
		208VL-L (AV6)	>1MΩ
Energy additional errors		400VL-L (AV5)	>1MΩ
Influence quantities	According to EN62053-21, EN62053-23	1/5(10) A (AV5-AV6)	< 0.3VA
Temperature drift	≤200ppm/°C	**Frequency**	50±5Hz/60±5Hz
Sampling rate	1600 samples/s @ 50Hz 1900 samples/s @ 60Hz	**Joystick**	For variable selection: programming of the instrument working parameters and Wdmd max reset
Display refresh time	750 msec		
Display	3 lines (1 x 8 DGT; 2 x 4 DGT)		
Type	LCD, h 9.5mm, dual colour backlight (selectable)		
Instantaneous variables read-out	4 DGT		
Energies	Exported: Total 6+1DGT or 7DGT (with "-" sign). Imported: 6+2, 7+1 or 8DGT		

Output specifications

Digital outputs

Pulse type

Number of outputs	Up to 3, independent. Programmable from 0.001 to 10.00 kWh/kvarh per pulse.
Type	Outputs connectable to the energy meters (Wh/varh)
Pulse duration	T_{ON} selectable (30 ms or 100 ms) according to EN62053-31 T_{OFF}: ≥120ms, according to EN62052-31

Alarm type

Number of outputs	Up to 3, independent
Alarm modes	Up alarm, down alarm (see the table "List of the variables that can be connected to")
Set-point adjustment	From 0 to 100% of the display scale
Hysteresis	From 0 to full scale
On-time delay	0 to 255s
Output status	Selectable: normally de-energized or normally energized
Min. response time	≤ 700ms, filters excluded. Set-point on-time delay: "0 s"
Remote control	The digital ouputs status can be managed by means of serial communication RS485, if programmed as remote.
Note	The 3 digital outputs can also work as a triple pulse output, triple alarm output, or in any other combination.

Static output

Physical outputs	Max. 3
Purpose	For pulse output, alarm output or remote control.
Signal	V_{ON} 1.2 VDC/ max. 100 mA V_{OFF} 30 VDC max.
Insulation	By means of optocouplers, 4000 VRMS output to measuring inputs, 4000 VRMS output to power supply input.

Relay output

Physical outputs	Max. 2
Purpose	For alarm output, pulse output or remote control.
Type	Relay, SPST type AC 1-5A @ 250VAC DC 12-5A @ 24VDC AC 15-1.5A @ 250VAC DC 13-1.5A @ 24VDC
Insulation	4000 VRMS outputs to measuring input. 4000 VRMS outputs to power supply input.

RS485

Type	Multidrop, bidirectional (static and dynamic variables)
Connections	2-wire Max. distance 1000m (without amplifier) Termination directly on the instrument
Addresses	247, selectable by means of the front joystick
Protocol	MODBUS/JBUS (RTU)
Data (bidirectional)	
Dynamic (reading only)	System and phase variables: see table "List of variables..."
Static (reading and writing)	All the configuration parameters.
Data format	1 start bit, 8 data bit, no parity,1 stop bit
Baud-rate	4800, 9600 bits/s
Driver input capability	1/5 unit load Maximum 160 transceivers on the same bus, which can be expanded with signal amplifiers.
Insulation	By means of optocouplers, 4000 VRMS output to measuring input. 4000 VRMS output to power supply input

Digital input specifications

Number of inputs	3	Working modes	Selectable: • total and partial energy meters (kWh and kvarh) managed by time periods (t1-t2-t3-t4), W dmd synchronisation (the synchronisation is made every time the tariff changes) and GAS (m^3) or WATER (hot-cold m^3)
Input frequency	20Hz max, duty cycle 50%		
Prescaler adjustment	From 0.001 to 999.9 m^3 or kWh/pulse		
Contact measuring voltage	5VDC +/- 5%		
Contact measuring current	10mA max		
Input impedance	680Ω		
Contact resistance	≤100Ω, closed contact ≥500kΩ, open contact		

Digital input specifications (cont.)

	or remote heating (kWh) meters or external kWh meter; • total and partial energy meters (kWh and kvarh) managed by time periods (t1-t2), W dmd synchronisation (the synchronisation is made independently of the tariff selection) and GAS (m³) or WATER (hot-cold m³) or remote heating (kWh) meters or external kWh meter;	
Note		• total energy (kWh, kvarh) and GAS, WATER (hot-cold m³) and remote heating meters or external kWh meter, 3 choices only. The energy metering is only made by means of the analogue inputs.
Insulation		By means of optocouplers, 4000 VRMS digital inputs to measuring inputs. 4000 VRMS digital inputs to power supply input.

Software functions

Password	Numeric code of max. 4 digits; 2 protection levels of the programming data:		current) being measured cannot exceed 66 MW for AV5_X models and 62 MW for AV6_X models. If the currents and/or voltages being measured exceed their maximum limits, the display shows the error message "EEEE". For EN50470-3 compliant applications the maximum power being measured is 25 MW.
1st level	Password "0", no protection;		
2nd level	Password from 1 to 9999, all data are protected		
System selection			
System 3-Pn unbalanced load	3-phase (4-wire); 3-phase (3-wire).		
System 3-P 1 balanced load	3-phase (3-wire) one current and 3-phase to phase voltage measurements. 3-phase (4-wire) one current and one-phase (L1) to neutral voltage measurement.	**Filter**	
		Operating range	0 to 100% of the input display scale
System 2-P	2-phase (3-wire).	Filtering coefficient	1 to 32
System 1-P	1-phase (2-wire).	Filter action	Measurements, serial output (fundamental variables: V, A, W and their derived ones).
Transformer ratio			
VT (PT)	1.0 to 999.9 / 1000 to 6000.		
CT	1.0 to 999.9 / 1000 to 9999 / 10.00k to 60.00k. Transformer ratio: VT (PT): 1.0 to 999.9 / 1000 to 6000, CT: 1.0 to 999.9 / 1000 to 9999 / 10.00k to 60.00k (only AV5_X and AV6_X). VT (PT) = 1.0 (fixed) for AV5_PF models. The maximum VT by CT ratio is 3150 for AV5_PF models, 4629 for AV5_X models.The maximum VT by CT ratio is 5448 for AV6_PF models, 14529 for AV6_X models. Note 1: for MID complaint applications the maximum power being measured is 25 MW for AV5_PF models. Note 2: for non-MID complaint applications the maximum power (calculated as maximum input voltage and	**Displaying**	Up to 3 variables per page See « Display pages » 8 different set of variables available (see « Display pages ») according to the application being selected
		Alarm highlight	In case of alarm and if the relevant function is enabled, the display changes the colour alternatively from white backlight to blue backlight and vice versa.
		Reset	By means of the front joystick: - dmd and max. dmd; - total energies and gas/water: kWh, kvarh; - partial energies and tariffs: kWh, kvarh
		Harmonic analysis	Up to the 15th harmonics on single current and voltage

CARLO GAVAZZI

Software functions (cont.)

Easy connection function	For all the display selections, both energy and power measurements are independent of the current direction. The displayed energy is always "imported" with the only exception of "F" and "H" types (see "display pages" table).	For these latter selections the energies can be either "imported" or "exported" depending on the current direction.

General specifications

Operating temperature	-25°C to +55°C (-13°F to 131°F) (R.H. from 0 to 90% non-condensing @ 40°C) according to EN62053-21 and EN62053-23	Immunity to conducted disturbances	10V/m from 150KHz to 80MHz
Storage temperature	-30°C to +70°C (-22°F to 158°F) (R.H. < 90% non-condensing @ 40°C) according to EN62053-21 and EN62053-23	Surge	On current and voltage measuring inputs circuit: 4kV;
Installation category	Cat. III (IEC60664, EN60664)	Radio frequency suppression	According to CISPR 22
Insulation (for 1 minute)	4000 VRMS between measuring inputs and power supply. 4000 VRMS between power supply and RS485 digital outputs	**Standard compliance** Safety	IEC60664, IEC61010-1 EN60664, EN61010-1 EN62052-11
		Metrology	EN62053-21, EN50470-3, EN62053-23.
Dielectric strength	4000 VRMS for 1 minute	Pulse output	DIN43864, IEC62053-31
Noise rejection CMRR	100 dB, 48 to 62 Hz	Approvals	CE, cULus listed, MID (PF option only)
EMC Electrostatic discharges Immunity to irradiated	According to EN62052-11 15kV air discharge; Test with current: 10V/m from 80 to 2000MHz;	**Connections** Cable cross-section area	Screw-type Max. 1.5 mm^2
Electromagnetic fields	Test without any current: 30V/m from 80 to 2000MHz;	**Housing** Dimensions (WxHxD) Material	96 x 96 x 63 mm ABS, self-extinguishing: UL 94 V-0
Burst	On current and voltage measuring inputs circuit: 4kV	Mounting	Panel mounting
		Protection degree Front Screw terminals	IP50 IP20
		Weight	Approx. 400 g (packing included)

Power supply specifications

Auxiliary power supply	H: 90 to 260VAC/DC (48 to 62Hz)	**Power consumption**	AC: 6VA DC: 3.5 W

    EM2696 DS ENG 130117

CARLO GAVAZZI

Accuracy (according to EN50470-3 and EN62053-23)

kWh, accuracy (RDG) depending on the current

Percentage error limits for class index B

+1.5%
+1%
0%
-1%
-1,5%

PF=1   0.05A (I_min) — 0.25A (I_tr) — 5A (I_n) — 10A (I_max)

PF=L0.5   0.25A (I_tr) — 5A (I_n) — 10A (I_max)
or C0.8

━━━ Accuracy limits (Active energy)
Start-up current: 10mA

kvarh, accuracy (RDG) depending on the current

+2,5%
+2%
0%
-2%
-2,5%

sinj=1   0.1A — 0.25A ——— 5A (I_n) ——— 10A (I_max)

sinj=0.5   0.25A — 0.5A ——— 5A (I_n) ——— 10A (I_max)

━━━ Accuracy limits (Reactive energy)
Start-up current: 10mA

MID compliance (PF option only)

Accuracy	0.9 Un ≤ U ≤ 1.1 Un; 0.98 fn ≤ f ≤ 1.02 fn; fn: 50Hz; cosj: 0.5 inductive to 0.8 capacitive.
AV5-AV6 models	Class B. I st: 0.01A; I min: 0.05A; I tr: 0.25A; I n: 5A; I max: 10A
Operating temperature	-25°C to +55°C (-13°F to 131°F) (R.H. from 0 to 90% non-condensing @ 40°C)

EMC compliance	E2
Mechanical compliance	M2
Protection degree	in order to achieve the protection against dust and water required by the norms harmonized to MID, the meter must be used only installed in IP51 (or better) cabinets.

Used calculation formulas

Phase variables

Instantaneous effective voltage

$$V_{1N} = \sqrt{\frac{1}{n} \cdot \sum_{i=1}^{n} (V_{1N})_i^2}$$

Instantaneous active power

$$W_1 = \frac{1}{n} \cdot \sum_{i=1}^{n} (V_{1N})_i \cdot (A_1)_i$$

Instantaneous power factor

$$PF = \frac{W_1}{VA_1}$$

Instantaneous effective current

$$A_1 = \sqrt{\frac{1}{n} \cdot \sum_{i=1}^{n} (A_1)_i^2}$$

Instantaneous apparent power

$$VA_1 = V_{1N} \cdot A_1$$

Instantaneous reactive power

$$var_1 = \sqrt{(VA_1)^2 - (W_1)^2}$$

Where: **n**= sample number

System variables

Equivalent three-phase voltage

$$V_\Sigma = \frac{V_1 + V_2 + V_3}{3}$$

Three-phase reactive power

$$var_\Sigma = (var_1 + var_2 + var_3)$$

Three-phase active power

$$W_\Sigma = W_1 + W_2 + W_3$$

Three-phase apparent power

$$VA_\Sigma = \sqrt{W_\Sigma^2 + var_\Sigma^2}$$

Three-phase power factor

$$\cos\varphi_\Sigma = \frac{W_\Sigma}{VA_\Sigma} \qquad \text{(TPF)}$$

Energy metering

$$kWh_1 = \int_{t1}^{t2} P_1(t)dt \cong \Delta t \sum_{j=n1}^{n2} P_1(j)$$

$$k\,var\,h_1 = \int_{t1}^{t2} Q_1(t)dt \cong \Delta t \sum_{j=n1}^{n2} Q_1(j)$$

Where:
P= active power;
Q= reactive power;
t_1, t_2 =starting and ending time points of consumption recording;
nj= time unit;
Δ**t**= time interval between two successive power consumptions;
n_1, n_2 = starting and ending discrete time points of consumption recording

CARLO GAVAZZI

List of the variables that can be connected to:

- RS485 communication port
- Alarm outputs ("max" variable", "energies" and "hour counter" excluded)
- Pulse outputs (only positive "energies")

No	Variable	1-phase system	2-phase system	3-ph. 4-wire balanced sys.	3-ph. 4-wire unbal. sys.	3 ph. 3-wire bal. sys.	3 ph. 3-wire unbal. sys.	Notes
1	V L-N sys		x	x	x	x	x	sys=system
2	V L1	x	x	x	x	x	x	
3	V L2	o	x	x	x	x	x	
4	V L3	o	o	x	x	x	x	
5	V L-L sys	o	x	x	x	x	x	sys=system
6	V L1-2	o	x	x	x	x	x	
7	V L2-3	o	o	x	x	x	x	
8	V L3-1	o	o	x	x	x	x	
9	A dmd max		x	x	x	x	x	Highest "dmd" current among the phases (1)
10	A L1	x	x	x	x	x	x	
11	A L2	o	x	x	x	x	x	
12	A L3	o	o	x	x	x	x	
13	VA sys	x	x	x	x	x	x	sys=system
14	VA sys dmd	x	x	x	x	x	x	sys=system (1)
15	VA L1	x	x	x	x	x	x	
16	VA L2	o	x	x	x	x	x	
17	VA L3	o	o	x	x	x	x	
18	var sys	x	x	x	x	x	x	sys=system
19	var L1	x	x	x	x	x	x	
20	var L2	o	x	x	x	x	x	
21	var L3	o	o	x	x	x	x	
22	W sys	x	x	x	x	x	x	sys=system
23	W sys dmd	x	x	x	x	x	x	sys=system (1)
24	W L1	x	x	x	x	x	x	
25	W L2	o	x	x	x	x	x	
26	W L3	o	o	x	x	x	x	
27	PF sys	x	x	x	x	x	x	
28	PF L1	x	x	x	x	x	x	
29	PF L2	o	x	x	x	x	x	
30	PF L3	o	o	x	x	x	x	
31	Hz	x	x	x	x	x	x	
32	Phase seq.	o	o	x	x	x	x	
33	Hours	x	x	x	x	x	x	
34	kWh (+)	x	x	x	x	x	x	Total or by user
35	kvarh (+)	x	x	x	x	x	x	Total or by user
36	kWh (+)	x	x	x	x	x	x	Partial or by tariff
37	kvarh (+)	x	x	x	x	x	x	Partial or by tariff
38	kWh (-)	x	x	x	x	x	x	Total
39	kvarh (-)	x	x	x	x	x	x	Total
40	m^3 Gas	x	x	x	x	x	x	Total
41	m^3 Cold H_2O	x	x	x	x	x	x	Total
42	m^3 Hot H_2O	x	x	x	x	x	x	Total
43	kWh H_2O	x	x	x	x	x	x	Total
44	kWh out	x	x	x	x	x	x	Total
45	A L1 THD	x	x	x	x	x	x	
46	A L2 THD	o	x	x	x	x	x	
47	A L3 THD	o	o	x	x	x	x	
48	V L1 THD	x	x	x	x	x	x	
49	V L2 THD	o	x	x	x	x	x	
50	V L3 THD	o	o	x	x	x	x	
51	V L1-2 THD	x	x	x	x	x	x	
52	V L2-3 THD	o	x	x	x	x	x	
53	V L3-1 THD	o	o	x	x	x	x	

(x) = available; (o) = not available (zero indication on the display); (1) Max. value with data storage.

CARLO GAVAZZI

Display pages

Sel. pos.	No	1st variable (1st line)	2nd variable (2nd line)	3rd variable (3rd line)	Note	Applications							
						A	B	C	D	E	F	G	H
	1	Total kWh (+)	W sys dmd	W sys dmd max		x	x	x		x	x	x	x
	2	kWh (+)	A dmd max	"PArt"	"PArt" = Partial kWh (+)						x	x	x
	3	Total kvarh (+)	VA sys dmd	VA sys dmd max			x	x			x	x	x
	4	kvarh (+)	VA sys	"PArt"	"PArt" = Partial kvarh (+)						x	x	x
	5	Totalizer 1 (2)	W sys	(text) (3)	(1)			x			x	x	x
	6	Totalizer 2 (2)	W sys	(text) (3)	(1)			x			x	x	x
	7	Totalizer 3 (2)	W sys	(text) (3)	(1)			x			x	x	x
	8	kWh (+)	t1 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	9	kWh (+)	t2 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	10	kWh (+)	t3 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	11	kWh (+)	t4 (text) (4)	W sys dmd	(1) digital input enebled			x			x	x	x
	12	kvarh (+)	t1 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	13	kvarh (+)	t2 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	14	kvarh (+)	t3 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	15	kvarh (+)	t4 (text) (4)	W sys dmd	(1) digital input enabled			x			x	x	x
	16	kWh (+) X	W X	User X	(1) specific function enabled				x				
	17	kWh (+) Y	W Y	User Y	(1) specific function enabled				x				
	18	kWh (+) Z	W Z	User Z	(1) specific function enabled				x				
	19	Total kvarh (-)	VA sys dmd	VA sys dmd max							x		x
	20	Total kWh (-)	W sys dmd	W sys dmd max						x	x		x
	21	Hours	W sys	PF sys						x	x	x	x
	22	Hours	var sys	PF sys						x	x	x	x
	23	W L1	W L2	W L3						x		x	x
	24	VA L1	VA L2	VA L3								x	x
	25	var L1	var L2	var L3								x	x
	26	PF L1	PF L2	PF L3								x	x
	27	V L1	V L2	V L3				x		x	x	x	x
	28	V L1-2	V L2-3	V L3-1								x	x
	29	A L1	A L2	A L3						x		x	x
	30	Phase seq.	V LN sys	Hz		x	x	x		x	x	x	x
	31	Phase seq.	V LL sys	Hz							x	x	x
	32	ASY	V LL sys	%							x	x	x
	33	ASY	V LN sys	%							x	x	x
	34	THD A1	THD A2	THD A3								x	x
	35	THD V1	THD V2	THD V3								x	x
	36	THD V12	THD V23	THD V 31								x	x
	37	Lot number	Year	DMD time		x	x	x	x	x	x	x	x
	38	CT ratio	Value of CT	System		x	x	x	x	x	x	x	x
	39	VT/PT ratio	Value of VT	Connection		x	x	x	x	x	x	x	x
	40 a	Alarm 1 status	Set-point value	Variable type				x		x		x	x
	41 a	Alarm 2 status	Set-point value	Variable type				x		x		x	x
	42 a	Alarm 3 status	Set-point value	Variable type				x		x		x	x
	40 b	Pulse 1 status	Output pulse			x	x	x	x	x	x	x	x
	41 b	Pulse 2 status	Output pulse			x	x	x	x	x	x	x	x
	42 b	Pulse 3 status	Output pulse			x	x	x	x	x	x	x	x
	43	Serial port	Address	RS485 status		x	x	x	x	x	x	x	x
0		Selector position which can be linked to any of the variable combinations listed above (No. from 1 to 36)											
1		Selector position which can be linked to any of the variable combinations listed above (No. from 1 to 36)											
2		Selector position which can be linked to any of the variable combinations listed above (No. from 1 to 36)											
3		Selector position which can be linked to any of the variable combinations listed above (No. from 1 to 36). In this position the front LED blinks proportionally to the reactive energy (kvarh) being measured											

(1) The page is available according to the enabled measurement. **(2)** m^3 Gas, m^3 Water, kWh remote heating, external kWh counter. **(3)** Hot or Cold (water), gas, ENE (external energy meter). **(4)** The active tariff is displayed with an "A" before the "t1-t2-t3-t4" simbols.

CARLO GAVAZZI

Additional available information on the display

Type	1st line	2nd line	3rd line
Meter information pag. 1	Firmware release	Year	Year of production
Meter information pag. 2	Pulse	LED	Value
Meter information pag. 3	System	2w, 3w or 4w	
Meter information pag. 4	CT ratio	Value of CT ratio	
Meter information pag. 5	PT ratio	Value of PT ratio	
In case of alarm output pag.6a	Alarm output 1, 2 or 3 status (ON/OFF)	Set-point value	Variable type
In case of pulse output pag. 6b	Pulse output 1,2 or 3 variable link (kWh/kvarh)	Output pulse weight (kWh/ kvarh per pulse)	
In case of communication port pag.7	Serial port	Address	RS485 status (RX-TX)
In case of communication port pag.8	Secondary address (for M-bus protocol)	Sn	

List of selectable applications

	Description	Notes
A	Basic domestic **	Main energy metering
B	Shopping centres **	Main energy metering
C	Advanced domestic**	Main energy metering (total and based on tariff), gas and water metering
D	Multi domestic (also camping and marinas) * / **	Main energy metering (3 by single phase)
E	Solar *	Energy meter with some basic power analyzer functions
F	Industrial *	Main energy metering
G	Advanced industrial **	Energy metering and power analysis
H	Advanced industrial for power generation *	Complete energy metering and power analysis

Notes: * Not available with option PF A. ** Not available with option PF B

Insulation between inputs and outputs

	Measuring Inputs	Relay output	Open collector outputs	Comm. port	Digital inputs	Auxiliary power supply
Measuring Inputs	-	4kV	4kV	4kV	4kV	4kV
Relay output	4kV	-	-	4kV	-	4kV
Open collector outputs	4kV	-	-	4kV	-	4kV
Comm. port	4kV	4kV	4kV	-	4kV	4kV
Digital inputs	4kV	-	-	4kV	-	4kV
Aux. power supply	4kV	4kV	4kV	4kV	4kV	-

NOTE: all the models with auxiliary power supply have, mandatory, to be connected to external current transformers because the insulation among the current inputs is just functional (100VAC).

# Tamper proof and display page selection

Lock of programming with seal.
Selection of up to 4 main pages (programmable by the user).

Easy access to specific display pages.

Wiring diagrams

System type selection: 3P.n

3-ph, 4-wire, unbalanced load **Fig. 1**

3-CT connection

3-ph, 4-wire, unbalanced load **Fig. 2**

3-CT and 3-VT/PT connections

System type selection: 3P.n

3-ph, 3-wire, unbalanced load **Fig. 3**

3-CT connection

3-ph, 3-wire, unbalanced load **Fig. 4**

3-CT and 2-VT/PT connections

3-ph, 3-wire, unbalanced load **Fig. 5**

2-CT connections (ARON)

System type selection: 3P.1

3-ph, 3-wire, unbalanced load **Fig. 6**

2-CT and 2-VT/PT connections ARON

3-ph, 3-wire, balanced load **Fig. 7**
1-CT connection

NOTE: a 2-wire connection for voltage measurement is available across 15 and 17 .

3-ph, 3-wire, balanced load **Fig. 8**

1-CT and 2-VT/PT connections

Wiring diagrams

System type selection: 2P

System type selection: 1P

| 2-ph, 3-wire | **Fig. 9** |

2-CT connection

| 2-ph, 3-wire | **Fig. 10** |

2-CT and 2-VT/PT connections

| 1-ph, 2-wire | **Fig. 11** |

1-CT connection

**System type selection: 1P**

Auxiliary power supply wiring diagrams

| 1-ph, 2-wire | **Fig. 12** |

1-CT and 1-VT connections

| 100 to 230VAC/DC ("H" option) | **Fig.13** |

F= 250V [T] 100mA

Digital inputs and RS485 port wiring diagrams

Digital Inputs

RS485 port

RS485 NOTE: additional devices provided with RS485 are connected in parallel. The termination of the serial output is carried out only on the last instrument of the network, by means of a jumper between (A-) and (T).

Open collector and relay outputs wiring diagrams

Open Collector

GND reference

Open Collector

VDC reference

Relay

The load resistances (RC) must be designed so that the close contact current is lower than 100mA; the VDC voltage must be lower than or equal to 30VDC.

Front panel description

1. **Display**
   LCD-type with alphanumeric indications to:
   - display configuration parameters;
   - display all the measured variables.
2. **Selector**
   To select the desired display pages and to lock the programming.
3. **Joystick**
   To program the configuration parameters and scroll the variables on the display.
4. **LED**
   Red LED blinking proportionally to the energy being measured.

Dimensions and Panel Cut-out

X-ON Electronics

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Power Analysers *category:*

Click to view products by Carlo Gavazzi *manufacturer:*

Other Similar products are found below :

AQ1018   AQ1038   AR1039   AD1016H   AD1040   MOO2   EM2172DAV63XOSX   AQ1042   AD1047   CS-BB3-04   PEL 103   C.A 8220   EM21072DAV63XOSX   EM21072DMV53XOSX   EM21072DMV63XOSX   EM24DINAV53DISX   EM28072DMV53X2SX   EM28072DMV63X2SX   EM50DINAV53HRSX   EM50DINRG53HRSX   EM50DINMV53HRSX   WM1496AV53HDG   WM14DINAV63CS   FLUKE 345