# Smart Laser Sensors E3NC

CSM\_E3NC\_DS\_E\_2\_1

# Ideal for Applications That Cannot Be Handled with Fiber Sensors or Photoelectric Sensors

- A wide variety of easy-to-use Laser Photoelectric Sensor Heads.
  - Coaxial Retro-reflective Models (E3NC-LH03).
  - Long-distance, variable spot, Diffuse-reflective Models (E3NC-LH02)
  - Small-spot (0.1 mm dia.), Limited-reflective Models (E3NC-LH01).
  - CMOS Reflective Models (E3NC-SH series).
- Smart Tuning to achieve stable detection with easy setup.
- White on black display characters for high visibility.
- Robot cables for reliable operation in harsh environments.

Refer to the *Safety Precautions* on page 14.





For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

# Features

#### **Retro-reflective Models: E3NC-LH03**

- Maximum sensing distance of 8 m.
- Stable detection of many types of workpieces.
- Stable detection of highly transparent films.



- Long-distance detection at up to 1.2 m.
- Spot can be adjusted to the workpiece or application.





# CMOS Laser, Reflective Models: E3NC-SH250H/SH250/SH100

- Stable detection even for different workpiece colors and materials.Stable detection for inclined Head installation and different
- workpiece shapes.



## **Amplifier Units**

- Same shape as Fiber Amplifier Units plus easy operation.
- Smart Tuning with one button.



# **Ordering Information**

# Sensor Heads: E3NC-L Compact Laser Sensor Series (Dimensions → page 17)

Sensing method	Appearance	Beam shape	Sensing distance	Laser class	Cable length	Model
Coaxial Retro- reflective with MSR function		Spot		Class 1	2 m	E3NC-LH03 2M
			)) 0 111		5 m	E3NC-LH03 5M
Diffuse- reflective	R	Variable spot			2 m	E3NC-LH02 2M
			)) 1.2 m		5 m	E3NC-LH02 5M
Limited- reflective	IJ	Spot	70+15 mm		2 m	E3NC-LH01 2M
					5 m	E3NC-LH01 5M

These values apply when an E39-R21, E39-R22, E39-RS10, or E39-RS11 Reflector is used. A Reflector is not included. Purchase a Reflector separately to match the intended use of the Sensor.
 Note: Only an E3NC-LA Amplifier Unit can be connected.

# Amplifier Units: E3NC-L Compact Laser Sensor Series (Dimensions → page 19)

Connecting mothod	Appearance	Inputs/outputs	Model			
connecting method	Appearance	inputs/outputs	NPN output	PNP output		
Pre-wired (2 m)		2 outputs + 1 input	E3NC-LA21 2M	E3NC-LA51 2M		
Wire-saving Connector	ing Connector 1 out		E3NC-LA7	E3NC-LA9		
M8 Connector		1 output + 1 input	E3NC-LA24	E3NC-LA54		
Connector for Sensor Communications Unit *	5.		E3NC-LA0			

\* A Sensor Communications Unit is required if you want to use the Amplifier Unit on a network.

Note: Only an E3NC-LH Sensor Head can be connected.

# Sensor Heads: E3NC-S Ultra-compact CMOS Laser Sensor Series (Dimensions → page 18)

Sensing method	Appearance	Beam shape	Measureme	ent range	Laser class	Cable length	Model
Distance- settable		Spot	25	to 250 mm	Class 2 2 m	E3NC-SH250H 2M	
						2 m	E3NC-SH250 2M
			35 to 100	0 mm	Class 1	2 m	E3NC-SH100 2M

Note: Only an E3NC-SA Amplifier Unit can be connected.

## Amplifier Units: E3NC-S Ultra-compact CMOS Laser Sensor Series (Dimensions → page 19)

Connecting method	Annearance	Inputs/outputs	Model			
connecting method	Appearance	inputs/outputs	NPN output	PNP output		
Pre-wired (2 m)		2 outputs + 1 input	E3NC-SA21 2M	E3NC-SA51 2M		
Wire-saving Connector	F.	1 output + 1 input	E3NC-SA7	E3NC-SA9		
M8 Connector	<b>F</b> er	1 output + 1 input	E3NC-SA24	E3NC-SA54		
Connector for Sensor Communications Unit *	5-1		E3NC-SA0			

\* A Sensor Communications Unit is required if you want to use the Amplifier Unit on a network. **Note:** Only an E3NC-SH or E3NC-SH H Sensor Head can be connected.

## Accessories (Sold Separately) Sensor Head Accessories

Reflectors for Retro-reflective Sensors (Dimensions → page 21) A Reflector is not provided with the Sensor Head. It must be ordered separately as required.



#### Lens Attachments for Sensor Heads (Dimensions → page 21) A Lens Attachment is not provided with the Sensor Head. It must be ordered separately as required.

Applicable Sensor Head	Appearance	Model	Quantity
E3NC-LH03		E39-P51	4
E3NC-LH02		E39-P52	I

Note: You can combine the Lens Attachment with an applicable Sensor Head to create a line beam.

#### Sensor Head Mounting Brackets (Dimensions → page 22) A Mounting Bracket is not provided with the Sensor Head. It must be ordered separately as required.

A mounting bracket is not provided with the Sensor Head. It must be ordered separately as required.

Applicable Sensor Head	Appearance	Model	Quantity	Contents
E3NC-LH03		E39-L190		
E3NC-LH02		E39-L185		
E3NC-LH01		E39-L186	1	Mounting Bracket: 1 Nut plate: 1 Phillips screws (M3×18): 2
E3NC-SH250H		E39-L187		
E3NC-SH100		E39-L188		

## **Amplifier Unit Accessories**

Wire-saving Connectors (Required for models for Wire-saving Connectors.) (Dimensions → page 26) Connectors are not provided with the Amplifier Unit and must be ordered separately. \*Protective stickers are provided.

Туре	Type Appearance Cable length No. of c		No. of conductors	Model
Master Connector	*	2 m	4	E3X-CN21
Slave Connector	-	2 111	2	E3X-CN22

# Sensor I/O Connectors (Required for models for M8 Connectors.) (Dimensions $\rightarrow$ page 26) Connectors are not provided with the Amplifier Unit and must be ordered separately.

Size	Cable	Appearance		Cable	e type	Model
M8 Standa		Straight Contraction Contracti	2 m		XS3F-M421-402-A	
	Standard apple			5 m	- 4-wire	XS3F-M421-405-A
	Standard Cable -			2 m		XS3F-M422-402-A
				5 m		XS3F-M422-405-A

Note: For details, refer to XS3 which can be accessed from your OMRON website.

#### Amplifier Unit Mounting Bracket (Dimensions → page 27) A Mounting Bracket is not provided with the Amplifier Unit. It must be ordered separately as required.

Appearance	Model	Quantity
	E39-L143	1

Note: For details, refer to Mounting Brackets on E39-L/E39-S/E39-R which can be accessed from your OMRON website.

#### DIN Track (Dimensions → page 27)

A DIN Track is not provided with the Amplifier Unit. It must be ordered separately as required.

Appearance	Туре	Model	Quantity
	Shallow type, total length: 1 m	PFP-100N	
	Shallow type, total length: 0.5m	PFP-50N	1
	Deep type, total length: 1 m	PFP-100N2	

#### End Plate (Dimensions → page 27)

Two End Plates are provided with the Sensor Communications Unit. End Plates are not provided with the Amplifier Unit. They must be ordered separately as required.



# Related Products

**Sensor Communications Units** 

Туре	Appearance	Model
Sensor Communications Unit for EtherCAT	A State	E3NW-ECT
Sensor Communications Unit for CompoNet *1		E3NW-CRT
Sensor Communications Unit for CC-Link *1		E3NW-CCL
Distributed Sensor Unit *2	and the second s	E3NW-DS

\*1. Refer to your OMRON website for details.

\*2. The Distributed Sensor Unit can be connected to any of the Sensor Communications Units.

EtherCAT<sup>®</sup> is a registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany.

CompoNet is a registered trademark of the ODVA. CC-Link is a registered trademark of Mitsubishi Electric Corporation. The trademark is managed by the CC-Link Partner Association.

# **Ratings and Specifications**

# **Compact Laser Sensors: E3NC-L**

#### **Sensor Heads**

	Sensir	g method	Coaxial Ret with MSR	ro-reflective function	Diffuse-ı	reflective	Limited- reflective		
Item		Model	E3NC-LH03	E3NC-LH03+ E39-P51	E3NC-LH02	E3NC-LH02+ E39-P52	E3NC-LH01		
Light source	(wavelength)*	1	Visible semiconduct (JIS Class 1, IEC/EN	or laser diode (660 n N Class 1, and FDA C	m), 1.35 mW (averag Class 1)	e output: 315 μW)			
Sensing distance*2	Giga-power (GIGA)	mode	8 m		1,200 mm	1,000 mm			
	Standard mo	de (Stnd)	6 m	0.5 m	750 mm	600 mm	70+15 mm		
	High-speed r	node(HS)	3.5 m	0.5 11	250 mm	200 mm	70±15 1111		
	Super-high-s mode (SHS)	speed	2 m		200 mm	150 mm			
Beam shape			Spot	Line	Spot	Line	Spot		
Beam size*3		Approx. 2 mm dia. at 1 m	Line length: Approx. 25 mm at 250 mm Line length: Approx. 50 mm at 500 mm	Approx. 0.8 mm dia. at 300 mm	Line length: Approx. 45 mm at 500 mm Line length: Approx. 100 mm at 1,000 mm	Approx. 0.1 mm dia. at 70 mm			
Differential distance*4			10% of sensing distance max.						
Indicators			OUT indicator (orange) and STABILITY indicator (green)						
Ambient illumination (Receiver side)			Incandescent lamp: 10,000 lx max., Sunlight: 20,000 lx max.						
Ambient temp	perature range	e	Operating: -10 to 55°C; Storage: -25 to 70°C (with no icing or condensation)						
Ambient hum	idity range		Operating and storage: 35% to 85% (with no condensation)						
Insulation res	istance		20 MΩ min. (at 500 VDC)						
Dielectric stre	ength		1,000 VAC at 50/60 Hz for 1 min						
Vibration resi	stance (destr	uction)	10 to 55 Hz with a 1.5-mm double amplitude or 100 m/s <sup>2</sup> for 2 hours each in X, Y, and Z directions						
Shock resista	ince (destruct	ion)	500 m/s <sup>2</sup> for 3 times each in X, Y, and Z directions						
Degree of pro	tection		IEC IP67*5		IEC IP65 (E3NC-LH02: Applies only when adjuster is locked.)*5				
Connecting n	nethod		Pre-wired connector (standard length: 2 m)						
	0	Case	Polybutylene terephthalate (PBT)						
	Sensor Head	Lens	Methacrylic resin (P	MMA)					
Materials		Cable	Vinyl chloride (PVC)			-			
	Lens	Case		ABS		ABS			
	Attachment	Lens		Methacrylic resin (PMMA)		Methacrylic resin (PMMA)			
	Models with	2-m cable	Approx. 120 g/appro	ox. 70 g	Approx. 115 g/appro	ox. 65 g			
weight (packed state/Sensor	Models with	5-m cable	Approx. 180 g/appro	ox. 130 g	Approx. 175 g/appro	ox. 125 g			
Head only)	Lens Attachn	nent		Approx. 25 g/ approx. 2 g		Approx. 25 g/ approx. 2 g			
Accessories			Instruction Manual						

\*1. These Sensors excluding the E3NC-LH03 are classified as Class 1 laser devices under IEC 60825-1 and the regulations of Laser Notice No. 50 for FDA certification. CDRH (Center for Devices and Radiological Health) registration has been completed. (Accession Number: 1220690) Application to the CDRH (Center for Devices and Radiological Health) is scheduled for the E3NC-LH03. The values were measured using the OMRON standard sensing object (white paper) for the E3NC-LH01, E3NC-LH02, and E3NC-LH02 + E39-P52.

\*2. The values for the E3NC-LH03, and E3NC-LH03 + E39-P51 apply when an E39-R21, E39-R22, E39-RS10, or E39-RS11 Reflector is used. Other Reflectors are not recommended.

\*3. Defined at the  $1/e^2$  (13.5%) of the central intensity at the measurement distance.

Measurement may be influenced if there is light leakage outside the defined region and the surroundings of the target object have a high reflectance in comparison to the target object.

Measured at the rated sensing distance. \*4.

\*5. The E39-P5 contains a packing to prevent entry of foreign matter. The degree of protection between the E3NC-LH and E39-P5 is not specified.

## **Amplifier Units**

	Туре		Standard models			Model for Sensor Communications Unit		
		NPN output	E3NC-LA21	E3NC-LA7	E3NC-LA24	5010140		
		PNP output	E3NC-LA51	E3NC-LA9	E3NC-LA54	E3NC-LAU		
Item		Connecting method	Pre-wired	Wire-saving Connector	M8 Connector	Connector for Sensor Communications Unit		
Inputs/	Outputs		2 outputs	*1				
outputs	External inputs	3	1 input					
Power supply	voltage		10 to 30 VDC, including 1	0% ripple (p-p)		Supplied from the connector through the communications units		
Power consur	mption *2		At Power Supply Voltage Normal mode: 1,560mW Power saving eco mode	of 24 VDC / max. (Current consumptio e: 1,200 mW max. (Current o	n: 65mA max.) consumption: 50 mA max.	)		
			Load power supply voltag Load current: Groups of 1 Amplifier Units: 20 mA ma	e: 30 VDC max., open-colle to 3 Amplifier Units: 100 m/ ax.	ctor output A max., Groups of 4 to 30			
Control outpu	ıts*3		Residual voltage: At load current of less At load current of 10 to					
			OFF current: 0.1 mA max.					
External input	ts		Refer to *4.					
Indicators			7-segment displays (Sub digital display: green, Main digital display: white) Display direction: Switchable between normal and reversed. OUT indicator (orange), L/D indicator (orange), ST indicator (blue), DPC indicator (green), and OUT selection indicator (orange, only on models with 2 outputs)					
Protection circuits			Power supply reverse pola output reverse polarity pro	Power supply reverse polarity protection and output short-circuit protection				
	Super-high-spe	eed mode (SHS)*5	Operate or reset: 80 µs					
Response	High-speed mo	ode (HS)	Operate or reset: 250 μs					
time	Standard mode	e (Stnd)	Operate or reset: 1 ms					
	Giga-power mo	ode (GIGA)	Operate or reset: 16 ms					
Sensitivity ad	justment		Smart Tuning (2-point tuning, full auto tuning, position tuning, maximum sensitivity tuning, power tuning, or percentage tuning (–99% to +99%)), or manual adjustment.					
No. of Unite	Super-high-spe	eed mode (SHS)*5	0					
for mutual	High-speed mo	ode (HS)	2					
prevention	Standard mode	e (Stnd)	2					
-	Giga-power mo	ode (GIGA)	4					
	Dynamic powe	r control (DPC)	Provided					
	Timer		Select from timer disabled, OFF-delay, ON-delay, one-shot, or ON-delay + OFF-delay timer: 1 to 9,999 ms					
	Zero reset	**	Negative values can be di	splayed. (Threshold value i	s shifted.)			
	Resetting setting	ngs^6	Select from initial reset (factory defaults) or user reset (saved settings).					
Eco mode Bank switching		Select from OFF (digital displays lit) or ECO (digital displays not lit).						
		Select from banks 1 to 4.						
Functions	Power tuning		Select from ON or OFF.					
	Output 1		Select from Normal Detec	Select from Normal Detection Mode or Area Detection Mode.				
	Output 2		Select from normal detection mode, alarm output mode, or error output mode.	_	-	Select from normal detection mode, alarm output mode, or error output mode.		
	External input		Select from input OFF, tur switching.	ning, power tuning, laser OF	F, zero reset, or bank			
	Hysteresis wid	th	Select from standard setti	ng or user setting.				

1.

Two sensor outputs are allocated in the programmable logic controller PLC I/O table. PLC operation via Communications Unit enables reading detected values and changing settings.

\*2.

At Power Supply Voltage of 10 to 30 VDC. Normal mode: 1,650 mW max. (Current consumption: 55 mA max. at 30 VDC, 115 mA max. at 10 VDC)

Power saving eco mode: 1,350 mW max. (Current consumption: 45 mA max. at 30 VDC, 80 mA max. at 10 VDC) \*3. The total for both outputs of a model with 2 outputs is 100 mA max. (Residual voltage: Load current of less than 10 mA: 1 V max., Load current of 10 to 100 mA: 2 V max.). \*4. The following details apply to the input.

	Contact input (relay or switch)	Non-contact input (transistor)	Input time*4-1
NPN	ON: Shorted to 0 V (Sourcing current: 1 mA max.). OFF: Open or shorted to Vcc.	ON: 1.5 V max. (Sourcing current: 1 mA max.) OFF: Vcc – 1.5 V to Vcc (Leakage current: 0.1 mA max.)	ON: 9 ms min.
PNP	ON: Shorted to Vcc (Sinking current: 3 mA max.). OFF: Open or shorted to 0 V.	ON: Vcc – 1.5 V to Vcc (Sinking current: 3 mA max.) OFF: 1.5 V max. (Leakage current: 0.1 mA max.)	OFF: 20 ms min.

\*4-1.Input time is 25 ms (ON)/(OFF) only when (in tUnE) or (in PtUn) input is selected. The mutual interference prevention function is disabled if the detection mode is set to super-high-speed mode. The bank is not reset by the user reset function or saved by the user save function. \*5.

\*6.

Туре			Standard models		Model for Sensor Communications Unit	
	NPN output		E3NC-LA21 E3NC-LA7			
	PNP output	E3NC-LA51 E3NC-LA9		E3NC-LA54	ESINC-LAU	
Item	Connecting method	Pre-wired	Wire-saving Connector	M8 Connector	Connector for Sensor Communications Unit	
Maximum connectable Units		30				
Ambient temperature range		Operating: Groups of 1 or 2 Amplifier Un Groups of 3 to 10 Amplifier L Groups of 11 to 16 Amplifier Groups of 17 to 30 Amplifier Storage: –30 to 70°C (with n	Operating: Groups of 1 or 2 Amplifier Units: 0 to 55°C, Groups of 3 to 10 Amplifier Units: 0 to 50°C, Groups of 11 to 16 Amplifier Units: 0 to 45°C, Groups of 17 to 30 Amplifier Units: 0 to 40°C, Storage: -30 to 70°C (with no icing or condensation)			
Ambient humidity range		Operating and storage: 35% to 85% (with no condensation)				
Insulation resistance		20 MΩ (at 500 VDC)				
Dielectric strength		1,000 VAC at 50/60 Hz for 1 min				
Vibration resistance (des	struction)	10 to 55 Hz with a 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions				
Shock resistance (destruction)		500 m/s <sup>2</sup> for 3 times each in X, Y, and Z directions			150m/s <sup>2</sup> for 3 times each in X, Y, and Z directions	
Weight (packed state/Amplifier Unit only)		Approx. 115 g/approx. 75 g	Approx. 60 g/approx. 20 g	Approx. 65 g/approx. 25 g		
Case		Polycarbonate (PC)				
Materials	Cover	Polycarbonate (PC)				
	Cable	Vinyl chloride (PVC)				
Accessories		Instruction Manual				

# Accessories

## Reflectors

Item Model	I E39-R21 E39-R22		E39-RS10	E39-RS11	
Ambient temperature	Operating: -10 to 55°C; S	Storage: -25 to 70°C (with r	no icing or condensation)		
Ambient humidity	Operating/storage: 35% t	to 85% (with no condensat	ion)		
Vibration resistance (destruction)	10 to 55 Hz with a 1.5-m	n double amplitude or 100	m/s <sup>2</sup> for 2 hours each in X	K, Y, and Z directions	
Shock resistance (destruction)	500 m/s <sup>2</sup> 3 times each in X, Y, and Z directions				
Degree of protection	IEC IP67 (E39-R21 and E39-R22 only)				
Materials	Reflective surface:         Methacrylic resin (PMMA)           Back surface:         Polybutylene terephthalate (PBT)			)	
Weight (packed state/Reflector only)	Approx. 30 g/approx. 5 g	Approx. 35 g/approx. 10 g	Approx. 26 g/approx. 1 g	Approx. 30 g/approx. 5 g	
Accessories	Instruction manual				

# Ultra-compact CMOS Laser Sensor: E3NC-S

#### **Sensor Heads**

	Sensing method	Distance-settable			
Item	Model	E3NC-SH250H	E3NC-SH250	E3NC-SH100	
Light source (wavelength)*1		Visible semiconductor laser diode (660 nm), 1 mW (average output: 220 $\mu$ W) (JIS Class 2, IEC/EN Class 2, and FDA Class 2) Visible semiconductor laser diode output: 100 $\mu$ W) (JIS Class 1, IEC/		e (660 nm), 0.5 mW (average //EN Class 1, and FDA Class 1)	
Measureme	nt range	35 to 250 mm (display value: 350	to 2,500)	35 to 100 mm (display value: 350 to 1,000)	
Standard de *2	etected level difference	35 to 180mm: 9 mm 180 to 250 mm: 25 mm		35 to 50 mm: 1.5 mm 50 to 100 mm: 3 mm	
Beam size*3		Approx. 1 mm dia. at 250 mm		Approx. 0.5 mm dia. at 100 mm	
Indicators		OUT indicator (orange), STABILIT	Y indicator (green), and ST indicat	or (blue)	
Ambient illumination (Receiver side)		Incandescent lamp: 4,000 lx max., Sunlight: 8,000 lx max.	Incandescent lamp: 2,000 lx max., Sunlight: 4,000 lx max.	Incandescent lamp: 4,000 lx max., Sunlight: 8,000 lx max.	
Ambient ten	nperature range	Operating: -10 to 50°C; Storage: -25 to 70°C (with no icing or condensation)			
Ambient hu	midity range	Operating and storage: 35% to 85% (with no condensation)			
Insulation re	esistance	20 MΩ min. (at 500 VDC)			
Dielectric st	rength	1,000 VAC at 50/60 Hz for 1 min			
Vibration re	sistance (destruction)	10 to 55 Hz with a 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions			
Shock resis	tance (destruction)	500 m/s <sup>2</sup> 3 times each in X, Y, and Z directions			
Degree of p	rotection	IEC IP67			
Connecting method		Pre-wired connector (Standard cable length: 2 m)			
Case		Polybutylene terephthalate (PBT)			
Materials	Lens	Methacrylic resin (PMMA)			
	Cable	Vinyl chloride (PVC)			
Weight (pac only)	ked state/Sensor Head	Approx. 125 g/approx. 75 g			
Accessories	6	Instruction Manual, laser warning label (E3NC-SH250H only)			

Note: Incorrect detection may occur outside the measurement range if the object has a high reflection factor. \*1. These Sensors are classified as Class 1 laser devices under IEC 60825-1 and the regulations of Laser Notice No. 50 for FDA certification. CDRH (Center for Devices and Radiological Health) registration has been completed. (Accession Number: 1220691)

\*2. The values were measured at the center of the sensing distance using OMRON's standard sensing object (white ceramic).

Beam size: Defined at the  $1/e^2$  (13.5 %) of the central intensity at the measurement center distance. Measurement may be influenced if there is light leakage outside the defined region and the surroundings of the target object have a high reflectance in comparison \*3. to the target object.

Also, when detecting a workpiece that is smaller than the beam size, a correct value may not be obtained.

#### **Amplifier Units**

Туре		Standard models			Model for Sensor Communications Unit		
		NPN output	E3NC-SA21	E3NC-SA7	E3NC-SA24		
		PNP output	E3NC-SA51	E3NC-SA9	E3NC-SA54	E3NC-SA0	
Item		Connecting method	Pre-wired	Wire-saving Connector	M8 Connector	Connector for Sensor Communications Unit	
Inputs/	Outputs		2 outputs	*1			
outputs	External input	S	1 input				
Power supply	voltage		10 to 30 VDC, including 1	0% ripple (p-p)		Supplied from the connector through the communications units	
Power consu	mption *2		At Power Supply Voltage Normal mode: 1,920 m Power saving eco mode	of 24 VDC W max. (Current consumptic e: 1,680 mW max. (Current c	on: 80 mA max.) consumption: 70 mA max.)		
			Load power supply voltag Load current: Groups of 1 Amplifier Units: 20 mA ma	e: 30 VDC max., open-colle to 3 Amplifier Units: 100 m/ ax.	ctor output A max., Groups of 4 to 30		
Control outpu	ıts *3		Residual voltage: At load current of less At load current of 10 to	than 10 mA: 1 V max. o 100 mA: 2 V max.			
			OFF current: 0.1 mA max.				
External input	ts		Refer to *4.				
Indicators			7-segment displays (Sub digital display: green, Main digital display: white) Display direction: Switchable between normal and reversed. OUT indicator (orange), L/D indicator (orange), ST indicator (blue), ZERO indicator (green), and OUT selection indicator (orange, only on models with 2 outputs)				
Protection cir	cuits		Power supply reverse pol output reverse polarity pro	Power supply reverse polarity protection and output short-circuit protection			
	Super-high-sp	eed mode (SHS) *5	Operate or reset: 1.5 ms				
Response	High-speed me	ode (HS)	Operate or reset: 5 ms				
time	Standard mod	e (Stnd)	Operate or reset: 10 ms				
	Giga-power m	ode (GIGA)	Operate or reset: 50 ms				
Sensitivity ad	justment		Smart Tuning (2-point tuning, full auto tuning, 1-point tuning, tuning without workpiece, 2-point area tuning, 1-point area tuning, or area tuning without workpiece), or manual adjustment				
	Super-high-sp	eed mode (SHS) *5	0				
No. of Units for mutual	High-speed me	ode (HS)	2				
interference	Standard mod	e (Stnd)	2				
prevention	Giga-power m	ode (GIGA)	2				
	Timer		Select from timer disabled, OFF-delay, ON-delay, one-shot, or ON-delay + OFF-delay timer: 1 to 9,999 ms				
	Zero reset		Negative values can be displayed. (Threshold value is shifted.)				
Resetting settings *6		Select from initial reset (factory defaults) or user reset (saved settings).					
Eco mode		Select from OFF (digital displays lit) or ECO (digital displays not lit).					
Bank switching		Select from banks 1 to 4.					
	Output 1		Select from Normal detec	tion mode, Area detection m	node, or hold mode.		
Functions	Output 2		Select from Normal detection mode or Error output mode.	n Normal mode or Error		Select from Normal detection mode or Error output mode.	
	External input		Select from input OFF, tu	ning, laser OFF, zero reset,	or bank switching.		
	Keep function	*7	Select from ON or OFF.				
	Background s	uppression*8	Select from ON or OFF.				
	Hysteresis wid	lth	Select from standard setting or user setting.				

\*1.

Two sensor outputs are allocated in the programmable logic controller PLC I/O table. PLC operation via Communications Unit enables reading detected values and changing settings. At Power Supply Voltage of 10 to 30 VDC.

\*2.

Normal mode: 2,250 mW max. (Current consumption: 75 mA max. at 30 VDC, 145 mA max. at 10 VDC)

Power saving eco mode: 1,950 mW max. (Current consumption: 65 mA max. at 30 VDC, 125 mA max. at 10 VDC) The total for both outputs of a model with 2 outputs is 100 mA max. (Residual voltage: Load current of less than 10 mA: 1 V max., Load current of 10 to 100 mA: \*3. 2 V max.). \*4. The following details apply to the input.

	Contact input (relay or switch)	Non-contact input (transistor)	Input time*4-1
NPN	ON: Shorted to 0 V (Sourcing current: 1 mA max.). OFF: Open or shorted to Vcc.	ON: 1.5 V max. (Sourcing current: 1 mA max.) OFF: Vcc – 1.5 V to Vcc (Leakage current: 0.1 mA max.)	ON: 9 ms min.
PNP	ON: Shorted to Vcc (Sinking current: 3 mA max.). OFF: Open or shorted to 0 V.	ON: Vcc – 1.5 V to Vcc (Sinking current: 3 mA max.) OFF: 1.5 V max. (Leakage current: 0.1 mA max.)	OFF: 20 ms min.

\*4-1. Input time is 25 ms (ON)/(OFF) only when (in tUnE) input is selected.
\*5. The mutual interference prevention function is disabled if the detection mode is set to super-high-speed mode.
\*6. The bank is not reset by the user reset function or saved by the user save function.

\*6. \*7.

The output for a measurement error is set. ON: The value of the output from before the measurement error is retained. OFF: The output is turned OFF when a measurement error occurs.

\*8. Only the sensing object is detected when tuning.

	Туре		Standard models		Model for Sensor Communications Unit		
	NPN output	E3NC-SA21	E3NC-SA7	E3NC-SA24	E3NC-SA0		
	PNP output	E3NC-SA51	E3NC-SA9	E3NC-SA54	LJNC-JAU		
Item	Connecting method	Pre-wired	Connector for Sensor Communications Unit				
Maximum connectable U	Inits	30					
Ambient temperature range		Operating: Groups of 1 or 2 Amplifier Ur Groups of 3 to 10 Amplifier U Groups of 11 to 16 Amplifier Groups of 17 to 30 Amplifier Storage: -30 to 70°C (with r	Operating: Groups of 1 or 2 Amplifier Units: 0 to 55°C, Groups of 3 to 10 Amplifier Units: 0 to 50°C, Groups of 11 to 16 Amplifier Units: 0 to 45°C, Groups of 17 to 30 Amplifier Units: 0 to 40°C Storage: –30 to 70°C (with no icing or condensation)				
Ambient humidity range		Operating and storage: 35% to 85% (with no condensation)					
Insulation resistance		20 MΩ (at 500 VDC)					
Dielectric strength		1,000 VAC at 50/60 Hz for 1 min					
Vibration resistance (des	struction)	10 to 55 Hz with a 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions					
Shock resistance (destruction)		500 m/s <sup>2</sup> for 3 times each in X, Y, and Z directions			150 m/s <sup>2</sup> for 3 times each in X, Y, and Z directions		
Weight (packed state/Amplifier Unit only)		Approx. 115 g/approx. 75 g	Approx. 60 g/approx. 20 g	Approx. 65 g/approx. 25 g			
Case		Polycarbonate (PC)					
Materials	Cover	Polycarbonate (PC)					
	Cable	Vinyl chloride (PVC)					
Accessories		Instruction Manual					

# **Engineering Data (Reference Value)**

## Beam Diameter Vs. Distance



#### Diffuse-reflective Model E3NC-LH02 + E39-P52



# Limited-reflective Model E3NC-LH01



#### Distance-settable Model E3NC-SH250/SH250H



#### Distance-settable Model E3NC-SH100



# I/O Circuit Diagrams

NPN Output				
Model	Operation mode	Timing chart	L/D indicator	Output circuit
E3NC-LA21	Light-ON	ch1/ Incident light ch2 No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between brown and black (orange) leads)	L lit.	Display 00T1 indicator 00T2 indicator (orange) (orange) Brown Black Load Photoelectic Control output Load Orange ch1 10 to
E3NC-SA21	Dark-ON	ch1/ Incident light ch2 No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between brown and black (orange) leads)	D lit.	Service man dicut Service man dicut Service man Control output Pink Ch2 External Blue Service man So VDC
E3NC-LA7 E3NC-LA24	Light-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between brown and black leads)	L lit.	Display OUT indicator (orange) Photoelectic Photoelectic 10 to
E3NC-SA7 E3NC-SA24	Dark-ON	Incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Batween brown and black leads)	D lit.	30 VDC

# **PNP Output**

Model	Operation mode	Timing chart	L/D indicator	Output circuit
E3NC-LA51	Light-ON	ch1/ Incident light ch2 No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between blue and black (orange) leads)	L lit.	Display OUT1 indicator OUT2 indicator (orange) (orange) Pink External input Pink Control output Black chi
E3NC-SA51	Dark-ON	ch1/ Incident light ch2 No incident light OUT Indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between blue and black (orange) leads)	D lit.	Sensor man cicult Control output ch2 Control output ch2 Control output ch2 Blue Load
E3NC-LA9 E3NC-LA54	Light-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between blue and black leads)	L lit.	Display OUT indicator (orange) Photoectic Photoectic
E3NC-SA9 E3NC-SA54	Dark-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Operate (e.g., relay) Reset (Between blue and black leads)	D lit.	Blue 30 VDC

# Nomenclature

# Compact Laser Sensors

#### E3NC-LA21/LA51/LA0

E3NC-SA21/SA51/SA0



**Ultra-compact CMOS Laser Sensors** 

#### E3NC-LA7/LA9/LA24/LA54



#### E3NC-SA7/SA9/SA24/SA54



[
MODE Button]
Used to switch between Detection
Mode and Setting Mode.

[ L/D Button]

Used to switch

between Light-ON and Dark-ON.

[±UP/DOWN Button] Used to fine-tune the threshold or change set values.

# **Safety Precautions**

## To ensure safe operation, be sure to read and follow the Instruction Manual provided with the Sensor.

## Indication and Meaning for Safe Use

	Indicates a potentially hazardous situation which, if not avoided, will result in minor or moderate injury, or may result in serious injury or death. Additionally there may be significant property damage.
Precautions for Safe Use	Supplementary comments on what to do or avoid doing, to use the product safely.
Precautions for Correct Use	Supplementary comments on what to do or avoid doing, to prevent failure to operate, malfunction or undesirable effect on product performance.

# **Sensor Heads**

#### Laser Safety

Various safety standards regarding laser devices are stipulated in Japan and abroad. When this Sensor Head is used in Japan and when it is assembled in Japan but exported to a foreign country, the safety standards are classified into three cases.

#### 1. When Using the Sensor Head in Japan

JIS C6802 stipulates the safety measures that must be observed by the user for each type of laser equipment.

E3NC-LH Sensor Heads: Class 1 E3NC-SH Sensor Heads: Class 1 E3NC-SH H Sensor Heads: Class 2

## <u> WARNING</u>

Do not expose your eyes to the laser beam either directly or indirectly (i.e., after reflection from a mirror or shiny surface). The laser beam has a high power density and exposure may result in loss of sight.



Do not disassemble the Sensor Head. Doing so may cause the laser beam to leak, resulting in a risk of visual impairment.



 The following laser warning label and laser description labels are attached to the sides of the Sensor Heads. E3NC-LH03 Description Label Certification Label

Description Label Certification La Class1 LASER PRODUCT

E3NC-LH01 /E3NC-LH02

E3NC-SH



E3NC-SH□□H



Laser Warning Labe

Description Labe





#### 2. Using in the USA

When using devices in which the Sensor Head is installed in the USA, the devices are subject to FDA (Food and Drug Administration) laser regulations of the USA.

#### E3NC-LH03:

These Sensor Heads are classified as Class 1 laser devices under IEC/EN 60825-1 and the regulations of Laser Notice No. 50 for this certification. Application to the CDRH (Center for Devices and Radiological Health) is scheduled.

#### E3NC-LH01, E3NC-LH02:

These Sensor Heads are classified as Class 1 laser devices under IEC/EN 60825-1 and the regulations of Laser Notice No. 50 for this certification. CDRH (Center for Devices and Radiological Health) registration has been completed. (Accession Number: 1220690)

#### E3NC-SHOD, E3NC-SHODH:

These Sensor Heads are classified as Class 1 or Class 2 laser devices under IEC/EN 60825-1 and the regulations of Laser Notice No. 50 for this certification. CDRH (Center for Devices and Radiological Health) registration has been completed. (Accession Number: 1220691)

For countries other than Japan
 Benlage the warning lebel with

Replace the warning label with the corresponding English label (supplied with  $SH\square\squareH$ ).



#### 3. Using in Europe

E3NC-LH , E3NC-SH ::

These Sensor Heads are classified in Class 1 under EN 60825-1. E3NC-SH $\square$ H:

These Sensor Heads are classified in Class 2 under EN 60825-1.

14

#### **Precautions for Safe Use**

The following precautions must be observed to ensure safe operation of the Sensor Head.

- **1.** Installation Environment
- Do not use the Sensor Head in an environment where explosive or flammable gas is present.
- To secure the safety of operation and maintenance, do not install the Sensor Head close to high-voltage devices or power devices.
- 2. Power Supply and Wiring
- Always use an E3NC-LA , E3NC-LA0, E3NC-SA or E3NC-SA0 Amplifier Unit. If a different Amplifier Unit is used, damage or fire may occur.
- If you short the cable, reconnect it as specified. If the connections are not correct, damage or fire may occur.
- High-voltage lines and power lines must be wired separately from the Sensor Head. Wiring them together or placing them in the same duct may cause induction, resulting in malfunction or damage.
- Always turn OFF the power supply before connecting or disconnecting the connectors.
- 3. Installation
- Use screws for installation and tighten the screws securely, but do not exceed the specified tightening torque.
   Specified torque (M3): 0.5 N·m
- 4. Others
- Never disassemble (including removing labels), repair, modify, deform by pressure, or incinerate the Sensor Head. Do not turn the adjuster on the E3NC-LH02 with a force that is greater than 40 mN·m. Damage or fire may occur.
- · Dispose of the Sensor Head as industrial waste.
- If you notice any abnormalities, immediately stop using the Sensor Head, turn OFF the power supply, and contact your OMRON representative.

#### **Precautions for Correct Use**

Observe the following precautions to prevent failure to operate,

malfunctions, or undesirable effects on Sensor Head performance. **1.** Installation Environment

Do not install the Sensor Head in locations subject to the following conditions:

- · Ambient temperatures outside of the rated range
- Condensation caused by rapid changes in temperature
- Relative humidity that is not between 35% and 85%
- Corrosive or flammable gas
- Dust, salt, or iron particles
- Direct vibration or shock
- Strong external light interference (such as other laser beams or electric arc-welding machines)
- · Direct sunlight or near heaters
- Water, oil, or chemical fumes or spray
- Strong magnetic or electric fields
- 2. Warming Up
- The circuits will be unstable just after the power supply is turned ON, so measurement values may fluctuate gradually.
- For accurate measurements, allow the product to stand for at least 10 minutes after turning ON the power supply before use. (E3NC-S Series)

- 3. Maintenance and Inspection
- Always turn OFF the power supply before adjusting or connecting/ disconnecting the Sensor Head.
- Do not use thinner, benzene, acetone, or kerosene to clean the Sensor Head.
- If large dust particles or dirt adheres to the filter on the front of the Sensor Head, use a blower brush (such as one used to clean camera lenses) to blow it off. Do not blow the dust particles or dirt with your mouth. To remove dust particles or dirt, wipe it off gently with a soft cloth (such as one for cleaning lenses) moistened with a small amount of alcohol. Do not wipe it off with excessive force. Scratches on the filter may cause errors.
- 4. Sensing Object
- The Sensor Head cannot accurately measure objects with the following materials and shapes: Transparent objects (with the E3NC-LH03, objects that are extremely transparent), objects with an extremely low reflection ratio, objects smaller than the spot diameter, objects with a large curvature, excessively inclined objects, etc. Also, for long-distance detection, the Sensor may falsely operate if a white object approaches near the Sensor Head (E3NC-LH03).
- 5. The degree of protection is IP67, but do not use the Sensor Head in water, rain, or outdoors. (E3NC-S Series)
- A ferrite core is attached to the Sensor Head end of the cable connected to the E3NC-LH03 5M. Do not remove the ferrite core or change its position. Also, do not bend the cable within 12 mm of each end of the ferrite core. Doing so may damage the cable.

#### Attaching a Lens Attachment (E39-P51 or E39-P52)

 Check the widths of the slots in the Sensor and the widths of the tabs on the Lens Attachment and attach the Lens Attachment as shown below. (The Lens Attachment must be in the correct orientation, so the widths of the tabs on the Lens Attachment are different on the top and bottom.)



2. After you attach the Lens Attachment, make sure that the tabs are completely engaged in the slots in the Sensor.



# **Amplifier Units**

#### \Lambda WARNING

This Amplifier Unit is not designed or rated for ensuring safety of persons either directly or indirectly.

Do not use it for such purposes.

Do not use the Amplifier Unit with voltage in excess of the rated voltage. Excess voltage may result in malfunction or fire.

Never use the Amplifier Unit with an AC power supply. Otherwise, explosion may result.



#### Precautions for Safe Use

The following precautions must be observed to ensure safe operation of the Amplifier Unit. Doing so may cause damage or fire.

- 1. Do not install the Amplifier Unit in the following locations.
- · Locations subject to direct sunlight
- · Locations subject to condensation due to high humidity
- · Locations subject to corrosive gas
- · Locations subject to vibration or mechanical shocks exceeding the rated values
- · Locations subject to exposure to water, oil, chemicals
- · Locations subject to steam
- Locations subjected to strong magnetic field or electric field
- 2. Do not use the Amplifier Unit in environments subject to flammable or explosive gases.
- 3. Do not use the Amplifier Unit in any atmosphere or environment that exceeds the ratings.
- 4. To secure the safety of operation and maintenance, do not install the Amplifier Unit close to high-voltage devices or power devices.
- 5. High-voltage lines and power lines must be wired separately from the Amplifier Unit. Wiring them together or placing them in the same duct may cause induction, resulting in malfunction or damage.
- 6. Do not apply any load exceeding the ratings. Otherwise, damage or fire may result.
- 7. Do not short the load. Otherwise, damage or fire may result.
- 8. Do not use the Amplifier Unit if the case is damaged.
- 9. Burn injury may occur. The Amplifier Unit surface temperature rises depending on application conditions, such as the ambient temperature and the power supply voltage. Use caution when operating or cleaning the Amplifier Unit.
- 10. When setting the sensor, be sure to check safety such as by stopping the equipment.
- .Be sure to turn off the power supply before connecting or disconnecting wires.
- 12.Do not attempt to disassemble, repair, or modify the Amplifier Unit in anv wav.
- 13. When disposing of the Amplifier Unit, treat it as industrial waste.

#### **Precautions for Correct Use**

- 1. Connect the load correctly.
- Do not miswire such as the polarity of the power supply.
- 3. Be sure to mount the unit to the DIN track until it clicks.
- 4. When using the Amplifier Units with Wire-saving Connectors, attach the protective stickers (provided with E3X-CN-series Connectors) on the unused power pins to prevent electrical shock and short circuiting. Attach the protective cap when using a model with a connector for

a Sensor Communications Unit. Amplifier Unit with Wire-

Amplifier Unit with Connector for Sensor Communications Unit





Protective cap

- connecting terminals 5. Use an extension cable with a minimum thickness of  $0.3 \text{ mm}^2$  and less than 100 m long.
- 6. Do not apply the forces on the cord exceeding the following limits: Pull: 40 N; torque: 0.1 N·m; pressure: 20 N; bending: 29.4 N
- 7. Do not apply excessive force (9.8 N max.) such as tension, compression or torsion to the connector of the Sensor Head that is fixed to the Amplifier Unit.
- 8 Always keep the protective cover in place when using the Amplifier Unit. Not doing so may cause malfunction.
- 9. It may take time until the received light intensity and measured value become stable immediately after the power is turned on depending on use environment.
- 10. The product is ready to operate 200 ms after the power supply is turned ON.
- 11. The Mobile Console E3X-MC11, E3X-MC11-SV2 and E3X-MC11-S cannot be connected.
- 12. The mutual interference prevention function does not work when in combination with E3C/E2C/E3X.
- 13.If the unit receives excessive sensor light, the mutual interference prevention function may not work properly, resulting in malfunction of the unit. In such case, increase the threshold.
- 14.Standard models (E3NC-DA21/51/7/9) The Sensor Communications Unit E3X-DRT21-S, E3X-CRT, E3X-ECT and E3NW cannot be connected. Model for Sensor Communications Unit (E3NC-□A0) The Sensor Communications Unit E3NW can be connected. E3X-DRT21-S, E3X-CRT, E3X-ECT cannot be connected.
- 15. If you notice an abnormal condition such as a strange odor, extreme heating of the unit, or smoke immediately stop using the product, turn off the power, and consult your dealer.
- 16.Do not use thinner, benzene, acetone, and lamp oil for cleaning.

# Dimensions

# **Sensor Heads**





#### Diffuse-reflective Model E3NC-LH02



#### Limited-reflective Model E3NC-LH01



# **Amplifier Units**



(13)

Wire-saving Connector

Mounting Holes Two, M3 holes

φ

(sold separately)

unications

(86.9)

32.1

(49.5)

Optical cor

PFP-DN DIN Track

(sold separately)

(24)

(13)

Wire-saving

Connecto

communications (sold separately)

E39-L143 Mounting Bracket

(sold separately, SUS304)

Q

Ne

(9.4)

T

16

-16 -

- Øf

. htica

0

5

Two, 3.2 dia

(mounting holes)

32.

-(41.5)



#### Amplifier Units with Connectors for Sensor Communications Unit E3NC-LA0 E3NC-SA0



\*1. The indicators are as follows:

# Accessories (Sold Separately)



21

#### Sensor Head Mounting Brackets E39-L190





16.4

20.5±0.1

φ

8.4 10.5

#### With E39-L190 Mounting Bracket Attached for Bottom Mounting

31.5

16.4 10.5 8.4

6.5±0.1

+ 16.4 + 17.5 + 16.4 + 17.5 21.5±0.1+

10.5±0.1



#### With E39-L190 Mounting Bracket Attached for Back Mounting



#### E39-L185





#### With E39-L185 Mounting Bracket Attached



#### E39-L186

#### Mounting Bracket Material: Stainless steel (SUS304)





## Accessories: Phillips screws (M3×18, P = 0.5, stainle Nut plate: 1



# E3NC

#### With E39-L186 Mounting Bracket Attached for Bottom Mounting







#### E39-L187





24

With E39-L187 Mounting Bracket Attached



#### E39-L188



#### With E39-L188 Mounting Bracket Attached



## **Wire-saving Connectors**

#### Master Connector E3X-CN21





\*4-dia. cable with 4 conductors, Standard cable length: 2 m (Conductor cross-section: 0.2 mm<sup>2</sup> (AWG24), Insulation diameter: 1.1 mm)

#### Slave Connector E3X-CN22





\*4-dia. cable with 2 conductors, Standard cable length: 2 m (Conductor cross-section: 0.2 mm<sup>2</sup> (AWG24), Insulation diameter: 1.1 mm)

# Sensor I/O Connectors



L-shaped XS3F-M422-40□-A





#### Amplifier Unit Mounting Bracket E39-L143



#### DIN Track PFP-100N PFP-50N



Material: Aluminum

#### PFP-100N2



Material: Aluminum

# End Plate









Materials: Iron, zinc plating

Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranties.

(a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.

(b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE

PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See <u>http://www.omron.com/global/</u> or contact your Omron representative for published information.

#### Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

#### Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buver's application or use of the Product. At Buver's request. Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

#### Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof

#### Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

#### Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions. Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

OMRON Corporation Industrial Automation Company

# **X-ON Electronics**

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Photoelectric Sensors category:

Click to view products by Omron manufacturer:

Other Similar products are found below :

E3JM-DS70R4T-US E3L2DC4 E3RA-DN12 2M E3RA-DP12 2M E3S5LE4S E3S-AD38 E3S-CR11 5M E3SCT11D5M E3SCT11M1J03M E3T-SL14R E3T-SL24 5M E3T-ST12R E3X-CN02 E3X-CN11 5M E3X-CN21 10M E3ZM-B66 E3ZM-CL81H 2M E3Z-T62 2M NJL5303R-TE1 PB10CNT15PO PD60CNX20BP CX-491-P-J CX-491-Z XUM2BKCNL2T XUM2BKCNL2T XUM2BNANL2R Y92E-ES30M Y92E-GS08SS ZXTDS04T ZX-XC4A 4M E3E23Y2US E3JM-DS70S4-US E3RA-RN11 2M E3S5LE42M E3S-LS20XB4 5M E3TFD14N E3T-FD14R E3T-SL21 5M E3T-SL21M E3T-ST11R E3T-ST12 5M E3X-DA41-S-M1J 0.3M E3X-DAB6 E3X-DAG8 E3ZM-B86 E3ZM-CR81 2M E3ZM-CR86 E3Z-T61A-L 2M ZX-XGC2R ZX-XB1A