Solid-state Timer

Miniature Timer with Multiple Time Ranges and Multiple Operating Modes

- Multiple operating modes include ON-delay, interval, flicker OFF start, or flicker ON start.
- Multiple time ranges from 0.1 s to 10 min or 1 min to 10 hr
- Minimizes stock: User selectable time range and mode by DIP switches.
- Pin configuration compatible with MY Power Relay.
- Conforms to EN 61812-1 and IEC 60664-1 for Low Voltage, and EMC Directives.





For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

Refer to Safety Precautions on page 14.

Ordering Information

List of Models

Specify both the model number and supply voltage when ordering. Example: H3YN-2 DC24

Supply voltage	Time-limit contact	Short-time range model (0.1 s to 10 min)	Long-time range model (0.1 min to 10 h)
24, 100 to 120, 200 to 230 VAC; 12, 24, 48, 100 to 110, 125 VDC	DPDT	H3YN-2	H3YN-21
	4PDT	H3YN-4 *1	H3YN-41 *1
24 VDC	4PDT (Twin contacts)	H3YN-4-Z * 1, * 2	H3YN-41-Z *1, *2

Note: Sockets and Hold-down Clips are not included with the H3YN. They must be ordered separately.

*1. Use the H3YN-4 or H3YN-41 Series when switching micro loads, and use the H3YN-4-Z or H3YN-41-Z Series when switching even smaller loads.

*2. Only models with 24 VDC power supply are available.

Accessories (Order Separately)

Adapter, Mounting Plate, Clip

Name/specification		Model
Flush mounting adapter		Y92F-78
Mounting Plate for Seeket	For 1 Socket	PYP-1
Mounting Plate for Socket	For 18 Sockets	PYP-18
Clip	For PYF A	Y92H-3
Clib	For PY and PYF M	Y92H-4

Note: For details, refer to Precautions for H3Y-series Timers on page 14.

Socket

Timer				Square Sockets			
Contact	Model	Pin	Connection	Terminal	Model		
				DIN track mounting	PYF08A		
DPDT H3YN-		8-pin	Front Connecting	DIN track mounting (Finger-safe type)	PYF08A-E		
	H3YN-2			Screw mounting	PYF08F		
			Back Connecting	Solder terminal	PY08		
				PCB terminal	PY08-02		
				DIN track mounting	PYF14A		
4PDT	H3YN-4□	14-pin	Front Connecting	DIN track mounting (Finger-safe type)	PYF14A-E		
				Solder terminal	PY14		
Back Connectin		Back Connecting	PCB terminal	PY14-02			

Note: 1. Cannot be used with the H3Y- \Box -0 (PCB terminals).

2. The PYF□□A-E has a finger-protection structure. Round crimp terminals cannot be used. Use forked crimp terminals.

^{3.} For details, refer to Precautions for H3Y-series Timers on page 14.

H₃YN

Specifications

Ratings

Item	H3	3YN-2/-4/-4-Z		H3YN-21/-41/-41-Z
Time ranges	0.1 s to 10 min (1 s, 10 s, 1 min, or 10 min max.0.1 min to 10 h (1 min, 10 min, 1 h, or 10 selectable)0.1 s to 10 min (1 s, 10 s, 1 min, or 10 min max.0.1 min to 10 h (1 min, 10 min, 1 h, or 10 selectable)			0.1 min to 10 h (1 min, 10 min, 1 h, or 10 h max. selectable)
Rated supply voltage * 5, * 6	24, 100 to 120, 200 12, 24, 48, 100 to 1	to 230 VAC (5 10, 125 VDC 3	0/60 Hz) ≭ 1 ₽	
Pin type	Plug-in			
Operating mode	ON-delay, interval,	flicker OFF sta	rt, or flicker ON	start (selectable with DIP switch)
Operating voltage range	85% to 110% of rat	ed supply volta	ge (12 VDC: 90	% to 110% of rated supply voltage) * 3
Reset voltage	10% min. of rated supply voltage *4			
Power consumption	100 to 120 VAC: 200 to 230 VAC: 24 VAC: 12 VDC: 24 VDC: 48 VDC: 100 to 110 VDC: 125 VDC:	Relay ON: Relay OFF: Relay OFF:	Approx. 1.8 V/ Approx. 1 VA Approx. 2.2 V/ Approx. 1.5 V/ Approx. 1.5 V/ Approx. 0.3 V/ Approx. 0.1 W Approx. 0.1 W Approx. 0.1 W Approx. 0.1 W Approx. 0.3 W Approx. 0.3 W Approx. 0.3 W Approx. 0.4 W Approx. 0.4 W	A (1.6 W) at 120 VAC, 60 Hz 0.6 W) at 120 VAC, 60 Hz A (1.8 W) at 230 VAC, 60 Hz A (1.1 W) at 230 VAC, 60 Hz A (1.1 W) at 24 VAC, 60 Hz A (0.2 W) at 24 VAC, 60 Hz at 12 VDC at 12 VDC at 24 VDC at 24 VDC at 24 VDC at 48 VDC at 48 VDC at 110 VDC at 110 VDC at 125 VDC
Control outputs	DPDT: 5 A at 250 VAC, resistive load ($\cos\phi = 1$) The minimum applicable load is 1 mA at 5 VDC (P reference value). Contact materials: Ag 4PDT: 3 A at 250 VAC, resistive load ($\cos\phi = 1$) H3YN-4/-41 series: The minimum applicable load is 1 mA at 1 VDC (P reference value). H3YN-4-Z/-41-Z series: The minimum applicable load is 1 mA at 1 VDC (P reference value). H3YN-4-Z/-41-Z series: The minimum applicable load is 1 mA at 1 VDC (P reference value).			⁹ reference value). is 1 mA at 1 VDC (P reference value). oad is 1 mA at 1 VDC (P reference value).
Ambient operating temperature	-10°C to 50°C (with	no icing)		
Storage temperature	-25°C to 65°C			
Ambient operating humidity	35% to 85%			

*1. Do not use the output from an inverter as the power supply. Refer to Safety Precautions for All Timers for details on your OMRON website.
*2. Single-phase, full-wave-rectified power supplies can be used.
*3. When using the H3YN continuously in any place where the ambient temperature is in a range of 45°C to 50°C, supply 90% to 110% of the provide the provided and the provided and

rated supply voltages (supply 95% to 110% with 12 VDC type).

*4. Set the reset voltage as follows to ensure proper resetting. 100 to 120 VAC: 10 VAC max. 200 to 230 VAC: 20 VAC max.

100 to 110 VDC: 10 VDC max.

*5. Refer to Safety Precautions for All Timers on your OMRON website when combining the Timer with an AC 2-wire proximity sensor. *6. A diode to prevent reverse voltages is provided only on models with a DC power supply.

2

Characteristics

Item	H3YN-2/-21/-4/-41			
Accuracy of operating time	±1% FS max. (1 s range: ±1%±10 ms max.)			
Setting error	±10%±50 ms FS max.			
Reset time	Min. power-opening time: 0.1 s max. (including halfway reset)			
Influence of voltage	±2% FS max.			
Influence of temperature	±2% FS max.			
Insulation resistance	100 MΩ min. (at 500 VDC)			
Dielectric strength	 2,000 VAC, 50/60 Hz for 1 min (between current-carrying terminals and exposed non-current-carrying metal parts) *1 2,000 VAC, 50/60 Hz for 1 min (between operating power circuit and control output) 2,000 VAC, 50/60 Hz for 1 min (between different pole contacts; 2-pole model) 1,500 VAC, 50/60 Hz for 1 min (between different pole contacts; 4-pole model) 1,000 VAC, 50/60 Hz for 1 min (between non-continuous contacts) 			
Vibration resistance	Destruction:10 to 55 Hz, 0.75-mm single amplitude for 1 h each in 3 directionsMalfunction:10 to 55 Hz, 0.5-mm single amplitude for 10 min each in 3 directions			
Shock resistance	Destruction: 1,000 m/s ² * 2 Malfunction: 100 m/s ²			
Life expectancy	Mechanical: 10,000,000 operations min. (under no load at 1,800 operations/h) Electrical: DPDT: 500,000 operations min. (5 A at 250 VAC, resistive load at 1,800 operations/h) 4PDT: 200,000 operations min. (H3YN-4-Z/-41-Z: 100,000 operations min.) (3 A at 250 VAC, resistive load at 1,800 operations/h) * 3			
Impulse withstand voltage	Between power terminals: 3 kV for 100 to 120 VAC, 200 to 230 VAC, 100 to 110 VDC, 125 VDC 1 kV for 12 VDC, 24 VDC, 48 VDC, 24 VAC Between exposed non-current-carrying metal parts: 4.5 kV for 100 to 120 VAC, 200 to 230 VAC, 100 to 110 VDC, 125 VDC 1 5 kV for 12 VDC, 24 VDC, 48 VDC, 24 VAC			
Noise immunity	\pm 1.5 kV, square-wave noise by noise simulator (pulse width: 100 ns/1 µs, 1-ns rise)			
Static immunity	Destruction: 8 kV Malfunction: 4 kV			
Degree of protection	IP40			
Weight	Approx. 50 g			
EMC	(EMI) EN 61812-1 Emission Enclosure: EN 55011 Group 1 class A Emission AC Mains: EN 55011 Group 1 class A (EMS) EN 61812-1 Immunity ESD: IEC 61000-4-2 Immunity RF-interference: IEC 61000-4-3 Immunity Burst: IEC 61000-4-4 Immunity Surge: IEC 61000-4-5 Immunity Conducted Disturbance: IEC 61000-4-6 Immunity Voltage Dip/Interruption: IEC 61000-4-11			
Approved standards	UL 508, CSA C22.2 No. 14, Lloyds, CCC Conforms to EN 61812-1 and IEC 60664-1. (2.5 kV/2 for H3YN-2/-21, 2.5 kV/1 for H3YN-4/-41, H3YN-4-Z/-41-Z) * 4			

*1. Terminal screw sections are excluded.
*2. The destructive shock resistance test was performed on the Timer.
*3. Refer to the *Life-test Curve.**4. Overvoltage category II.

Life-test Curve (Reference Value)

H3YN-2/-21





The minimum applicable load is 1 mA at 5 VDC (P reference value)













Load current (A)

 $\begin{array}{rl} \mbox{Reference:} & \underline{A\mbox{ maximum current of } 0.5\mbox{ A can be switched at 125 VDC (} \cos\phi = 1\mbox{)}. \\ & \mbox{Maximum current of } 0.2\mbox{ A can be switched if } L/R is 7\mbox{ ms. In both cases, a life of 100,000 operations can be expected.} \\ & \mbox{The minimum applicable load is } 0.1\mbox{ mA at 1 VDC (P reference value).} \end{array}$

Connections

Connection

H3YN-2/-21



(Bottom View)

Pulse Operation

A pulse output for a certain period can be obtained with a random external input signal. Use the H3YN in interval mode as shown in the following timing charts.

12

5

Ŷ

H3YN-2/-21



H3YN-4/-41 H3YN-4-Z/-41-Z



Power (9-14)
External short circu (5-13)
External input (9-13)
Time limit contact NO (12-8)
Time limit contact NC (12-4)
Run/Power indicato (PW) Output indicator (UI

min.		
_	_	

H3YN-4/-41 H3YN-4-Z/-41-Z

> 10 $\overline{1}$

Timer circuit

₩₩

VP PW

(Bottom View)

5

13

 (\sim)

Note: t: Set time Rt: Reset time

Power (9-14) External short circuit (5-13) External input (9-13) Time limit contact NO (10-6, 11-7, 12-8) Time limit contact NC (10-2, 11-3, 12-4) Run/Power indicator (PW) Output indicator (UP)

- t	Rt	-t	t - t-	-
			1	
E0 mo			1	_
min.				
	-		-	

Note: t: Set time Reset time Rt:

— ∕ ∩ Caution	
Be careful when	connecting wires.

Mode	Terminals
Pulse operation	Power supply between 9 and 14 Short-circuit between 5 and 13 Input signal between 9 and 13
Operating mode; interval and all other modes	Power supply between 13 and 14

DIN Notation

8

12

14

(+) (~)

Rt



H₃YN Nomenclature

Output Indicator (Orange) (Lit: Output ON)

Main Dial



Run/Power Indicator (Green) (Lit: Power ON)

Set the desired time according to time range selectable by DIP switch.

Dimensions

(Unit: mm)

4.1

ł

Timers H3YN-2/-21 Front Mounting





H3YN-4/-41 Front Mounting H3YN-4-Z/-41-Z





Operation

DIP Switch Settings

The 1-s range and ON-delay mode for H3YN-2/-4/-4-Z, the 1-min range and ON-delay mode for H3YN-21/-41/-41-Z are factory-set before shipping.

Time Ranges

Model	Time range	Time setting range	Setting	Factory-set
H3YN-2, H3YN-4 H3YN-4-Z	1 s	0.1 to 1 s		Yes
	10 s	1 to 10 s		No
	1 min	0.1 to 1 min		No
	10 min	1 to 10 min		No
H3YN-21, H3YN-41 H3YN-41-Z	1 min	0.1 to 1 min		Yes
	10 min	1 to 10 min		No
	1 h	0.1 to 1 h		No
	10 h	1 to 10 h		No

Note: The top two DIP switch pins are used to select the time ranges.

Operating Modes

Operating mode	Setting	Factory-set
		,
ON-delay		Yes
Interval		No
Flicker OFF-start		No
Flicker ON-start		No



Note: The bottom two DIP switch pins are used to select the operating mode.

H3YN

Operating mode	Timing chart		
Operating mode	H3YN-2/-21	H3YN-4/-41	
ON-delay Powert	Power (13-14) Time limit contact NC (9-1, 12-4) Time limit contact NO (9-5, 12-8) Run/Power indicator (PW) Output indicator	Power (13-14) Time limit contact NC (9-1, 10-2, 11-3, 12-4) Time limit contact NO (9-5, 10-6, 11-7, 12-8) Run/Power indicator (PW) Output indicator (UP)	
Power	Power (13-14) Time limit contact NC (9-1, 12-4) Time limit contact NO (9-5, 12-8) Run/Power indicator (PW) Output indicator (UP)	Power (13-14) Time limit contact NC (9-1, 10-2, 11-3, 12-4) Time limit contact NO (9-5, 10-6, 11-7, 12-8) Run/Power indicator (PW) Output indicator (UP)	
Flicker OFF-start	Power (13-14) Time limit contact NC (9-1, 12-4) Time limit contact NO (9-5, 12-8) Run/Power indicator (PW) Output indicator (UP)	Power (13-14) Time limit contact NC (9-1, 10-2, 11-3, 12-4) Time limit contact NO (9-5, 10-6, 11-7, 12-8) Run/Power indicator (PW) Output indicator (UP)	
Flicker ON-start	Power (13-14) Time limit contact NC (9-1, 12-4) Time limit contact NO (9-5, 12-8) Run/Power indicator (PW) Output indicator	Power (13-14) Time limit contact NC (9-1, 10-2, 11-3, 12-4) Time limit contact NO (9-5, 10-6, 11-7, 12-8) Run/Power indicator (PW) Output indicator (UP)	

Note: t: Set time Rt: Reset time

Precautions for H3Y-series Timers

Flush Mounting Adapter

Y92F-78



Note: 1. Push the H3Y in until the Adaptor (Y92F-78) hooks engage with its rear panel.
2. Do not round the corners of the cutout on the rear panel surface, otherwise the Adaptor (Y92F-78) tabs may not engage properly.

Mounting Height

PYF08A/PYF08A-N/PYF08A-E (PYF14A/PYF14A-N/PYF14A-E *1)





PY08 (PY14 *1)

PY08QN (PY14QN *1)



PYF08A (PYF14A)

*1. Models in parentheses are Connecting Sockets to the H3YN-4/-41 or H3YN-4-Z/-41-Z.

Connecting Sockets (Sold Separately)

H3Y/H3YN Series

Use one of the following Connecting Sockets: PYF_A, PYF_M, PY_, PY_-02, or PY_QN(2)(-Y3).(= 08 or 14)

Accessories (Order Separately)

Use the PYF A, PY , PY -02, or PY QN(2) to mount the H3Y/H3YN. When ordering any one of these sockets, replace " \Box " with "08" or "14."

Socket Mounting Plates (t = 1.6)

Use a Socket Mounting Plate to mount multiple Connecting Sockets in a row.

Applicable socket	For mounting 1 socket	For mounting 18 sockets
PY08, PY14, PY08QN(2), PY14QN(2)	PYP-1	PYP-18

Note: PYP-18 may be cut to any desired length.

PYP-1



Relay Hold-down Clips

The Hold-down Clip makes it possible to mount the H3YN securely and prevent the H3YN from falling out due to vibration or shock.

Note: When you attach the Hold-down Clip to or remove it from the Socket, take sufficient precautions to not injury your fingers, such as wearing gloves.

Y92H-3 Y92H-4 H3Y/H3YN Series for PYFDA Socket Y92H-3 (Set of Two Clips)





Y92H-4 for PY Socket



H3Y/H3YN Series Track Mounting/Front Connecting Sockets

PYF08A



H3Y Series



H3Y/H3YN Series Back Connecting Sockets

PY08, PY14



PY08QN, PY14QN PY08QN(2), PY14QN(2)



Note: With PY QN(2), dimension * should read 20 max. and dimension ** 36.5 max.

PY08-02, PY14-02



Terminal Arrangement (Bottom View)

0	0	00	00
6	8	00	00
9	Ð	90	00
®	0	€	ø
P۱	/08	PY14	

Terminal Arrangement (Bottom View)

0	0	00	00
0	8	66	08
0	Ð	00	ÐØ
₿	Ø	₿	ø
PY08QN PY08QN(2)		PY14 PY14	

Terminal Arrangement

0	0	00	80
6	0	00	00
0	Ð	90	00
•	Ø	€	Ø
PY08	-02	PY14-	02

Panel Cutout





PY□, PY□-02, PY□QN(2)

Mounting Track PFP-100N/PFP-50N (see note 1)



24 27±0.15 35±0.3

PFP-M

Note: 1. Meets DIN EN50022

2. This dimension applies to PFP-50N.

Spacer PFP-S

1





Safety Precautions

Be sure to read precautions for all models in the website at the following URL: http://www.omron247.com/.

Warning Indications

	Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury or in property damage.
Precautions for Safe Use	Supplementary comments on what to do or avoid doing, to use the product safely.
Precautions for Correct Use	Supplementary comments on what to do or avoid doing, to prevent failure to operate, malfunction or undesirable effect on product performance.

Meaning of Product Safety Symbols

\bigcirc	Used for general prohibitions for which there is no specific symbol.	
	Use to indicate prohibitions when there is a risk of minor injury from electrical shock or other source if the product is disassembled.	
0	Used for general mandatory action precautions for which there is no specified symbol.	
🗥 CAUTION		

Risk of fire and explosion due to arcing and relay heat generation that accompanies switching. Do not use in an environment where flammable or explosive gas is present.



The service life of the output relay varies widely depending on switching capacity and switching conditions. Use only within the rated load and electrical life count, based on actual conditions of use. Risk of contact sticking and burning if used past the service

life. Always use a load current that does not exceed the rating, and if a heater is used, use a thermal switch in the load circuit.

Do not remove the outer casing.



In rare circumstances there is a risk of slight electrical shock, fire, or device damage. Do not disassemble, modify, repair, or otherwise touch the inside.



Tighten the screws for the lead wires to the Socket to the following torque.

PYF Socket: 0.78 to 1.18 N·m

This is the recommended range when crimp terminals are used.

If the screws are not tightened sufficiently on Front-connecting Sockets, the lead wires may come off, connection failure may cause abnormal heating, or fires may occur.

If they are tightened excessively, the screw threads may be damaged.

Precautions for Safe Use

Confirm that the setting dial, indicators and plastic parts are operating normally. Depending on the operating environment, the setting dial, indicators and plastic parts may deteriorate faster than expected, causing the indicators to fail. Periodically perform inspections and replacements.

We recommend that you use a surge absorber if surge voltages may occur. When you dispose of the Timer, do so according to all local ordinances for processing industrial waste.

Precautions for Correct Use

- When selecting a control output, use the H3Y-2/H3YN-2/H3Y-2-B/ H3YN-2-B for switching ON and OFF the power and the H3Y-4/ H3YN-4/H3Y-4-B/H3YN-4-B for switching ON and OFF the minute load. Gold-plated relays are used in the H3Y-4, H3YN-4, H3Y-4-B, H3YN-4-B, H3YN-4-Z, H3YN-41-Z, H3YN-4-Z-B, and H3YN-41-Z-B Series.
- Connect the power supply between terminals A1 (13) and A2 (14). For a DC power supply, connect the negative side to A1 (13) and the positive side to A2 (14).
- The operating voltage will increase when using the H3Y/H3YN/ H3Y-B/H3YN-B in any place where the ambient temperature is more than 50°C. Supply 90% to 110% of the rated voltages (at 12 VDC: 95% to 110%) when operating at 45°C or higher.
- Do not leave the H3Y/H3YN/H3Y-B/H3YN-B in time-up condition for a long period of time (for example, more than one month in any place where the ambient temperature is high), otherwise the internal parts (aluminum electrolytic capacitor) may become damaged. Therefore, the use of the H3Y/H3YN/H3Y-B/H3YN-B with a relay as shown in the following circuit diagram is recommended to extend the service life of the H3Y/H3YN/H3Y-B/ H3YN-B.



(X): Auxiliary relay such as MY Relay

- The H3YN/H3YN-B must be disconnected from the Socket when setting the DIP switch, otherwise the user may touch a terminal imposed with a high voltage and get an electric shock.
- Do not connect the H3Y/H3YN/H3Y-B/H3YN-B as shown in the following circuit diagram on the right hand side, otherwise the H3Y's/H3YN's/H3Y-B's/H3YN-B's internal contacts different from each other in polarity may become short-circuited.



 Use the following safety circuit when building a self-holding or selfresetting circuit with the H3Y/H3YN/H3Y-B/H3YN-B and an auxiliary relay, such as an MY Relay, in combination.



- In the case of the above circuit, the H3YN will be in pulse operation. Therefore, if the circuit shown on page 13 is used, no auxiliary relay will be required.
- Do not set to the minimum setting in the flicker modes, otherwise the contact may become damaged.
- Be careful not to apply any voltage to the terminal screws on the back of the Timer. Mount the product so that the screws will not come in contact with the panel or metal parts.
- Do not use the H3Y/H3YN/H3Y-B/H3YN-B in places where there is excessive dust, corrosive gas, or direct sunlight.
- Do not mount more than one H3Y/H3YN/H3Y-B/H3YN-B closely together, otherwise the internal parts may become damaged. Make sure that there is a space of 5 mm or more between any H3Y/ H3YN/H3Y-B/H3YN-B Models next to each other to allow heat radiation.
- The internal parts may become damaged if a supply voltage other than the rated ones is imposed on the H3Y/H3YN/H3Y-B/H3YN-B. When more than 100 V is applied to 12 or 24 VDC models, the internal element (varistor) may break.

Precautions for EN 61812-1 Conformance

The H3Y/H3YN/H3Y-B/H3YN-B as a built-in timer conforms to EN 61812-1 provided that the following conditions are satisfied.

Handling

- Do not touch the DIP switch while power is supplied to the H3YN/ H3YN-B.
- Before dismounting the H3YN/H3YN-B from the Socket, make sure that no voltage is imposed on any terminal of the H3YN/ H3YN-B.
- The applicable Socket is the PYFDA (H3Y/H3YN).
- Only basic insulation is ensured between the Y92H-3 Hold-down Clips and H3Y/H3YN/H3Y-B/H3YN-B internal circuits.
- Do not allow the Y92H-3 Hold-down Clips to contact other parts.
- The insulation test voltage between different pole contacts for the 4-pole model is the impulse voltage of 2.95 kV.

Wiring

- The power supply for the H3Y/H3YN/H3Y-B/H3YN-B must be protected with equipment such as a breaker approved by VDE.
- Basic insulation is ensured between the H3Y's/H3YN's/H3Y-B's/ H3YN-B's operating circuit and control output.
- Insulation requirement:

Overvoltage category II,

pollution degree 1 (H3Y-4/-4-0/-4-B, H3YN-4/41/-4-B/-41-B, H3YN-4-Z/-41-Z/-4-Z-B/-41-Z-B),

pollution degree 2 (H3Y-2/-2-0/-2-B, H3YN-2/21/-2-B/-21-B) (with a clearance of 1.5 mm and a creepage distance of 2.5 mm at 240 VAC)

• Output terminals next to each other on the H3Y-4 or H3Y-4-0 must have the same polarity.

- In order to conform to UL and CSA requirements when using the H3Y-4/-4-0/-4-B, H3YN-4/-41/-4-B/-41-B, or H3YN-4-Z/-41-Z/ -4-Z-B/-41-ZB, connect the Unit so that output contacts (contacts of different poles) have the same electric potential.
- In cases such as PLC input where the load is extremely small for the control output of a timer containing a power relay (using other than gold-plated contacts), reliability can be increased by using contacts of the same poles (e.g., the H3Y-2) in parallel.
- Always use the same type of wire.
- Installation
 - There are no restrictions on the installation orientation. Install the Timer securely.

Recommended Replacement Periods and Periodic Replacement as Preventive Maintenance

The recommended replacement period for preventive maintenance is greatly influenced by the application environment of the product. As a guideline for models that do not have a Maintenance Forecast Monitor, the recommended replacement period is 7 to 10 years.* To prevent failures that can be caused by using a product beyond its service live, we recommend that you replace the product as early as possible within the recommended replacement period. However, realize that the recommended replacement period is for reference only and does not guarantee the life of the product.

Many electronic components are used in the product and the product depends on the correct operation of these components to achieve product functions and performance. However, the influence of the ambient temperature on aluminum electrolytic capacitors is large, and the service life is reduced by half for each 10°C rise in temperature (Arrhenius law). When the capacity reduction life of the electrolytic capacitor is reached, the product may fail. We therefore recommend that you replace the product periodically to minimize product failures in advance.

* The following conditions apply: rated input voltage, load rate of 50% max., ambient temperature of 35°C max., and the standalone mounting method.

This product model is designed with a service life of 10 years minimum under the above conditions.

МЕМО

Terms and Conditions of Sale

- 1. Offer; Acceptance. These terms and conditions (these "Terms") are deemed part of all quotes, agreements, purchase orders, acknowledgments, price lists, catalogs, manuals, brochures and other documents, whether electronic or in catalogs, manuals, brochures and other documents, whether electronic or in writing, relating to the sale of products or services (collectively, the "Products") by Omron Electronics LLC and its subsidiary companies ("<u>Omron</u>"). Omron objects to any terms or conditions proposed in Buyer's purchase order or other documents which are inconsistent with, or in addition to, these Terms. <u>Prices: Payment Terms</u>. All prices stated are current, subject to change without notice by Omron. Omron reserves the right to increase or decrease prices on any unshipped portions of outstanding orders. Payments for Products are due net 30 days unless otherwise stated in the invoice. <u>Discounts</u>. Cash discounts, if any, will apply only on the net amount of invoices sent to Buyer after deducting transportation charges, taxes and duties, and will be allowed only if (i) the invoice is paid according to Omron's payment terms and (ii) Buyer has no past due amounts.
- 2
- 3.
- and (ii) Buyer has no past due amounts. Interest. Omron, at its option, may charge Buyer 1-1/2% interest per month or the maximum legal rate, whichever is less, on any balance not paid within the stated terms.
- Orders. Omron will accept no order less than \$200 net billing. Governmental Approvals. Buyer shall be responsible for, and shall bear all 6 costs involved in, obtaining any government approvals required for the impor-tation or sale of the Products.
- Taxes. All taxes, duties and other governmental charges (other than general real property and income taxes), including any interest or penalties thereon, imposed directly or indirectly on Omron or required to be collected directly or 7. indirectly by Omron for the manufacture, production, sale, delivery, importa-tion, consumption or use of the Products sold hereunder (including customs
- tion, consumption or use of the Products sold hereunder (including customs duties and sales, excise, use, turnover and license taxes) shall be charged to and remitted by Buyer to Omron. <u>Financial.</u> If the financial position of Buyer at any time becomes unsatisfactory to Omron, Omron reserves the right to stop shipments or require satisfactory security or payment in advance. If Buyer fails to make payment or otherwise comply with these Terms or any related agreement, Omron may (without liabil-ity and in addition to other remedies) cancel any unshipped portion of Prod-ucts sold hereunder and stop any Products in transit until Buyer pays all amounts, including amounts payable hereunder, whether or not then due, which are owing to it by Buyer Buyer shall in any event remain liable for all 8. which are owing to it by Buyer. Buyer shall in any event remain liable for all unpaid accounts
- <u>Cancellation</u>; <u>Etc.</u> Orders are not subject to rescheduling or cancellation unless Buyer indemnifies Omron against all related costs or expenses.
 <u>Force Majeure</u>. Omron shall not be liable for any delay or failure in delivery
- resulting from causes beyond its control, including earthquakes, fires, floods strikes or other labor disputes, shortage of labor or materials, accidents to machinery, acts of sabotage, riots, delay in or lack of transportation or the requirements of any government authority.
 <u>Shipping: Delivery.</u> Unless otherwise expressly agreed in writing by Omron: a. Shipments shall be by a carrier selected by Omron; Omron will not drop ship contain in the data in strike data.
- except in "break down" situations. b. Such carrier shall act as the agent of Buyer and delivery to such carrier shall
 - constitute delivery to Buyer;
- c. All sales and shipments of Products shall be FOB shipping point (unless othc. All sales and shipments of Products shall be FOB shipping point (unless otherwise stated in writing by Omron), at which point title and risk of loss shall pass from Omron to Buyer; provided that Omron shall retain a security interest in the Products until the full purchase price is paid;
 d. Delivery and shipping dates are estimates only; and
 e. Omron will package Products as it deems proper for protection against normal handling and extra charges apply to special conditions.
 12. <u>Claims</u>. Any claim by Buyer against Omron for shortage or damage to the Products occurring before delivery to the carrier must be presented in writing to Omron within 30 days of receipt of shipment and include the original transportation bill signed by the carrier routing the Products
- portation bill signed by the carrier noting that the carrier received the Products from Omron in the condition claimed.
- <u>Warranties</u> (a) <u>Exclusive Warranty</u>. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed 13. (b) <u>Limitations</u>. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABIL-

Certain Precautions on Specifications and Use

- 1. Suitability of Use. Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide application to use or the Product. At Buyer's request, and applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Prod-uct in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. The particular Product with respect to Buyers application, product or system. Buyer shall take application responsibility in all cases but the following is a non-exhaustive list of applications for which particular attention must be given: (i) Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this document. (ii) Use in consumer products or any use in significant quantities. (iii) Energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equip-ment and installations ubiot to construct industry or any organization

whent, and installations subject to separate industry or government regulations. (iv) Systems, machines and equipment that could present a risk to life or prop-erty. Please know and observe all prohibitions of use applicable to this Prod-

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO

ITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or oth-erwise of any intellectual property right. (c) <u>Buyer Remedy</u>. Omron's sole obli-gation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsi-ble for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were prop-erly handled, stored, installed and maintained and not subject to contaminaerly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Compa-nies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty. See http://www.omron247.com or contact your Omron representative for published information.

- lished information. Limitation on Liability: Etc. OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY. Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted. 14
- Indemnities. Buyer shall indemnify and hold harmless Omron Companies and their employees from and against all liabilities, losses, claims, costs and expenses (including attorney's fees and expenses) related to any claim, investigation, litigation or proceeding (whether or not Omron is a party) which arises 15
- tigation, litigation or proceeding (whether or not Omron is a party) which arises or is alleged to arise from Buyer's acts or omissions under these Terms or in any way with respect to the Products. Without limiting the foregoing, Buyer (at its own expense) shall indemnify and hold harmless Omron and defend or set-tle any action brought against such Companies to the extent based on a claim that any Product made to Buyer specifications infringed intellectual property rights of another party. <u>Property: Confidentiality.</u> Any intellectual property in the Products is the exclu-sive property of Omron Companies and Buyer shall not attempt to duplicate it in any way without the written permission of Omron. Notwithstanding any charges to Buyer for engineering or tooling, all engineering and tooling shall premain the exclusive property of Omron. All information and materials supplied by Omron to Buyer relating to the Products are confidential and proprietary, and Buyer shall limit distribution thereof to its trusted employees and strictly prevent disclosure to any third party. 16.
- prevent disclosure to any third party. <u>Export Controls.</u> Buyer shall comply with all applicable laws, regulations and licenses regarding (i) export of products or information; (iii) sale of products to "forbidden" or other proscribed persons; and (ii) disclosure to non-citizens of mendetation between the product for a state of the state
- "forbidden" or other proscribed persons; and (ii) disclosure to non-citizens of regulated technology or information. <u>Miscellaneous</u>. (a) <u>Waiver</u>. No failure or delay by Omron in exercising any right and no course of dealing between Buyer and Omron shall operate as a waiver of rights by Omron. (b) <u>Assignment</u>. Buyer may not assign its rights hereunder without Omron's written consent. (c) <u>Law</u>. These Terms are governed by the law of the jurisdiction of the home office of the Omron company from which Buyer is purchasing the Products (without regard to conflict of law principles). (d) <u>Amendment</u>. These Terms constitute the entire agreement between Buyer and Omron relating to the Products, and no provision may be changed or waived unless in writing signed by the parties. (e) Severability. If any provi-18. or waived unless in writing signed by the parties. (e) <u>Severability</u>. If any provi-sion hereof is rendered ineffective or invalid, such provision shall not invalidate any other provision. (f) <u>Setoff</u>. Buyer shall have no right to set off any amounts against the amount owing in respect of this invoice. (g) <u>Definitions</u>. As used herein, "including" means "including without limitation"; and "<u>Omron Compa</u>nies" (or similar words) mean Omron Corporation and any direct or indirect subsidiary or affiliate thereof.

ADDRESS THE RISKS, AND THAT THE OMRON'S PRODUCT IS PROP-ERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

- Programmable Products. Onron Companies shall not be responsible for the user's programmable Products. Onron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof. <u>Performance Data</u>. Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitabil-ity and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application require-2 3 ments. Actual performance is subject to the Omron's Warranty and Limitations of Liability.
- Change in Specifications. Product specifications and accessories may be 4 changed at any time based on improvements and other reasons. It is our prac-tice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifica-tions of the Product may be changed without any notice. When in doubt, spe-cial part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product. Errors and Omissions. Information presented by Omron Companies has been
- 5 checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.



OMRON AUTOMATION AMERICAS HEADQUARTERS • Chicago, IL USA • 847.843.7900 • 800.556.6766 • www.omron247.com

OMRON CANADA, INC. • HEAD OFFICE Toronto, ON, Canada • 416.286.6465 • 866.986.6766 • www.omron247.com

OMRON ELECTRONICS DE MEXICO • HEAD OFFICE México DF • 52.55.59.01.43.00 • 01-800-226-6766 • mela@omron.com

OMRON ELECTRONICS DE MEXICO • SALES OFFICE Apodaca, N.L. • 52.81.11.56.99.20 • 01-800-226-6766 • mela@omron.com

OMRON ELETRÔNICA DO BRASIL LTDA • HEAD OFFICE São Paulo, SP, Brasil • 55.11.2101.6300 • www.omron.com.br OMRON ARGENTINA • SALES OFFICE Cono Sur • 54.11.4783.5300

OMRON CHILE • SALES OFFICE Santiago • 56.9.9917.3920

OTHER OMRON LATIN AMERICA SALES 54.11.4783.5300

OMRON EUROPE B.V. • Wegalaan 67-69, NL-2132 JD, Hoofddorp, The Netherlands. • +31 (0) 23 568 13 00 • www.industrial.omron.eu

Authorized Distributor:

Controllers & I/O

- Machine Automation Controllers (MAC)
 Motion Controllers
- Programmable Logic Controllers (PLC)
 Temperature Controllers
 Remote I/O

Robotics

Industrial Robots
 Mobile Robots

Operator Interfaces

• Human Machine Interface (HMI)

Motion & Drives

- Machine Automation Controllers (MAC)
 Motion Controllers
 Servo Systems
- Frequency Inverters
- Vision, Measurement & Identification
- Vision Sensors & Systems Measurement Sensors Auto Identification Systems

Sensing

- Photoelectric Sensors Fiber-Optic Sensors Proximity Sensors
- Rotary Encoders
 Ultrasonic Sensors

Safety

- Safety Light Curtains
 Safety Laser Scanners
 Programmable Safety Systems
- Safety Mats and Edges
 Safety Door Switches
 Emergency Stop Devices
- Safety Switches & Operator Controls Safety Monitoring/Force-guided Relays

Control Components

- Power Supplies
 Timers
 Counters
 Programmable Relays
- Digital Panel Meters
 Monitoring Products

Switches & Relays

Limit Switches • Pushbutton Switches • Electromechanical Relays
 Solid State Relays

Software

Programming & Configuration • Runtime

X-ON Electronics

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Timers category:

Click to view products by Omron manufacturer:

Other Similar products are found below :

 79237785
 H5AN-4DM DC12-24
 H5CN-YAN AC100-240
 H5CX-L8S-N AC100-240
 H5AN-4D DC12-24
 THR2U-110A
 81506944

 88225029
 H5S-YB4-X
 H7AN-2D DC12-24
 H5CN-XANS DC12-48
 H7AN-W4DM DC12-24
 H7AN-4DM DC12-24
 H7AN-4D DC12-24

 H7AN-RT6M AC100-240
 600DT-CU
 7PV1513-1AP30
 7PV1538-1AW30
 1SVR508100R0000
 1SVR550127R4100
 1SVR550212R4100

 1SVR730010R3200
 1SVR730020R3300
 1SVR730120R3100
 1SVR730180R3100
 1SVR730211R2300
 PCU-5111UNI
 H3C-R
 H3CR-A8-301

 24-48AC/12-48DC
 H3CR-A8E 24-48AC/DC
 H3CR-F8
 100-240AC/100-125DC
 H3CR-FN
 100-240AC/100-125DC
 H3DK-G
 24-230AC/DC

 H3DK-HBL AC/DC24-48
 H3DK-M1A DC12
 LT4H-AC24V
 LT4HW8-AC240V
 LT4HW-AC24VS
 31L48AP

 31L48TPM240
 RC302
 RC312
 REV-201M
 RG
 AT78051
 ATC180041
 TMM1
 TMP