

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



The figure shows a 7-position

Panel feed-through terminal block, connection method: Screw connection with tension sleeve, Cable lug connection, number of positions: 1, load current: 101 A, cross section: 6 mm² - 35 mm², connection direction of the conductor to plug-in direction: -90 °, width: 15.1 mm, color: gray

#### Your advantages

version

- $\overline{\mathbf{v}}$ Both terminal halves can be easily assembled by simply snapping them together
- Touch-proof insulating housing in a new design
- Molded versions ensure maximum tightness of seal
- Spacer plates increase clearances and creepage distances
- $\checkmark$ Automatic compensation of the panel thickness via the snap principle integrated in the insulation housing
- Universal screw connection with screw locking
- ✓ Well-known connection principle allows worldwide use
- Tool-free snap-in principle enables easy mounting on the device panel
- ✓ Automatic panel thickness compensation enables universal use
- Reliable seal even with low-viscosity molding compounds



# **Key Commercial Data**

Packing unit	25 pc
Minimum order quantity	25 pc
GTIN	4 0 4 6 3 5 6 3 4 4 8 0 7
GTIN	4046356344807

#### Technical data

### Item properties

Brief article description	Panel feed-through terminal block
Range of articles	UWV 25-POT



# Technical data

#### Item properties

Pitch	15.1 mm
Number of positions	1
Connection method	Screw connection with tension sleeve
Number of connections	2
Number of potentials	1

#### Electrical parameters

Nominal current	101 A
Nom. voltage	630 V
Rated voltage	630 V
Rated surge voltage (III/3)	6 kV

# Connection capacity, external

Connection method	Screw connection with tension sleeve
Connection direction of the conductor to plug-in direction	-90 °
Conductor cross section solid	6 mm² 35 mm²
Conductor cross section flexible	10 mm² 25 mm²
Conductor cross section flexible, with ferrule without plastic sleeve	4 mm² 25 mm²
Conductor cross section, flexible, with ferrule, with plastic sleeve	4 mm² 25 mm²
2 conductors with same cross section, solid	2.5 mm² 10 mm²
2 conductors with same cross section, flexible	4 mm² 10 mm²
2 conductors with same cross section, flexible, with ferrule without plastic sleeve	2.5 mm² 10 mm²
2 conductors with the same cross section, flexible, with TWIN ferrule with plastic sleeve	2.5 mm² 10 mm²
Internal cylindrical gage	B7
Stripping length	19 mm
Torque	4 Nm 4.5 Nm

# Connection capacity, internal

Connection method	Cable lug connection
Connection direction of the conductor to plug-in direction	0 °

#### Material data - contact

Note	WEEE/RoHS-compliant, free of whiskers according to IEC 60068-2-82/ JEDEC JESD 201
Contact material	Cu alloy
Surface characteristics	tin-plated

# Material data - housing

Housing color	gray (7042)
Insulating material	PA
Insulating material group	I
CTI according to IEC 60112	600



# Technical data

#### Material data - housing

Flammability rating according to UL 94	V0
Glow wire flammability index GWFI according to EN 60695-2-12	850
Glow wire ignition temperature GWIT according to EN 60695-2-13	775
Temperature for the ball pressure test according to EN 60695-10-2	125 °C

#### Dimensions for the product

Width [w]	15.1 mm
Pitch	15.1 mm

### Dimensions for mounting cutout

Plate thickness	1 mm 6 mm
-----------------	-----------

#### Packaging information

Pieces per package	25
Denomination packing units	Pcs.

#### General product information

Type of note	Notes on safety
	Note on application
Note	The cable entry funnel is not touch-proof. Never connect or disconnect the terminal when it is energized. Take appropriate steps to ensure touch proofness.
	To maintain the nominal voltage, align the cable lugs straight and centered, and cast the terminals on the inside.

#### Termination and connection method

Test for conductor damage and slackening	IEC 60947-7-1:2009-04
	Test passed

#### Pull-out test

Pull-out test	IEC 60947-7-1:2009-04
	Test passed
Conductor cross section / conductor type / tensile force	6 mm² / solid / > 80 N
	10 mm² / flexible / > 90 N
	35 mm² / stranded / > 190 N
	25 mm² / flexible / > 135 N

# Mechanical tests according to standard

Test specification	IEC 60947-7-1 (following)

#### Electrical tests

Rated current	101 A
Conductor cross section	25 mm²

# Air clearances and creepage distances

Clearances and creepage distances	Internal part not molded with spacer plate IEC 60947-7-1:2009-04
Application	Internal part not molded



# Technical data

# Air clearances and creepage distances

	with spacer plate
Specification	IEC 60947-7-1:2009-04
Minimum clearance - inhomogeneous field (III/3)	5.5 mm
Minimum creepage distance value (III/3)	8 mm

#### Temperature-rise test

Specification	IEC 60947-7-1:2009-04
Result	Test passed
Requirement temperature-rise test	Increase in temperature ≤ 45 K

# Standards and Regulations

Connection in acc. with standard	UL
	IEC 60947-7-1
Flammability rating according to UL 94	V0
Safety note	WARNING: Only electrically qualified personnel may install and operate the product. They must observe the following safety notes. The qualified personnel must be familiar with the basics of electrical engineering. They must be able to recognize and prevent danger. The relevant symbol on the packaging indicates that only personnel familiar with electrical engineering are allowed to install and operate the product.
	The installation notes/Design In documents online on the download page at phoenixcontact.com/products must be observed for this product.
	The cable entry funnel is not safe to touch. Never connect or disconnect the terminal when it is energized. Take appropriate steps to ensure touch protection.
	To maintain the nominal voltage, align the cable lugs straight and centered, and cast the terminals on the inside.

#### Glow-wire test

Specification	IEC 60695-2-11:2000-10
Result	Test passed
Temperature	960 °C
Time of exposure	30 s

#### Needle flame test

Specification	IEC 60947-7-1:2009-04
Result	Test passed
Time of exposure	30 s


# **Environmental Product Compliance**

China RoHS	Environmentally friendly use period: unlimited = EFUP-e
	No hazardous substances above threshold values

# Drawings




# Dimensional drawing



- \* Only when using the UW...-F flange plate
  \*\* Dimensions when using the DP-UW... spacer plate

#### Dimensional drawing



# Classifications

# eCl@ss

eCl@ss 10.0.1	27141134
eCl@ss 4.0	27141100



# Classifications

# eCl@ss

eCl@ss 4.1	27141100
eCl@ss 5.0	27141100
eCl@ss 5.1	27141100
eCl@ss 6.0	27141100
eCl@ss 7.0	27141134
eCl@ss 8.0	27141134
eCl@ss 9.0	27141134

#### **ETIM**

ETIM 2.0	EC001283
ETIM 3.0	EC001283
ETIM 4.0	EC001283
ETIM 5.0	EC001283
ETIM 6.0	EC001283
ETIM 7.0	EC001283

#### **UNSPSC**

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410
UNSPSC 18.0	39121410
UNSPSC 19.0	39121410
UNSPSC 20.0	39121410
UNSPSC 21.0	39121410

# **Approvals**

Approvals

Approvals

EAC / cULus Recognized

Ex Approvals

Approval details



# Approvals

EAC **EAC** B.01687

cULus Recognized CFU us	http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm E60425-20100423	
	В	С
Nominal voltage UN	600 V	600 V
Nominal current IN	112.5 A	112.5 A
mm²/AWG/kcmil	10-2	10-2

#### Accessories

#### Accessories

#### Mounting material

Sealing plate - POT-UW 25 - 3074075



Mounting material, number of positions: 0, color: gray

#### Screwdriver tools

Screwdriver - SZS 1,0X6,5 VDE - 1205079



Screwdriver, slot-headed, VDE insulated, size: 1.0 x 6.5 x 150 mm, 2-component grip, with non-slip grip

#### Terminal marking

Zack marker strip - ZB 15:UNBEDRUCKT - 0811972



Zack marker strip, Strip, white, unlabeled, can be labeled with: PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into tall marker groove, for terminal block width: 15.2 mm, lettering field size: 10.5 x 15.1 mm, Number of individual labels: 5



#### Accessories

Zack Marker strip, flat - ZBF 15:UNBEDRUCKT - 0811202



Zack Marker strip, flat, Strip, white, unlabeled, can be labeled with: PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into flat marker groove, for terminal block width: 15 mm, lettering field size: 15 x 5.2 mm, Number of individual labels: 5

Marker for terminal blocks - TMT 100 R - 0816605



Marker for terminal blocks, Roll, white, unlabeled, can be labeled with: THERMOMARK ROLL 2.0, THERMOMARK ROLL, THERMOMARK ROLL X1, THERMOMARK ROLLMASTER 300/600, THERMOMARK X1.2, THERMOMARK S1.1, unperforated, mounting type: snap into universal marker groove, snap into flat marker groove, for terminal block width: 100 mm, lettering field size: 6.35 x 101.5 mm, Number of individual labels: 1000

Marker for terminal blocks - TMT (EX9,5)R - 0828295



Marker for terminal blocks, Roll, white, unlabeled, can be labeled with: THERMOMARK ROLL 2.0, THERMOMARK ROLL, THERMOMARK ROLL, THERMOMARK ROLLMASTER 300/600, THERMOMARK X1.2, mounting type: snap into universal marker groove, snap into tall marker groove, for terminal block width: 50000 mm, lettering field size: 9.5 x 50000 mm, Number of individual labels: 1

Phoenix Contact 2020 © - all rights reserved http://www.phoenixcontact.com

PHOENIX CONTACT GmbH & Co. KG Flachsmarktstr. 8 32825 Blomberg Germany

Tel. +49 5235 300 Fax +49 5235 3 41200

http://www.phoenixcontact.com

# **X-ON Electronics**

Largest Supplier of Electrical and Electronic Components

Click to view similar products for Fixed Terminal Blocks category:

Click to view products by Phoenix Contact manufacturer:

Other Similar products are found below:

MBE-1512 MBE-154 MBE-156 MBES-153 MBES-156 MH-2512 MHE-132 MHE-163 MI-254 (35) MI-272 880507 MPT-275

15602-04-08-21 BA311TU BA411SU MV-152 MV-252-D MV-253/NCNOC MV-254-D MV-255 MV-462 MV-493 MVE-252 MVE-253

MVE-273 MVEB-153 1700096 1705142 1712417 1713020 1713088 1745195 1760594 1776118-2 1790852 1-796689-8 1-796692-6

1800001 1800114 1995279 20020314-C121B01LF CB2-12 KP03215000J0G KP04215000J0G S451 282802-2 29.007 29.116 30.103

30.106